



REPORT

Nestlé Waters Canada - Erin

Technical Study for Permit To Take Water Renewal Application

Submitted to:

Ministry of the Environment, Conservation and Parks


West Central Region
119 King St. W., 12th Floor
Hamilton, ON L8P 4Y7

Submitted by:

Golder Associates Ltd.
S.S. Papadopoulos & Associates, Inc.
C. Portt & Associates
Beacon Environmental

13-1152-0250 (9000)

June 2019



Distribution List

1 Copy - Nestlé Waters Canada

1 Copy - MECP

1 Copy - Golder Associates Ltd.

Executive Summary

Nestlé Waters Canada (Nestlé) is submitting this Technical Study Report in support of its Permit To Take Water (PTTW) renewal application. The current PTTW (Number 3716-8UZMCU) was issued in September 2012 and expired on August 31, 2017. The PTTW renewal application was submitted to the Ministry of the Environment, Conservation and Parks (MECP, formerly the Ministry of the Environment and Climate Change) in May 2017. Well TW1-88 continues to operate under the terms of the existing PTTW in accordance with the Ontario Water Resources Act Section 34.1 (6) until a decision is made regarding the renewal. Key facts and findings presented in the Technical Study Report are as follows:

- The supply well, TW1-88, referred to as the Erin well, is used for the purpose of bottling water and is permitted to pump at 773 L/min (1,113,000 L/day). Nestlé proposes to continue using the well for this purpose with no increase in the permitted water taking.
- TW1-88 has been permitted and operating since 2000.
- Comprehensive annual monitoring reports are prepared for the Erin well (TW1-88) under the conditions of the PTTW that remains in effect.
- In 2014 bottled water consumption surpassed carbonated soft drinks in Canada and continues to grow. Nestlé wants to continue to provide a healthy beverage alternative from its water source in Erin.
- In the past four years (2015 – 2018) the daily takings have ranged from 0 L/day to 937,836 L/day.
- The annual water takings have ranged from a minimum of 54.0 million litres in 2007, to a maximum of 282.8 million litres in 2001. Since 2000, the annual groundwater taking has ranged from approximately 13% to 70% of the current permitted annual taking of 406,288,800 L.
- TW1-88 is completed in the dolostone bedrock aquifer that is overlain by a sandy silt/clay aquitard and a surficial sand and gravel aquifer.
- TW1-88 is located outside of municipal water quality wellhead protection areas (WHPA) but within the upper end of the City of Guelph Eramosa Intake water quantity intake protection zone (IPZ-Q). A review by the Source Protection Committee indicates that the consumptive water use within the IPZ-Q is negligible compared to the natural variability in flow of the Eramosa River at the intake and therefore, on an average basis, consumptive water takings are not expected to impact the municipal surface water intake's ability to pump.
- There have been no well interference complaints arising from the water taking from TW1-88.
- The variations in water levels in TW1-88 are due mainly to short-term changes in the pumping rate. The long-term water level fluctuations in TW1-88 are relatively stable. On-going pumping from TW1-88 has not led to a long-term declining trend in water levels in the well.
- Water levels in the bedrock aquifer have been similar over the years with no long-term increasing or decreasing trend. The influence that pumping TW1-88 has on water levels in other wells decreases with distance from TW1-88.

- Water level fluctuations in the overburden are due to natural seasonal changes and recharge and are not due to pumping TW1-88.
- Water levels in the mini-piezometers fluctuate seasonally with higher water levels observed in the spring and lower water levels observed in the late summer. The water levels also show a response to precipitation and melt events. Overall the water levels have been stable.
- Long-term surface water levels are stable and pumping at TW1-88 does not influence the water levels in the surface water features. Water levels in the surface water features respond to precipitation and melt events.
- Surface water flow is influenced by precipitation and/or melt events and is not influenced by pumping at TW1-88.
- Water quality at TW1-88 has not significantly changed over the last 17 years and is characterized as a calcium-magnesium-bicarbonate type, consistent with a carbonate aquifer.
- Portions of the Erin property include high quality terrestrial, wetland, and aquatic habitats, some of which are designated as provincially and regionally significant. Since 2008, Nestlé has regularly monitored these ecosystems. Some changes have been observed in the various ecological parameters monitored over this period; however, these changes are related to natural succession and beaver activity. All of the changes are considered to be within the expected range of natural variation for the types of ecosystems present. The water taking does not influence the terrestrial, wetland and aquatic ecosystems that are supported by the shallow groundwater system and surface water.
- The withdrawal does not result in physical and ecological impacts to the wetlands in the Eramosa River headwaters, which are monitored and assessed annually.
- There are no long-term adverse impacts to other water users and the environment from the historical water taking from TW1-88 (2000-2018). The water taking does not prevent water users from continuing their established pattern of use. The groundwater withdrawal from TW1-88 does not interfere with existing or future municipal uses.

Table of Contents

1.0 INTRODUCTION	1
1.1 Setting	1
1.2 Historical Summary	1
1.3 Previous Studies	2
2.0 BACKGROUND	3
2.1 Description of Taking	3
2.2 Justification of Bottled Water Taking	4
2.3 Supply Well TW1-88	4
2.4 Land Use	5
2.5 Characterization of the Regional Setting	5
2.5.1 Topography	5
2.5.2 Physiography	5
2.5.3 Ecological Setting	6
2.6 Geology	6
2.6.1 Overburden Geology	6
2.6.2 Bedrock Geology	7
2.7 Hydrogeology	7
2.7.1 Pumping Tests	7
2.7.2 Groundwater Flow	10
2.8 Surface Water Features	10
2.8.1 Grand River Watershed	10
2.8.2 Eramosa River Subwatershed	10
2.8.3 Credit River Watershed	11
2.9 Water Use	11
2.9.1 Private Wells	11
2.9.2 Permitted Water Takings	12

2.10	Source Water Protection	13
2.11	Potential Contaminated Sites.....	13
2.12	Climate	14
2.12.1	Temperature.....	14
2.12.2	Precipitation	15
2.12.2.1	Annual Precipitation	15
2.12.2.2	Monthly Precipitation.....	16
3.0	CONSULTATION	18
4.0	METHODOLOGY	19
4.1	Summary of Long-Term Monitoring Field Program.....	19
4.1.1	Groundwater and Surface Water Monitoring Program	19
4.1.1.1	Water Taking.....	19
4.1.1.2	Groundwater Monitoring Program	19
4.1.1.3	Surface Water Monitoring Program	20
4.1.1.4	Monitoring Locations Which Have Become Inaccessible	21
4.1.2	Biological Monitoring	21
4.1.2.1	Aquatic Resources Monitoring.....	21
4.1.2.2	Terrestrial Resources Monitoring.....	21
4.2	Water Quality Monitoring.....	22
4.3	Tier 3 Modelling.....	22
4.4	Drought and Cumulative Effects Water Quantity Risk Assessment	23
5.0	MONITORING PROGRAM RESULTS	25
5.1	Water Taking.....	25
5.2	Groundwater Levels	25
5.2.1	TW1-88	25
5.2.2	Bedrock Aquifer.....	27
5.2.3	Overburden (Water Table) Aquifer.....	28
5.2.4	Vertical Gradients.....	28
5.3	Surface Water Levels.....	29

5.3.1 Mini-Piezometer Water Levels and Vertical Gradients29

5.3.2 Surface Water Levels.....30

5.4 Surface Water Flow.....31

5.5 Water Quality.....32

5.6 Biological Monitoring32

5.6.1 Aquatic Resources.....32

5.6.2 Terrestrial Resources.....32

6.0 IMPACT ASSESSMENT34

6.1 Impact to Groundwater Users34

6.1.1 Municipal Groundwater Users.....34

6.1.2 Private Groundwater Users.....35

6.2 Impact to Surface Water and Natural Functions of the Ecosystem35

6.3 Water Quality Potential Impacts.....35

6.4 Drought and Cumulative Effects Water Quantity Risk Assessment36

7.0 CONCLUSIONS38

8.0 RECOMMENDED MONITORING PLAN39

9.0 CONTINGENCY PLAN41

9.1 Low Flow Response Plan.....41

9.2 Well Interference Plan.....42

9.3 Other Impacts Identified by the MECP.....42

10.0 REFERENCES43

TABLES

Table 1: Permitted Water Taking at Erin2

Table 2: Erin Annual Withdrawals3

Table 3: Permits To Take Water within 2 km of TW1-88.....12

Table 4: Average Temperatures at Shand Dam (1981-2010)14

Table 5: Annual Precipitation.....15

Table 6: Normal (1981 – 2010) Monthly Precipitation at Shand Dam16

Table 7: Inaccessible Monitoring Locations.....	21
---	----

FIGURES

Figure 1: Site Location	
Figure 2: Site Setting	
Figure 3: TW1-88 Annual Water Taking (2000 to 2018)	
Figure 4: Erin TW1-88	
Figure 5: Land Use	
Figure 6: Topography and Drainage	
Figure 7: Regional Quaternary Geology	
Figure 8: Hydrogeologic Cross-Section A-A'	
Figure 9: Hydrogeologic Cross-Section B-B'	
Figure 10: Hydrogeologic Cross-Section C-C'	
Figure 11: Regional Bedrock Geology	
Figure 12: Potentiometric Surface of Bedrock Aquifer (Non-Pumping Condition January 2000)	
Figure 13: Interpreted Drawdown in Bedrock Aquifer (June 2001)	
Figure 14: Flow in Creek at SW1 on Nestlé Property in Erin	
Figure 15: Flow in the Eramosa River Above Guelph	
Figure 16: MECP Water Well Records	
Figure 17: Historical Annual Precipitation (2008 to 2018)	
Figure 18: Monitoring Locations	
Figure 19: Natural Environment Monitoring	
Figure 20: Potentiometric Surface of Bedrock Aquifer (August 2018)	
Figure 21: Environment Canada Drought Monitoring	

APPENDICES

APPENDIX A

Permit To Take Water

APPENDIX B

Well Information

APPENDIX C

Transmissivity Analysis

APPENDIX D

Groundwater Hydrographs

APPENDIX E

Groundwater Hydrographs (Average)

APPENDIX F

Vertical Gradients (Overburden/Bedrock)

APPENDIX G

Mini-Piezometer Hydrographs

APPENDIX H

Surface Water Hydrographs

APPENDIX I

Surface Water Flow

APPENDIX J

Water Quality

APPENDIX K

Groundwater Modelling Report

APPENDIX L

Well Interference Protocol

1.0 INTRODUCTION

Nestlé Waters Canada (Nestlé) has retained Golder Associates Ltd. (Golder), S.S. Papadopoulos & Associates, Inc. (SSPA), C. Portt and Associates and Beacon Environmental (Beacon) to prepare this Technical Study Report in support of a Permit To Take Water (PTTW) renewal application for TW1-88 at its Erin facility. The current PTTW (Number 3716-8UZMCU) was issued in September 2012. The PTTW renewal application was submitted to the Ministry of the Environment, Conservation and Parks (MECP, formerly the Ministry of the Environment and Climate Change) in May 2017. The current PTTW expired on August 31, 2017, but in accordance with the Ontario Water Resources Act Section 34.1 (6), Nestlé continues to operate TW1-88 under the terms of the existing PTTW until a decision is made regarding the renewal.

On December 16, 2016, Ontario Regulation 463/16 (Taking Groundwater to Produce Bottled Water) came into effect. The regulation prohibits a Director from issuing a new or amended permit that would authorize the taking of groundwater for the purpose of producing bottled water, unless the old permit already authorized the taking of the same or a greater amount of groundwater from the same location and for the same purpose. The PTTW authorizes water taking from one bedrock well located on the Nestlé property in Erin/Hillsburgh. Water from TW1-88 is taken for the purpose of bottling water and Nestlé proposes to continue using the well for this purpose with no increase in the permitted water taking.

This report provides the technical background in support of the PTTW renewal application. The study conforms to the requirements outlined in the Interim Procedural and Technical Guidance Document for Bottled Water Renewals: Permit to Take Water Applications and Hydrogeological Study Requirements prepared by the MECP in April 2017 to evaluate long-term impacts to other water users and the environment from the water taking. The PTTW renewal process and technical study requirements conform with the MECP's Statement of Environmental Values, which are in place "to protect, conserve and where reasonable, restore the integrity of the environment".

With increased focus on health and wellness, Canadians are actively managing their lifestyles and drinking more water, which is considered the most affordable "healthy" beverage. In 2014 bottled water consumption surpassed carbonated soft drinks in Canada and continues to grow. Nestlé wants to continue to provide a healthy beverage alternative from its water source in Erin.

1.1 Setting

The Erin property is located on a 75.5 hectare parcel in the southwest part of Lots 23 and 24, Concession 7, Town of Erin in Wellington County. The well is approximately 4 km west of the Town of Erin (Figure 1), 24 km north-northeast of Guelph, and approximately 35 km north of the Nestlé Aberfoyle bottling facility, to which the water is transported for processing.

The Erin property consists of a water silo, house, barns, paved access drives, ponds, and open fields with wooded areas and wetlands. No pesticides or herbicides are used on the agricultural land owned by Nestlé. Figure 2 is a recent aerial photograph showing the Erin property and land uses on adjacent properties.

1.2 Historical Summary

TW1-88 was constructed in August 1988 by Ryor's Drilling for a party other than Nestlé. In 1989, water was permitted to be taken from the well for a 10-year period at a maximum withdrawal rate of 1,112,860.8 L/day. However, the well was only used one day during this initial 10-year period.

In 1999, further testing was completed at TW1-88 and the well was re-permitted by the original owner. Nestlé purchased the property and began pumping for commercial purposes in March 2000; the well has been permitted continuously since that time. The PTTW allows water to be taken as outlined in Table 1. TW1-88 is permitted for a maximum instantaneous pumping rate of 773 L/min for a total maximum daily water taking of 1,113,000 L/day. A copy of the current PTTW (Number 3716-8UZMCU) is provided in Appendix A.

Table 1: Permitted Water Taking at Erin

Source	Maximum Instantaneous Rate	Maximum Number of Hours of Water Taking per Day	Maximum Daily Water Taking	Maximum Number of Days of Water Taking per Year
TW1-88	773 L/min*	24	1,113,000 L*	365

* The maximum instantaneous rate and maximum daily water taking may increase up to 946 L/min and 1,362,240 L/day ("spike rate") in each month between April 1 and September 30; however, the average daily taking in any month between April 1 and September 30 shall not exceed 1,113,000 L/day.

When water withdrawals for bottling began at the property, tankers were originally filled directly from the well. Starting in 2001, water pumped from TW1-88 has been transferred via pipeline to a 227,305 L stainless steel water storage silo. The silo is used for short-term storage where highway tanker trucks are filled. TW1-88 is located in the northern portion of the property and the loading station is situated in the southern portion of the property.

1.3 Previous Studies

Investigations have been conducted over the years to help establish whether the water supply is sustainable and if there are any impacts to the natural environment. Key investigations are summarized in the following reports:

- Well Construction and Testing Investigation (CRA, 1989); and
- Test Pumping Investigation Supply Well TW1-88 – Draft (CRA, 2006).

In 2000, Nestlé initiated a Long-Term Monitoring (LTM) program to evaluate both natural and pumping-induced changes in water resources. Annual reports of the LTM program have been provided to MECP as required by the PTTWs. Terrestrial and aquatic studies are also completed at the property by Beacon Environmental and C. Portt and Associates, respectively.

2.0 BACKGROUND

2.1 Description of Taking

In the past four years (2015 – 2018), the daily water takings have ranged from 0 L/day to 937,836 L/day which is 84% of the permitted daily water taking of 1,113,000 L/day.

The annual water takings have ranged from a minimum of 54.0 million litres in 2007, to a maximum of 282.8 million litres in 2001. Since 2000, the annual groundwater takings have ranged from approximately 13% to 70% of the current permitted annual taking of 406,288,800 L (Figure 3).

Groundwater withdrawals from Erin well TW1-88 have averaged 362,642 L/day over the last 10 years (2009 – 2018) as shown in Table 2. This rate is 33% of the maximum permitted withdrawal rate of 1,113,000 L/day. In 2018, the equivalent average daily withdrawal rate was 190,152 L/day, 17% of the maximum permitted withdrawal rate. The water takings over the past four years have been lower than the 10-year average.

Table 2: Erin Annual Withdrawals

Year	Total Annual Withdrawal (Litres)	Annual Average Rate (L/day)	Annual Average Percent of PTTW
2009	132,260,857	362,359	33
2010	157,877,281	432,540	39
2011	162,774,434	445,957	40
2012	204,766,809	559,472	50
2013	223,697,991	612,871	55
2014	146,030,433	400,083	36
2015	78,485,480	215,029	19
2016	82,269,338	224,780	20
2017	66,074,786	181,027	16
2018	69,405,417	190,152	17
10-year Average (2009-2018)	132,364,283	362,642	33

As indicated, water withdrawn from TW1-88 is transported to the Aberfoyle facility and used for bottling water purposes. Water is not discharged back to the environment at the Erin property and therefore there are no Environmental Compliance Approvals (ECA) required at the property.

2.2 Justification of Bottled Water Taking

According to A.C. Nielsen (2019), the following key points have been identified regarding the value of bottled water:

- In terms of volume, water is the number one consumed beverage in Canada;
- 74% of Canadians are actively managing their health and wellness lifestyles and are trying to drink more water;
- Water is considered as the most affordable “healthy” beverage, with a repeat purchase rate of 80% amongst consumers;
- Over the past three years, the bottled water category grew by 16%;
- Household penetration of bottled water (defined as the number of households who have purchased bottled water) is approximately 74% in Canada; and
- Household penetration for bottled water has been steadily increasing since and in 2014, bottled water consumption exceeded carbonated soft drinks.

In addition, Health Canada recommends water as the preferred drink of choice in Canada’s Food Guide.

Bottled water is not only important from an economic and health perspective, it is essential in time of emergencies. In 2017 and 2018, Nestlé donated over 2 million bottles of water to Canadians in crises during floods and fires, charitable donations and homelessness initiatives. Nestlé also has a partnership with the Canadian Red Cross to support the organization in times of need.

The above information indicates how important the bottled water industry is and based on the current consumer demand Nestlé is requesting that the water taking be kept at the same daily rate and amount as in the current permit. Over the past five years, there have been days when Nestlé has taken 90% or greater of their maximum daily permitted takings to meet peak demands. The volume of water withdrawn fluctuates based on demand. That demand varies from day to day and week to week so having flexibility is key to running an efficient business that enables Nestlé to respond to consumer and customer needs.

Also, Nestlé’s Erin facility is located in an area without municipal water supply; therefore, a portion of the water is also used to run the daily operations (i.e., flushing of silos). Nestlé is committed to continuously improving its water efficiency; however, this needs to be factored in to the overall water usage.

The Erin source currently represents the only source of redundancy for their Aberfoyle operation (i.e. a redundant supply is critical for any business). The Erin maximum permitted capacity can support approximately 50% of the Aberfoyle plant needs and therefore, is essential until a secondary back up source can be brought on-line. The Erin source is also currently the only source that can provide some operational flexibility for their Aberfoyle operation when conducting well maintenance and testing on the Aberfoyle source.

2.3 Supply Well TW1-88

The borehole log for TW1-88 is provided in Appendix B. TW1-88 is interpreted to be completed within the Guelph Formation limestone and dolostone. The bedrock is overlain by glacial sediments that are 19.5 m thick at TW1-88. The overburden consists of two general units: the uppermost unit consists of interlayered sand and gravel

with varying amounts of silt to a depth of 12.2 m below grade, and the lower unit consists of 7.3 m of sandy silt till/clay till. A 170 mm diameter high-carbon steel casing was drilled through the overburden and into the bedrock, and grouted 1.4 m into the bedrock at a depth of 20.9 m below grade. The well was completed as a 160 mm open borehole in bedrock with a depth of 57.3 m.

In 2010, a downhole video survey revealed that the original high carbon steel casing had some pitting (CRA, 2014). To prevent potential casing failure in the future and to upgrade the well to Nestlé standards, the original casing was overdrilled and removed, and a 200 mm diameter stainless steel casing was installed to a depth of 21.8 m. The new casing was cement grouted in place.

The lower portion of the well was noted to have been completed within a poor production zone (CRA, 2014). The bottom 18.3 m of the well was grouted with cement from 57.3 m to 39 m below grade in 2010. The revised water well record (Well Tag No. A095193) is included in Appendix B, and a schematic of the well is shown on Figure 4.

A nominal 152 mm diameter Grundfos pump (Model 230S200-6) with a 20 hp, 575 V, 3 phase motor, is currently installed in the well. The submersible pump installed in TW1-88 is suspended on 25.8 m of nominal 76 mm diameter schedule 40 stainless steel riser pipe.

2.4 Land Use

The Erin property consists of a 75.5 hectare parcel of land with open fields, wooded areas and wetlands (Figure 2). Local land uses surrounding the Nestlé property are illustrated on Figure 5 and include:

- Rural residential;
- Agricultural; and
- Vacant land to the northeast.

The Town of Hillsburgh, approximately 1 km north of TW1-88, consists of a variety of residential, commercial, and institutional uses. The built-up area of Hillsburgh continues southeast along Trafalgar Road, east of the TW1-88 property.

Nestlé is committed to preserving the natural environment and protecting the water supply within the land area that it controls.

2.5 Characterization of the Regional Setting

2.5.1 Topography

The topography and drainage of the property and surrounding area is shown on Figure 6. The regional topography is characterized by knobby hills surrounded by low-lying wetlands and/or streams with overall ground elevations increasing to the northwest. Ground surface elevations are highest near the middle of the property (450 masl) and decline toward the northwest (430 masl) and southern (410 masl) parts of the property. The topography is relatively flat in the northern part of the property and rolling elsewhere. In general, surface water features occur within the topographic lows.

2.5.2 Physiography

The area is situated between the physiographic regions described by Chapman and Putnam (1984) as the Guelph Drumlin Field (to the south) and the Hillsburgh Sandhills (to the north). Chapman and Putnam (1984)

characterize the Guelph Drumlin Field as drumlins fringed by gravel terraces and separated by swampy valleys in which flow sluggish tributaries of the Grand River. The drumlins are made up of glacial till. Chapman and Putnam (1984) characterize the Hillsburgh Sandhills as a glacial spillway with knobby hills. Surficial soils are generally sandy with swampy valleys.

2.5.3 Ecological Setting

The upland portions of the property comprise agricultural fields. The low-lying areas support forest and wetlands (Figure 2). The wetlands on the Grand River watershed portion of the property are part of the Speed Lutteral Swan Creek Wetland Complex. The wetlands on the Credit River watershed portion of the property are part of the West Credit River Wetland Complex. Both wetland complexes are designated as Provincially Significant Wetlands. The wetlands are generally undisturbed and support a diverse range of flora and fauna, including some that are ranked as locally significant.

2.6 Geology

The geology in the area has been interpreted based on published mapping, water well records, and detailed stratigraphic logging (CRA, 2014). Borehole logs are included in Appendix B.

2.6.1 Overburden Geology

The regional quaternary geology in the area of the property is shown on Figure 7. The surficial overburden of the area is characterized by the following units:

- Organic deposits;
- Glaciofluvial sandy deposits;
- Ice-contact stratified deposits; and
- Silty to sandy till.

The area to the south, southeast and east of the property generally contains silty to sandy till at surface with ice-contact stratified drift and glaciofluvial sand and gravel deposits occurring mainly in the low-lying areas. The area west, northwest and north of the property generally contains ice-contact stratified deposits that make up the surficial soils of the Orangeville Moraine. The property lies between these features, with till deposits occurring through the middle of the property where ground elevation is higher and sand and gravel deposits occurring toward the northwest and southeast parts of the property.

Three cross-sections through the property have been developed (Figures 8 through 10) with the locations shown on Figure 7 (CRA 2014). Two overburden stratigraphic units are interpreted to be present in the vicinity of the property:

- An upper sand and gravel originating from glaciofluvial outwash or ice-contact stratified drift; and
- A lower sandy silt/clay till.

The sand and gravel unit consists of sand, gravel, or sand and gravel, and generally increases in thickness to the northwest of TW1-88, but is generally absent to the south, southeast, and east of TW1-88. The sandy silt/clay till is continuous across the property and is present below the sand and gravel unit or at surface where the sand and gravel unit is not present. The till typically ranges in thickness from about 5 m to 35 m within 1 km of TW1-88.

2.6.2 Bedrock Geology

The regional bedrock geology is shown on Figure 11. The uppermost bedrock unit consists of dolostone of the Guelph Formation below the property, and dolostone of the Amabel Formation (the Ontario Geological Survey now identifies the rock of the Amabel Formation as comprising the Eramosa, Goat Island, Gasport or Irondequoit Formations) east of the property. Liberty (1975) describes the Guelph Formation in this area as light brown, fine to medium crystalline sucrosic dolostone. TW1-88 is completed within the Guelph Formation.

2.7 Hydrogeology

There are three hydrostratigraphic units present at the property as follows (from top to bottom):

- Surficial sand and gravel aquifer;
- Sandy silt/clay till aquitard; and
- Dolostone bedrock aquifer (Guelph Formation).

The Erin property is located in a regional recharge area of a very large and robust bedrock aquifer system. The water table generally lies within the surficial sand and gravel aquifer. The direction of groundwater flow within the water table aquifer occurs in a southerly to southwesterly direction in the vicinity of TW1-88. Water recharges regionally through the glacial overburden and into the Guelph aquifer on the Orangeville Moraine, generally north and northwest of the Erin property.

The surficial sand and gravel aquifer and bedrock aquifer are separated by a sandy silt/clay till unit which acts as an aquitard. The difference in water levels between the aquifers indicates that the till acts as an aquitard and that a downward vertical gradient exists under both pumping and non-pumping conditions.

The bedrock aquifer does not supply the pond network on the Erin property. The potentiometric surface of the bedrock aquifer is approximately 5 metres below the surface elevation of the on-Site pond. The bedrock aquifer also does not discharge to the tributary of the Eramosa River that flows from the wetland to the pond network. The tributary is supplied almost exclusively by runoff from surrounding topography, precipitation on the wetlands and pond and discharge from the overburden aquifer.

The carbonate units of the Guelph Formation comprise a regional aquifer, utilized by residential, commercial, and municipal water supplies. The bedrock aquifer is the main water supply aquifer in the vicinity of the property for both the Nestlé supply and private wells.

2.7.1 Pumping Tests

To better understand the hydraulic characteristics of the aquifers on a larger scale and determine flow within the groundwater system, pumping tests have been conducted on the property. Two pumping tests have been completed at the property as follows:

- TW1-88 - 24-hour initial test in August 1988; and
- TW1-88 – 7 day test in November 2005.

A summary of the testing is as follows. A copy of the original pumping test report is included on CD (attached).

1988 Pumping Test

- 24-hour pumping of TW1-88 at 546 L/min;
- Drawdown at TW1-88 stabilized at 6.9 m after 6 hours of pumping;
- Estimated transmissivity of 170 m²/d;
- The fine-grained till provides some degree of protection from surface contaminants which could potentially migrate to the underlying bedrock; and
- A sustained yield of 546 L/min was demonstrated and it was estimated that a yield of 773 L/min could be maintained based on the size of the well.

2005 Pumping Test

- Seven (7)-day pumping test of TW1-88 at 1,227 L/min with 12.5 hours of shutdown prior to the test;
- Drawdown at TW1-88 stabilized at 13.7 m after about 8 hours of pumping;
- Groundwater flow in the bedrock aquifer under static conditions is to the southeast;
- Groundwater flow in the bedrock under pumping conditions indicates that although some flow is directed toward TW1-88, the overall flow to the southwest is maintained (pre-pumping flow paths exist at a distance of about 1,000 m to the northwest and southeast of TW1-88);
- The area in the bedrock affected by pumping is elongated to the southwest. Based on the 1 m drawdown contour, the area influenced by pumping extends about 850 m to the northwest, 850 m to the southeast, and 650 m to the northeast of TW1-88. The 1 m drawdown contour is not defined to the southwest;
- Water level changes in the overburden were generally not evident or less than 0.1 m with vertical hydraulic gradients remaining unchanged;
- Surface water flow did not appear to be influenced by pumping;
- No complaints were received during the test; and
- A long-term yield of 1,227 L/min was sustained.

Transmissivity Estimate

Consistent estimates of the transmissivity of the Guelph Formation in the vicinity of TW1-88 are obtained from the data collected during the controlled pumping tests and from the interpretation of ongoing well performance data.

Step and constant-rate pumping tests have been conducted at TW1-88 in 1988 and 2005 (CRA, 1989; 2006). The results of the testing are summarized graphically on Figure C1, in which the pumping rates are plotted against the observed drawdowns in the well. The data from the 1988 step test and the two constant rate tests approximate closely a straight line, suggesting that nonlinear well losses in TW1-88 are negligible. The data also suggest that the pumped aquifer is effectively confined, with the water level in the well remaining at all times above the top of the primary bedrock flow zones.

The slope of the straight line shown on Figure C1 is designated the specific capacity of TW1-88. The specific capacity is estimated to be 1.53 L/s/m of drawdown as described further in Section 5.2.1.

Following the approach of Driscoll (1986), a preliminary estimate of the transmissivity (T) can be obtained from the specific capacity (SC) as follows:

$$T \sim 1.3 \text{ SC}$$

Therefore, as a first approximation:

$$T \sim 1.3 \left(1.53 \frac{\text{L/s}}{\text{m}} \right) \left| \frac{\text{m}^3}{1000 \text{ L}} \right| \left| \frac{84600 \text{ sec}}{\text{day}} \right| = 170 \text{ m}^2/\text{d}$$

Since the drawdowns plotted on Figure C1 correspond to stable conditions, and the data approximate a straight line, the transmissivity can also be estimated with the steady-state Thiem solution [see Bear (1979), page 304, for example]:

$$T = \text{SC} \frac{1}{2\pi} \ln \left\{ \frac{R}{r_w} \right\}$$

Here r_w denotes the radius of TW1-88 and R represents the effective radius of influence. It is not possible to estimate the radius of influence of TW1-88 from only the drawdown data for the pumping well. However, as shown on Figure C2 the estimated transmissivity is not particularly sensitive to its assumed value. Over a relatively wide range of the assumed value of R/r_w the transmissivity is on the order of 200 m^2/d , which is consistent with the preliminary estimate.

As discussed further in Section 5.2.1, the historical performance of TW1-88 and the long-term performance data for TW1-88 are consistent with the estimated specific capacity of 1.53 L/s/m. Therefore, these data would also support a transmissivity estimate of about 200 m^2/d .

Distributions of drawdowns in the Guelph Formation caused by pumping TW1-88 are presented in CRA (2006) and CRA (2014). The distribution of drawdown interpreted at the end of the 7-day pumping test conducted in 2005 is reproduced on Figure C3. The distribution of drawdown interpreted at the end of 18 hours of pumping in 2001 is reproduced on Figure 13. The distributions of drawdown highlight both the consistency of the responses at different pumping rates, and the relatively smooth nature of the response in the rock. The distributions suggest that it is appropriate to interpret the effects of pumping with an equivalent porous medium conceptualization.

A Cooper Jacob analysis of the drawdowns in TW1-88 during the 1988 constant rate pumping test is shown on Figure C4. The slope of the portion of the response that is representative of the response of the formation yields a transmissivity estimate of about 180 m^2/day :

$$\begin{aligned} T &= 2.303 \frac{Q}{4\pi} \frac{1}{\text{SLOPE}} \\ &= 2.303 \frac{(9.1 \text{ L/s})}{4\pi} \frac{1}{(0.80 \text{ m})} \left| \frac{\text{m}^3}{1000 \text{ L}} \right| \left| \frac{86400 \text{ sec}}{\text{day}} \right| = 180 \text{ m}^2/\text{day} \end{aligned}$$

This transmissivity estimate is similar to the estimates developed from the specific capacity of TW1-88.

The drawdowns at the end of the 7-day constant rate pumping test conducted in 2005 are plotted on Figure C5. The transmissivity estimated from a Cooper Jacob distance drawdown analysis is:

$$T = 2.303 \frac{Q}{2\pi} \frac{1}{\text{SLOPE}}$$

$$= 2.303 \frac{(270 \text{ Igpm})}{2\pi} \frac{1}{(3.03 \text{ m})} \left| \frac{\text{m}^3}{219.969 \text{ lgal}} \right| \left| \frac{1440 \text{ min}}{\text{day}} \right| = 210 \text{ m}^2/\text{day}$$

This transmissivity estimate is again similar to the estimates developed from the other analyses.

The consistency of the transmissivity estimates, and the regular and reproducible patterns of the interpreted drawdowns suggest that the properties of the Guelph Formation in the vicinity of TW1-88 are predictable and amenable to conventional methods of analyses.

2.7.2 Groundwater Flow

The regional bedrock aquifer is inferred to be recharged through the Orangeville Moraine north to northwest of TW1-88. Groundwater flows generally south to southeast in the direction of TW1-88, approximately parallel with the surface water divide between the Grand River and the Credit River watersheds. The bedrock aquifer extends to the south and west toward Guelph and Fergus. The Niagara Escarpment outcrop, which is the abrupt extent of the bedrock aquifer system, is about 12 km east of the property.

The potentiometric surface prior to pumping (January 24, 2000) is shown on Figure 12 (CRA 2014). Groundwater flow in the absence of pumping is to the south-southeast with a horizontal gradient of about 0.015 m/m. CRA (2014) notes that static water levels typically ranged from 6 to 16 m bgs, and the water level at TW1-88 before pumping began was about 10 m bgs (i.e., elevation of 424.3 masl).

A map showing the drawdown in the bedrock aquifer on June 15, 2001, after 18 hours of pumping TW1-88 at 773 L/min, is included on Figure 13 (CRA, 2014). The map shows that the zone of influence at this pumping rate (based on a drawdown of 0.1 m) extends approximately 1,000 m from TW1-88 to the west, north and east; and to the south and southwest, the zone of influence is greater than 700 m from TW1-88.

2.8 Surface Water Features

Well TW1-88 is situated in the Grand River watershed, near the surface water divide with the Credit River watershed (Figure 1). Specifically, TW1-88 is located in the Eramosa River subwatershed of the Grand River. The following sections discuss surface water features and flow measured in parts of the regional (Grand River and Credit River) and local (Eramosa River) watersheds.

2.8.1 Grand River Watershed

The Grand River flows 290 km through southern Ontario, from its source near the village of Dundalk just south of Georgian Bay, to Port Maitland at Lake Erie. Together with its major tributaries, it drains 6,965 square kilometres and is the largest watershed in southern Ontario. The Grand River traverses through wetlands, gorges, farmlands, gravel moraines, Carolinian Forest, and broad marshes (Grand River Conservation Authority, 2019 and Canadian Heritage Rivers System, 2019).

The nearest Grand River gauging station to Erin is located in Galt, downstream of where the Eramosa River flows into the Speed River which in turn flows into the Grand River. From 2008 through 2018, the average flow at this station was 46,876 L/s and the median flow was 26,850 L/s. The flow has ranged from a minimum flow of 6,441 L/s to a maximum flow of 780,000 L/s.

2.8.2 Eramosa River Subwatershed

There are two ponds on the Nestlé property within the watershed, as shown on Figure 6: one pond referred to as the “on-Site Pond” located approximately 135 m southwest of TW1-88, and one pond referred to as the “Wetland

Pond”, approximately 265 m south-southeast of TW1-88. The ponds discharge to an unnamed perennial tributary of the Eramosa River that flows in a southwest direction. Flow in the unnamed creek has been measured by Nestlé at a location immediately west of the property (SW1) as shown on Figure 14. Flow has been measured as high as 91 L/s but typically ranges from 10 L/s to 30 L/s (Figure 14).

The Eramosa River originates west of the property and flows generally in a northeast to southwest direction through Wellington County to the City of Guelph, where it joins the Speed River, which then flows into the Grand River in Cambridge. The catchment area of the Eramosa River subwatershed is 275.9 square kilometres (106.5 square miles).

Flow in the Eramosa River is monitored by the GRCA at a station near Guelph (Eramosa River WSC Station 02GA029), approximately 25 km southwest of the property. Data are publicly available for the station and the stream flow record is presented on Figure 15. The average flow near Guelph for the last 10 years (January 2009 through December 2018) is 2,610 L/s and the median flow is 1,710 L/s.

2.8.3 Credit River Watershed

The Erin Branch of the Credit River is located east of the property and flows in a general southeasterly direction, ultimately discharging to the Credit River. At its closest point, the creek is located approximately 470 m from TW1-88. Off the property (to the north and east), there are three large on-line ponds located along the Erin Branch of the Credit River. Another large surface water body located within the Credit River watershed, referred to as Roman Lake, is located about 1.2 km southeast of TW1-88. The Credit River ultimately discharges to Lake Ontario near Mississauga, Ontario.

2.9 Water Use

Local groundwater use consists of low-capacity residential use, commercial use, and municipal use. The higher water uses are for municipal supply (Hillsburgh and Erin) and bottling water.

2.9.1 Private Wells

There are some water takers that use less than 50,000 L/d, including commercial and agricultural use. The majority of wells in the vicinity of TW1-88 are private residential wells for typical household use. These wells are completed within the overburden or bedrock aquifers.

To gain a better understanding of the number of wells in the area, water well records were downloaded from the MECP website and are plotted on Figure 16. There are 60 water well records within 1 km of TW1-88 (Table B1 in Appendix B). The reported uses of those wells include 8 observation wells, 44 water supply wells, 6 abandoned wells and 2 with no use listed. Of the 44 water supply wells, the uses include 39 domestic, 2 commercial and 3 livestock. There are 7 water supply wells completed in the overburden and 37 completed in the bedrock.

Private well surveys are typically conducted to identify existing water users, collect well construction details and well use data and confirm the location of the wells to help assess potential impacts of the proposed water taking. Private well surveys have been conducted in the past around the Erin facility to identify wells for monitoring, as part of pumping tests and/or as part of previous studies. These included an initial survey in 1999, a survey in 2005 as part of the pumping test and a survey in 2007 to identify additional monitoring locations. As part of this study, a private well survey was conducted to update and/or provide additional information on private wells in the area.

Since there are a large number of private wells in the area, and previous surveys have been completed, a subset of the wells was identified and assessed for this study. The approach adopted to identify the subset is described below:

- 1) Identify water well records within 1 km of TW1-88 (approximate zone of influence);
- 2) Select water well records that are used for water supply (active wells);
- 3) Remove wells monitored by Nestlé (already monitored);
- 4) Remove water well records that plot in the wrong location (unknown reliability);
- 5) Remove water well records that are located in subdivisions with a water supply (wells likely not used anymore); and
- 6) Remove water well records constructed prior to 2000 (start of Nestlé water taking).

Following the screening, five (5) wells were selected for the private well survey. The private well survey was conducted on June 21, 2018 during the daytime working hours. At private residential locations, if there was no one home during the day, a letter and survey were left in the door or mailbox (see Appendix B for the letter and survey form). One owner completed the survey, one owner did not want to participate and one location was on the Nestlé property. The two additional locations not on the Nestlé property were gated. Since access could not be achieved, a second attempt to survey the domestic wells was not attempted; however, the letter and survey were left in the mailbox. A summary of the private well survey is included in Table B2 in Appendix B. Of the surveys delivered only one survey was completed for the location with Well ID 6714803.

2.9.2 Permitted Water Takings

A search of the MECP database indicates that there are two other water takings within 2 km of TW1-88 with a PTTW. Details of the PTTWs are listed in Table 3.

Table 3: Permits To Take Water within 2 km of TW1-88

Name	PTTW Number	Purpose	Source	Maximum Litres per Day	Maximum Days of Taking per Year
The Corporation of the Town of Erin	7740-A9ZNTF	Municipal Water Supply	Well H3	655,000	365
	6306-8X5KRY		Well H2	982,000	365

These PTTWs are for the municipal wells in Hillsburgh (Figure 2). In 2016, the average day pumping at H3 was 86.7 m³/day (13.3% of permitted rate) and increased to 103.5 m³/day (15.8% of permitted rate) in 2017. The average day pumping at H2 was similar in 2016 and 2017 at 75.9 m³/day (7.7% of permitted rate).

2.10 Source Water Protection

With the passing of the Clean Water Act (2006), municipalities in Ontario are required to develop source protection plans to protect their municipal sources of drinking water. These plans identify both water quality and water quantity risks to local drinking water sources and develop strategies to reduce or eliminate these risks. Potential and existing risks for a municipal source are identified within wellhead protection areas (WHPAs). A WHPA is an area projected to ground surface that reflects the zone in an aquifer where groundwater is flowing to a municipal drinking water source (pumping well). These areas are defined to protect water quality. The Nestlé Erin property and well TW1-88 are located more than 1.4 km from the closest WHPAs, which include the Hillsburgh WHPA to the north and the Erin WHPA to the east.

In addition to protecting water quality, water quantity is also a concern and is being considered under Water Quantity Protection Plans, which are currently being established. The Water Quantity assessment is completed to ensure that future water needs of a community can be met. It identifies existing water quantity threats and future activities that may limit municipal water supplies. This is important because when more water is taken from an area than can be naturally replenished, water supplies are threatened and water shortages are possible. The Erin property falls within the upper end of a Water Quantity Intake Protection Zone (IPZ-Q) for the City of Guelph Eramosa Intake on the Eramosa River, which has been assigned a significant risk level (Matrix Solutions 2017). The IPZ-Q was assigned a significant risk level because of interconnection through the City of Guelph Arkell Water System. As a result, each of the consumptive water uses within the IPZ-Q are categorized as significant; however, the net consumptive water use within the IPZ-Q is small compared to the natural variability in flow of the Eramosa River at the intake (Matrix 2018a). Therefore, on an average basis, consumptive water taking threats are not expected to affect the municipal surface water intake's ability to obtain water. Further assessment of the threats was carried out as part of the climate changes assessment (Matrix 2018b). The municipal and non-municipal threats were ranked as follows: 1) Arkell Wells, 2) Glen Collector, 3) Non-Municipal PTTWs, and 4) Rockwood Wells. The Nestlé water taking is one of twelve water takings that fall within the third-ranked threat of four threats. The study indicates that the total potential influence of municipal and non-municipal takings on streamflow in the Eramosa River at Gauge 02GA029 is a reduction in flow of 0.287 m³/s; the amount represents approximately 12% of the mean annual flow (2.3 m³/s) (Matrix 2018b). Within this total, the impact of permitted municipal pumping rates represents 85% of the total potential impact of permitted water takings on the Eramosa River intake. The Water Quantity assessment conducted for the Nestlé takings at TW1-88 as described in Section 4.3. The assessment was completed using the Guelph Tier 3 Model, which has been updated and used for this study.

2.11 Potential Contaminated Sites

The land use within 1 km of TW1-88 consists of residential, agricultural and vacant land. Based on the land use mapping (Figure 5), there are no potential contaminated properties identified within 1 km of the Nestlé pumping well. Nestlé monitors surrounding land uses to identify potential future concerns that may arise with respect to source water protection. Nestlé purchased a neighbouring property with potential contamination concerns and conducted a clean-up of the site.

Nestlé does not use any pesticides or herbicides on its property (included in an agreement with the farmer) and reduces salt usage for de-icing in the winter as much as possible (i.e., preference to use sand). Further discussion on water quality monitoring (Section 4.2), water quality results (Section 5.5) and potential impacts (Section 6.3) are provided below.

2.12 Climate

Daily weather statistics (meteorological data) have been recorded at the Orangeville MOE station (ID #6155790) from 1961 to 2015 and at the Shand Dam station (ID #6142400) from 1939 to present. The weather stations are part of the Environment Canada network.

Climatic normals discussed in the following sections, calculated as statistical averages of weather data from the previous 30 years, are currently based on the 1981 to 2010 period of record.

2.12.1 Temperature

The average yearly temperature over the 1981 to 2010 period at Orangeville is 6.3°C. The average yearly temperature over the 1981 to 2010 period at Shand Dam is 6.7°C. During the 30-year period, daily average normal temperatures at Orangeville range from -7.5°C in January to 19.4°C in July and from -7.4°C in January to 20°C in July at Shand Dam. The extreme maximum temperature recorded at the Orangeville station was 35.5°C in August 1988 and the extreme minimum was -36.5°C in February 1979. The extreme maximum temperature recorded at the Shand Dam station was 35.5°C in July 1988 and the extreme minimum was -35°C in January 1943. The daily average, maximum, and minimum temperatures at Shand Dam are summarized in Table 4.

Table 4: Average Temperatures at Shand Dam (1981-2010)

Month	Daily Average Temperature (°C)	Daily Average Maximum Temperature (°C)	Daily Average Minimum Temperature (°C)
January	-7.4	-3.6	-11.1
February	-6.3	-2.1	-10.5
March	-1.9	2.6	-6.5
April	5.7	10.4	0.9
May	12.2	17.5	6.9
June	17.5	22.8	12.2
July	20.0	25.2	14.7
August	19.0	24.2	13.8
September	14.9	19.8	9.9
October	8.3	12.7	3.9
November	2.1	5.4	-1.2
December	-3.9	-0.7	-7.1
Year	6.7	11.2	2.2

2.12.2 Precipitation

Precipitation recorded at the Orangeville and Shand Dam meteorological stations are used as a component of the LTM program. Prior to 2016, the data were collected from the Orangeville station and augmented with data from the Shand Dam station. From 2016 to present, the data are from the Shand Dam station as precipitation data are no longer recorded at the Orangeville station.

It is recognized that there are differences between the amounts of precipitation recorded at the different stations sometimes due to localized precipitation events such as thunderstorms or snow squalls. It is impossible to obtain a perfectly representative estimate of the annual precipitation over the full extent of the area of contribution for the Nestlé Erin well. What is most important is that adopting a consistent approach from year to year allows an assessment of the differences with respect to long-term average conditions (30-year climate normals). An analysis of precipitation trends is conducted to see if there is a correlation with water level trends. We note that the actual influence on water levels (groundwater) would be due to recharge and not total precipitation, and that recharge is controlled by more than just precipitation. However, in the absence of detailed recharge data in the area, the use of precipitation totals allows for some comparison of long-term changes in water levels, particularly in the shallow monitors (overburden and mini-piezometers).

2.12.2.1 Annual Precipitation

The annual average (1981-2010) precipitation from the Orangeville Station is 901.5 mm which is slightly higher than the previous average (1971-2000) of 891.7 mm. The annual average (1981-2010) precipitation from the Shand Dam Station is 945.7 mm which is again slightly higher than the previous average (1971-2000) of 938.5 mm. A summary of the total annual precipitation over the past ten years is provided in Table 5. Annual precipitation is also shown graphically on Figure 17 along with the 30-year normal. More than 10% below-average precipitation occurred in 2012 and 2015 with more than 10% above-average precipitation occurring in 2009, 2010, 2011, 2013 and 2017. Total precipitation declined over the period from 2010 to 2012 and again from 2013 to 2015.

Table 5: Annual Precipitation

Year	Precipitation (mm)	Difference Between Actual and Average Precipitation (mm)	% Difference from Average
2009	1044.9 (Orangeville)	143.4	15.9
2010	1113 (Orangeville)	211.5	23.5
2011	1077.7 (Orangeville)	176.2	19.5
2012	803 (Orangeville)	-98.5	-10.5
2013	1035.7 (Orangeville)	134.2	14.9
2014	954.5 (Orangeville)	53.0	5.9

Year	Precipitation (mm)	Difference Between Actual and Average Precipitation (mm)	% Difference from Average
2015	783.1 (Orangeville)	-118.4	-13.1
2016	1032 (Shand Dam)	86.3	9.1
2017	1109.6 (Shand Dam)	163.9	17.3
2018	953.3 (Shand Dam)	7.6	0.8
Average (1981-2010)	901.5 (Orangeville), 945.7 (Fergus Shand Dam)		

2.12.2.2 Monthly Precipitation

A summary of the monthly average precipitation is included in Table 6 for Shand Dam. The driest month of the year at the Shand Dam station is February, with an average precipitation of 55.9 mm. The wettest month is August, with an average precipitation of 96.6 mm.

Table 6: Normal (1981 – 2010) Monthly Precipitation at Shand Dam

Month	Rainfall (mm)	Snowfall (cm)	Precipitation (mm)
January	27.8	40.1	67.9
February	25.3	30.6	55.9
March	36.7	22.9	59.6
April	67.9	6.2	74.1
May	86.8	0.1	86.9
June	83.8	0	83.8
July	89.2	0	89.2
August	96.6	0	96.6
September	93.1	0	93.1
October	75.6	1.6	72.2
November	80.5	12.5	93.0

Month	Rainfall (mm)	Snowfall (cm)	Precipitation (mm)
December	34.7	33.9	68.6
Year	797.8	147.8	945.7

3.0 CONSULTATION

There is value in involving those with a potential interest or those who may be affected by the water taking proposal to have opportunities to provide input during the application process. This consultation protects those interested and helps ensure concerns are identified early and addressed where possible. This consultation was conducted during the pre-submission phase of the application process and a summary is included in the application package.

4.0 METHODOLOGY

4.1 Summary of Long-Term Monitoring Field Program

This section describes the field activities that are performed as per the conditions of PTTW Number 3719-8UZMCU (for TW1-88) or performed per the conditions of previous PTTWs.

4.1.1 Groundwater and Surface Water Monitoring Program

Groundwater and surface water monitoring was initiated in 2000 and has evolved over the years with the objectives to 1) characterize the existing hydrogeologic setting, and 2) document potential long-term changes to the groundwater and surface water resources in the area. The monitoring program includes measurement and record-keeping of water takings, groundwater levels, mini-piezometer levels, surface water levels and flows. The monitoring program includes the following instrumentation, with the locations shown on Figure 18:

- Groundwater levels and water takings in the production well (TW1-88);
- Groundwater levels in 15 monitors wells at 9 locations;
- Shallow groundwater levels in 7 piezometer nests with a total of 14 monitors (shallow and deep pair);
- Surface water levels at 6 stations;
- Surface water flow at 3 stations; and
- Water levels at 13 private wells on 9 properties (3 of the 13 are no longer monitored since 2014 due to access restrictions).

Data are recorded at several stations on an hourly basis, and manual groundwater and surface water monitoring are conducted on a monthly basis when the data are collected from the dataloggers.

4.1.1.1 Water Taking

Water taking from TW1-88 is measured using an Endress & Hauser Promag magnetic flow meter connected to an Allen-Bradley industrial Programmable Logic Controller. The instantaneous flow and volume are recorded every minute. The flow meter was most recently calibrated on November 5, 2018 by Endress & Hauser (per Nestlé).

The water takings from supply well TW1-88 are described in Section 2.1.

4.1.1.2 Groundwater Monitoring Program

Groundwater levels have been measured at various locations since a monthly water level monitoring program was initiated in January 2000. Changes have been made over time as wells have become inaccessible. The monitoring locations for the groundwater monitoring program are shown on Figure 18 and are summarized as follows:

Overburden Monitors

- TW1/99, MW2, MW3A/B, MW5B, MW6B, MW11B-08, MW12B-08, D2B (no longer accessible), D7B, D26C, D27, D36A

Bedrock Monitors

- TW1-88, MW5A, MW6A, MW11A-08, MW12A-08, D2A (no longer accessible), D3, D8, D15, D19 (no longer accessible), D24A, D24B, D26A, D26B, D32, D36B

4.1.1.3 Surface Water Monitoring Program

The surface water monitoring program includes the following components, with locations shown on Figure 18:

- Surface water levels;
- Stream flow; and
- Water levels in nested mini-piezometers.

Surface water levels and flow have been measured since a monitoring program was initiated in January 2000.

Surface Water Levels

Currently, surface water levels are measured at the following locations:

- ST03-05, SW1, SW3, SW4, SW5, SW7

Water levels are measured at all locations on a monthly basis using a water level meter and hourly using pressure transducer dataloggers.

A new station (SW7B) was established in the Erin Branch of the Credit River by D7B in May 2016. The site was chosen at a location with more favourable hydraulics (i.e., single channel, stable conditions and no backwater). This station will eventually replace SW7, which is located in an area with changing stream conditions and flooding.

Stream Flow

Currently, stream flows are measured at the following locations:

- SW1, SW3, SW7

Stream flow velocities are measured using a Valeport electromagnetic flow meter and the surface water flows are calculated using the cross-sectional area-velocity method.

The monthly surface water elevations (“stage”) and stream flow measurements (“discharge”) collected are used to establish the stage-discharge relationships (rating curves) at SW1 and SW7. The rating curves are used to calculate stream flow from the continuous water level measurements at these stations. Flow at SW3 is also measured on a continuous basis using a Stingray Flow Meter.

Mini-Piezometers

Currently, water levels are measured in mini-piezometers at seven locations, each containing a shallow and a deep monitor.

- P1A/B-07, P3A/B-05, P6A/B-07, P10A/B-05, P11A/B-05, P12A/B-07, P13A/B-07

The average elevation difference between the middle of the shallow screen and the middle of the deep screen is 1.2 m with actual separation differences ranging from approximately 0.6 to 1.6 m.

4.1.1.4 *Monitoring Locations Which Have Become Inaccessible*

In 2014, homeowners requested that monitoring be discontinued at three wells. A list of these wells along with a recommended replacement are provided in Table 7.

Table 7: Inaccessible Monitoring Locations

Monitoring Location	Reason for Inaccessibility	Recommendation	Documented In Letter to MECP
D19	In October 2014, the resident notified Nestlé that they would no longer like their well monitored.	No additional wells to be monitored in place of D19 as there are other wells in the area that can be monitored.	October 10, 2014
D2A	In December 2014, the resident notified Nestlé that they would no longer like their well monitored.	Install a monitoring well on a neighbouring property in the future if land access is granted.	December 2, 2014
D2B	In December 2014, the resident notified Nestlé that they would no longer like their well monitored.	No additional wells will be monitored in place of D2B as there are no impacts to the overburden aquifer and there are other wells being monitored in the overburden.	December 2, 2014

4.1.2 *Biological Monitoring*

Biological monitoring is not a requirement of the PTTW at Nestlé's Erin property. Nestlé voluntarily undertakes biological monitoring at this property as part of its natural resource management program. The information collected is used to monitor the state and condition of the aquatic, wetland, and terrestrial ecosystems associated with its source properties to ensure that natural resources are being managed sustainably. Biological monitoring was initiated at the Erin property in 2008 and is conducted annually. The location of monitoring stations are illustrated on Figure 19. The findings and recommendations for each monitoring year are published in annual monitoring reports provided to Nestlé.

4.1.2.1 *Aquatic Resources Monitoring*

Electrofishing to assess the fish community was conducted in 2011 and 2014. A trout spawning survey was conducted from Fifth Line upstream to the source of the branch which originates on the Nestlé property in 2011 and 2014. Water temperature in the tributary has also been monitored since 2014.

4.1.2.2 *Terrestrial Resources Monitoring*

Monitoring of terrestrial resources was initiated on the Erin property in 2008 and is focused on documenting the site's vegetation and wildlife resources. Core terrestrial resources parameters monitored include vegetation,

amphibians, birds and reptiles. Supplemental to these key components has been characterization of the ecological communities using the provincial Ecological Land Classification System (ELC), mapping for invasive alien species such as Common Reed (*Phragmites australis*), monitoring endangered or threatened species including Butternut (*Juglans cinerea*) and Bobolink (*Dolichonyx oryzivorus*), as well as occasional specialized surveys for odonates (damselflies and dragonflies).

4.2 Water Quality Monitoring

Groundwater quality from well TW1-88 has been monitored by Nestlé since the well has been used as a spring water bottling source, to ensure water quality standards established by Nestlé, the Canadian Food Inspection Agency (CFIA) and the Canadian Bottled Water Association (CBWA) continue to be met. Furthermore, Nestlé is vigilant with respect to the aesthetic character of groundwater, and is very much aligned with the Province's requirements to preserve water quality in the vicinity of the water source (i.e., source water protection). Nestlé monitors its water supply for changes and/or long-term trends in the water quality.

4.3 Tier 3 Modelling

An assessment of the potential cumulative impacts that could be caused by the bottled water takings at the Nestlé facility at Erin is required under the Interim Procedural and Technical Guidance Document for Bottled Water Renewals: Permit to Take Water Applications and Hydrogeological Study Requirements (Ontario Ministry of the Environment and Climate Change Operations Division, April 2017). The following requirements are extracted from the Interim Procedural and Technical Guidance Document:

All applications for water bottling shall consider the potential for cumulative effects, under both current conditions and various climate change or drought scenarios. Unless instructed otherwise or agreed to by the Director, the cumulative effects assessment shall use information obtained through watershed water budget evaluations completed under the Clean Water Act, 2006, where available. The highest tier of water budget completed for the location should be used to evaluate the potential for cumulative effects.

TW1-88 is located within the model area of the City of Guelph and Township of Guelph/Eramosa (GGET) Tier Three Water Budget and Local Area Risk Assessment study area (Matrix Solutions, 2017; Figure 1-1). Following the recommendations of the Interim Procedural and Technical Guidance Document, the groundwater model developed for the GGET Tier Three Assessment has been applied for the analyses to support the PTTW application for TW1-88. The GGET Tier Three model builds on the integrated water budget analysis for the Grand River watershed (AquaResource Inc., 2009). The Tier Three groundwater model is documented in detail in Appendix B of the final Local Area Risk Assessment report (Matrix Solutions, 2014). The GGET Tier Three model has been peer reviewed and has been approved by the Lake Erie Source Protection Region.

The approach to applying the GGET Tier Three groundwater model was discussed during a meeting held on July 10, 2017 between Nestlé, the MECP, GRCA and the City of Guelph. It was agreed that it is appropriate to use the existing GGET Tier Three model to support the impact assessment requirements for the Nestlé PTTW application. During the July 10, 2017 meeting, it was also agreed that the most effective approach for the modeling would be for the developers of the GGET Tier Three model, Matrix Solutions, to be subcontracted to conduct the modeling. This would eliminate the need to address any concerns regarding model ownership and distribution. More importantly, this approach would ensure that any refinements in the representation of conditions around the

Nestlé facilities would be retained in any future analyses. The City of Guelph is the custodian of the GGET Tier Three model. Nestlé contracted with the City, and the City subcontracted Matrix Solutions for the analyses.

The GGET Tier Three groundwater model was designed to encompass the entire hydrogeological system that influences the City of Guelph's municipal water supply wells. The model covers the entire Speed River and Eramosa River watersheds. The model was designed to simulate detailed local groundwater flow conditions around the city's municipal wellfields, and regional-scale conditions outside the city. The model has been refined in the vicinity of TW1-88. The application of the GGET Tier Three model for the Nestlé assessment is documented in a stand-alone report prepared for this study (Matrix Solutions, 2019) and included in Appendix K. The discussion of the modeling methodology here is limited to a summary of the refinements made to the GGET Tier Three model for this study.

To support the refinement of the GGET Tier Three model in the area potentially affected by pumping from TW1-88, Nestlé provided Matrix Solutions with the following data and interpretations.

- Nestlé Annual Monitoring Reports;
- Nestlé pumping test reports (TW1-88);
- Maps of surface water features;
- Hydrographs for Nestlé monitoring wells from the Erin Annual Monitoring Report;
- Groundwater level targets for pumping and non-pumping conditions and interpreted drawdowns (Overburden, Bedrock);
- Interpreted map of drawdowns in the Bedrock Aquifer (Guelph), June 2001; and
- Baseflow targets for SW1 and SW3.

Blackport Hydrogeology worked with Matrix Solutions to revise the structure of the Tier Three model around TW1-88. The GGET Tier Three model was recalibrated to improve the match to the high-quality local data in the area around TW1-88. During the re-calibration, Matrix Solutions improved the match to groundwater levels, drawdowns, and interpreted drawdowns contours with a single groundwater model.

4.4 Drought and Cumulative Effects Water Quantity Risk Assessment

Water is vital to health and integrity of ecosystems. Drought, climate change and water needs associated with increases in population have raised concerns related to water security in Ontario, particularly communities that depend on groundwater. For this reason, the potential effects of drought and climate change are considered as part of this assessment. The potential for cumulative effects, under both current and drought conditions and various climate change scenarios has been investigated with the refined GGET Tier Three model.

Cumulative effects are defined here as the potential combined effects of changes in pumping from the Nestlé production well TW1-88, changes in conditions that may arise during sustained periods of below-average precipitation (drought) and the potential effects of long-term changes in the climate of southern Ontario. Cumulative impacts are quantified in terms of potential changes in groundwater levels and groundwater discharge to surface water features with respect to pre-defined baseline conditions.

Pumping from the Hillsburgh municipal wells and TW1-88 has been ongoing for a relatively long time. Nestlé began pumping from the TW1-88 in 2000. The groundwater systems have attained natural equilibria in response to that pumping. No long-term declining trends in either groundwater levels or surface water flows are evident in the continuous records presented in the annual monitoring report for the Erin facility. As shown in Figure 4.1 of the 2017 Annual Report for Erin, the annual takings for 2015 through 2017 have been similar. To establish baseline conditions, TW1-88 is assigned a constant pumping rate corresponding to the average annual takings over this period.

With respect to the potential impacts of an increase in TW1-88 pumping, analyses were conducted with the pumping rate increased from its current average to the maximum rate in the current PTTW.

A long-term hydrologic analysis was conducted for the GGET Tier Three study to assess the variability of precipitation. The results of the analysis indicated that the longest sustained period on record of below-average precipitation occurred in the early to mid-1960s. This is well before Nestlé began pumping from TW1-88. The analysis of cumulative effects during drought is based on the hypothetical condition that current or increased Nestlé pumping continues during a reoccurrence of the period of sustained below average precipitation that was observed in the early to mid-1960s. This is in effect a worst-case scenario.

The approach developed for the Guelph Guelph/Eramosa Water Quantity Policy Study to analyze the potential effects of long-term climate change has been adopted for the present study (Matrix Solutions, 2018b). Following the climate change methodology developed in the Guide for the Assessment of Hydrologic Effects of Climate Change in Ontario (EBNFLO and AquaResource 2010), existing information has been leveraged to achieve the overall outcome of constructing and analyzing an ensemble of future climate projections for temperature and precipitation variables. The effects of changes in Nestlé pumping are added to any changes predicted with the climate change modeling.

5.0 MONITORING PROGRAM RESULTS

5.1 Water Taking

The water takings from TW1-88 are summarized in Section 2.1. Over the last 10 years (2009 through 2018) the annual water takings have ranged from a minimum of 66.1 million litres in 2017 to a maximum of 223.7 million litres in 2013 (Figure 3). Over that time period, the annual taking increased from 2009 to 2013, then decreased to 2015 and has been relatively constant over the past 4 years. Groundwater withdrawals from TW1-88 have averaged 362,642 L/day over the last 10 years (2009 – 2018). The water takings over the past four years have been lower than the 10-year average (Table 2).

5.2 Groundwater Levels

Hydrographs with the manual or transducer water level data for the monitoring wells are included in Appendix D. To support the inference of long-term trends in the groundwater levels and relationship, if any, to variations in pumping and precipitation, hydrographs of average monthly water levels, monthly volume pumped from TW1-88 and monthly precipitation over the past eleven years (2008 through 2018) have been prepared and are included in Appendix E. The average monthly water level data were calculated from the near-continuous record of water levels recorded with pressure transducer dataloggers.

5.2.1 TW1-88

The pumping rate and water level in TW1-88 are monitored continuously. Water levels and average daily pumping rates for TW1-88, along with daily precipitation, over the past 11 years (2008 through 2018) are shown on Figure D1 in Appendix D. Water levels since 2008 at TW1-88 range from approximately 414 to 424 masl under pumping and non-pumping conditions.

The estimated non-pumping water levels (partially recovered conditions following temporary shutdown of the pump) observed since 2008 range from 422 to 424 masl (Figure D1). It should be noted that non-pumping water levels do not represent “true” conditions that would be observed if there were no pumping at TW1-88. Instead, they represent partially recovered conditions, with the amount of recovery depending on the average pumping rate before the pumping stopped, how much time has elapsed before pumping resumes and whether there is a background (seasonal) trend in the water levels. CRA (2014) indicated that, based on historical data, static water levels ranged from 423.5 masl to 424.5 masl. Overall, the water levels have been similar over the past 11-year period. The upper bound on the water level in TW1-88 inferred from Figure D1, 423.5 masl, is within the range of the historic static water levels, which suggests that water levels recover almost completely following temporary stoppages of pumping. This is one line of evidence that the pumping of TW1-88 has been sustainable.

Since 2008 TW1-88 water levels have ranged from approximately 414 masl to 419 masl under pumping conditions (Figure D1). Based on a static water level of 424 masl, the equivalent drawdown has ranged from 5 to 10 m. Overall, the water levels respond to pumping as expected. Changes in total drawdown are related to changes in operation of the well. Since the water taking at TW1-88 decreased in mid-2014, the water levels at TW1-88 have increased an average of approximately 0.5 m. Since pumping has decreased, the seasonal fluctuations in water levels are more evident.

The data collected during controlled pumping tests provide insights into the performance of TW1-88. Step and constant-rate pumping tests have been conducted on TW1-88 in 1988 and 2005 (CRA, 1989; 2006). The results of the testing are summarized graphically on Figure C1, in which the pumping rates are plotted against the

inferred drawdowns in the well. As shown on Figure C1, the data from the two constant-rate pumping tests, which represent stabilized conditions, are consistent with the results of the initial step test on TW1-88. A slightly higher well capacity is inferred from the 2005 step test.

The 2005 test was conducted at a rate of 1,227 L/min, which is more than double the rate of the 1988 test, 546 L/min. Despite the difference in the pumping rates, the data from the 1988 step test and the two constant rate tests closely approximate a straight line, suggesting that non-linear well losses are negligible. More significantly with respect to the sustainability of pumping, the linear response indicates that TW1-88 is effectively confined, with the water level in the well remaining at all times above the top of the bedrock aquifer (the top of the bedrock aquifer at TW1-88 is at an elevation of about 410.5 masl).

The slope of the straight line shown on Figure C1 is designated the specific capacity of TW1-88, that is, the yield of the well per metre of drawdown in the pumping well:

$$\text{Specific capacity} = Q/s_w = 1.53 \text{ (L/s)/m}$$

Here Q denotes the pumping rate and s_w is the drawdown in TW1-88.

The actual performance of TW1-88 can best be interpreted by considering the well data collected during operations. The continuous records from 2008 through 2019 (Figure D1) show that the cumulative volume pumped from 2015 through 2018 was significantly reduced with respect to previous years in the decade. Although the pumping has declined in recent years, the water levels in TW1-88 have fluctuated within a consistent band between 416.5 masl and 423 masl. This suggests that TW1-88 has been pumped at a relatively constant rate, but for fewer hours each day.

The average monthly water level hydrograph is shown on Figure E1 and extends back to 2008. The data provide important insights into the performance of the well and the long-term sustainability of pumping. The trends in the data are clearer when presented in terms of the monthly average data, as shown on Figure E1 with the performance data presented as the monthly average water level versus the cumulative volume of water pumped each month. The decline in the pumpage from mid-2014 onward is evident as is the similarity in the water takings over the past four years (2015 through 2018). The water levels in the pumping well have fluctuated between similar bounds over the same period. Prior to that, the average water levels (pumping and non-pumping) were lower. The higher water levels in recent years are due to a decrease in the pumping (i.e., the decline in mid-2014 caused the monthly average water level in TW1-88 to rise from about 419.5 masl to a steady level of 422.0 masl, with the water level in the well being stable since the end of 2014). The slight increase in the water taking in 2018 corresponds with a slight decrease in the average water level during the same time period. In general, the water level trend at TW1-88 corresponds to the overall water taking from the well, as suggested on Figure E1. Overall, the water levels appear to be relatively stable under both pumping and non-pumping conditions and the groundwater taking at TW1-88 has not caused a long-term declining trend of the water level in the production well.

Selected points from the monthly average record are plotted on Figure C6. The equivalent constant pumping rate, reported as litres per second, is calculated by dividing the cumulative volume pumped in each month by the number of seconds in a month. The TW1-88 performance data approximate a straight line of the following form:

$$WL = WL_0 - \text{SLOPE} \times Q$$

Here WL represents the monthly average water level in TW1-88, WL_0 the non-pumping water level in the well (fully recovered conditions), Q is the monthly average pumping rate and SLOPE is the reciprocal of the specific capacity of TW1-88.

On Figure C6 a line corresponding to the specific capacity inferred from the 1988 and 2005 testing is superimposed on the average monthly TW1-88 performance data. The selected points from the monthly average data are consistent with the specific capacity inferred from controlled tests. The close agreement shown on Figure C6 provides another line of evidence that the pumping is sustainable. The data are sufficient to confirm the general impression that the changes in the water levels in TW1-88 are due to changes in the pumping rate.

The consistent and predictable response from year to year confirms that the pumping from TW1-88 has been sustainable, that is, the pumping has not caused a long-term declining trend in the water level in the well.

5.2.2 Bedrock Aquifer

An example of the potentiometric surface of the bedrock aquifer was shown on Figure 20 based on the water levels measured on August 24, 2018. A review of the potentiometric surface on August 24, 2018, indicates groundwater flow is to the south with influence from pumping around TW1-88.

Hydrographs for wells completed in the bedrock aquifer are included on Figures D2 through D12 in Appendix D and Figures E2 and E3 in Appendix E. A review of the hydrographs indicates the following:

- Water levels in the bedrock aquifer appear stable over the monitoring period;
- For the purpose of this study, water levels in MW12A-08 and D15 are interpreted to represent background conditions. Water levels are measured on a monthly basis in these wells and the measurements show only small water level fluctuations over the past eleven years (i.e., less than 1 m);
- In most years the water levels generally increase in the spring and then decrease through the summer and are relatively constant for the remainder of the year (see Figure D2);
- The amount of influence that pumping TW1-88 has on water levels in other wells declines with distance from TW1-88 (e.g., more pronounced in MW5A-05 compared to MW12A-08);
- The drawdown cone from pumping TW1-88 is localized, especially with the reduced intermittent pumping that is currently occurring;
- In 2016, there was a decline in water levels evident in some of the wells. The decline was likely associated with below-average precipitation recorded during the summer of 2016. Water levels in the south-east part of the Site continue to fluctuate seasonally but remain slightly lower than those observed prior to 2016, which is due to the below normal precipitation recorded during the summer and fall of the past three years (2016 – 2018);
- With only a small amount of fluctuation occurring in the bedrock water levels, the long-term precipitation trends are not evident; and
- Water levels in the private wells may be influenced by pumping at TW1-88; however, fluctuations are mainly due to pumping at the private wells.

5.2.3 Overburden (Water Table) Aquifer

Hydrographs for wells completed in the overburden are included on Figures D13 through D15 in Appendix D and Figures E4 and E5 in Appendix E. A review of the hydrographs indicates the following:

- Water levels in overburden show similar trends, with increasing water levels through the spring followed by decreasing water levels through the summer and relatively stable water levels in the fall. The exception to this trend is at well D7B, which has had a relatively consistent water level over the years with little to no fluctuation;
- The timing of the high and low water levels can vary by a month or two from well to well. This may be due to the time for recharge to the aquifer to occur, which is expected to vary across the property based on the variations in surficial geology (i.e., sand and gravel versus glacial till) and topography.
- Water levels also fluctuate more in the southern part of the study areas (Figure E5) compared to the northern part of the study area (Figure E4). This is in response to how quickly water moves through the different aquifers following recharge and reflects their positions in the groundwater flow system, where greater variations in water levels occur at the higher topographic elevations (i.e., recharge areas) compared to the low-lying areas (i.e., discharge areas);
- A response to precipitation or melt events (i.e., increase in water levels) is evident in the wells for which levels are recorded continuously; and
- Overall, the similarity in water level trends, regardless of distance from TW1-88, indicates that water level fluctuations are not due to pumping TW1-88 but due to natural seasonal changes and recharge.

5.2.4 Vertical Gradients

Vertical gradients between the overburden and bedrock at monitoring well nests (MW5-05, MW6-05, MW11-08 and MW12-08) are plotted on Figures F1 through F4 in Appendix F. Note that a positive gradient is calculated when the water level in the upper aquifer exceeds the level in the lower aquifer. Under these conditions, the potential groundwater flow is downwards.

A review of the gradient data indicates the following:

- A positive vertical gradient between the overburden and bedrock (potential downward flow) is present at all of the monitoring well nests;
- The vertical gradients fluctuate due to changes in the bedrock water levels that respond to pumping TW1-88 (i.e., a decrease in the bedrock water level) or changes in the overburden water levels that respond to recharge events (i.e., an increase in the overburden water level), but the overall trends remains stable;
- The gradients at MW5-05 and MW6-05 vary in response to pumping TW1-88 and are due to the water level fluctuations in the bedrock aquifer at these sites;
- The gradient at MW11-08 is relatively constant on an annual interval (i.e., no short-term influence from pumping) but shows a slight increase in the positive gradient when pumping is greatest from 2012 to 2014 and a slight decrease in the positive gradient from 2013 through 2017. The gradient at MW11-08 was more variable in 2018, with no influence from pumping but due to higher water levels observed in the overburden in February and lower water levels observed in the bedrock in the late summer and early fall;

- The gradient at MW12-08 increases in the spring and then decreases through the summer, with no influence from pumping. The increase in gradient in the spring is due to a rise in the water levels in the overburden during the spring melt;
- There does not appear to be a measurable hydraulic response in the overburden water levels from pumping the bedrock aquifer at the historical rates of water taking; and
- Vertical gradients at the two wells closest to TW1-88 ranged from approximately 0.4 m/m to 0.8 m/m at MW5-05 and approximately 0.4 m/m to 0.5 m/m at MW6-05. On average, the vertical gradients at the other two wells that are monitored monthly are about 0.1 m/m at MW11-08 and 0.3 m/m at MW12-08. The gradient at MW12-08 increases in the spring and then decreases through the summer (no influence of pumping). The increase in the gradient in the spring is due to the rise in water levels in the overburden during the spring melt.

5.3 Surface Water Levels

5.3.1 Mini-Piezometer Water Levels and Vertical Gradients

Hydrographs for the mini-piezometer locations extending over the last 11 years (2008 through 2018) are presented on Figures G1 through G7 in Appendix G. The graphs also include the average daily pumpage at TW1-88, precipitation as recorded at the Orangeville and Shand Dam stations and vertical hydraulic gradients. A negative gradient indicates that groundwater may be discharging to the surface water body, while a positive gradient indicates the surface water body is recharging the groundwater.

A review of the hydrographs for the mini-piezometers indicates the following:

- Water levels fluctuate seasonally, with higher water levels observed in the spring and lower water levels observed in the late summer;
- The water levels also show a response to precipitation and melt events;
- Overall the water levels are stable;
- There is no effect of pumping TW1-88 on vertical gradients in the shallow overburden near surface water features;
- The vertical gradients are similar over the years;
- Any slight reversals in gradients observed recently are not related to pumping at TW1-88 since total pumping over the past four and a half years is lower than previous years and a change in gradient was not observed during this change in pumping (i.e., vertical hydraulic gradients were not influenced by the lower daily pumping);
- P11-05 shows a change in gradient around the same time that pumping decreases at TW1-88; however, the change is a reduction in the negative gradient which is the opposite of what would be expected with the reduced pumping at TW1-88; and
- The negative gradient at P12-07 has decreased since mid-2017 due to the rise in water levels caused by the creation of a beaver dam.

Water level fluctuations and vertical gradients in the mini-piezometers are described below:

- P3A/B-05 (east side of on-Site pond) – water level fluctuations are similar in the shallow and deep piezometers with an overall fluctuation of less than 0.3 m. A weak negative gradient is evident, with the gradient occasionally reversed in the past. The gradient reversal generally occurs in the summer when water levels are lowest. Some changes in water levels were due to accumulation and subsequent removal of debris from the outlet of the pond;
- P6A/B-07 (west side of on-Site pond) – water level fluctuations are similar in the shallow and deep piezometers with an overall fluctuation of less than 0.3 m. A weak positive gradient exists that has occasionally reversed in the past. The gradient reversal generally occurs in the spring when water levels are highest. Some changes in water levels were due to accumulation and subsequent removal of debris from the outlet of the pond;
- P1A/B-07 (stream channel downstream of on-Site pond) – water levels have fluctuated just over 0.2 m with the exception of some short-term increases related to precipitation events. The water levels in the stream show less fluctuation than the water levels in the pond. A weak negative gradient exists that has occasionally reversed in the past;
- P11A/B-05 (further downstream from P1-07 at 6th Line) – water levels fluctuate just over 0.1 m. A weak negative gradient has been observed with the occasional positive gradient. The negative gradient decreases around the same time that pumping at TW1-88 decreases. The change is not related to the pumping, as a decrease in pumping would cause the negative gradient to increase if there was a connection between the bedrock aquifer and the shallow ground water system;
- P10A/B-05 (upgradient side of the wetland pond) – water levels have fluctuated by almost 0.8 m over the years and show a distinct seasonal pattern. The decline in water levels typically occurs in the summer and then water levels increase again in the fall. A negative gradient is typically observed with some small reversals;
- P12A/B-07 (stream flowing into Roman Lake) – water levels typically fluctuate 0.2 to 0.3 m and increased to approximately 0.4 m in the shallow piezometer in mid-2017 due to the construction of a beaver dam. There are also some short-term increases in response to spring melt and some precipitation events. A strong negative gradient was observed that decreased to a weak negative gradient after the construction of the beaver dam; and
- P13A/B-07 (Erin Branch of Credit River) – water levels have fluctuated 0.6 m in the shallow and deep piezometers. The vertical gradient is positive most of the time with greater fluctuation than at the other sites. Water levels may be influenced by fluctuations in water levels in the Hillsburgh reservoir.

Water levels observed in the mini-piezometers suggest relatively small fluctuations that are not caused by pumping TW1-88 and weak gradients across the stream beds.

5.3.2 Surface Water Levels

Hydrographs for the surface water level monitoring locations are included on Figures H1 through H4 in Appendix H. A review of the hydrographs for the surface water level monitoring locations indicates the following:

- Pumping at TW1-88 does not influence the water levels in the surface water features;
- Water levels in the surface water features respond to precipitation and melt events;

- The long-term fluctuation is generally less than 0.2 m with some seasonal variation evident;
- The long-term water levels are stable;
- Some of the changes in the water levels at SW3 (on-Site pond) are due to the outlet being partially obstructed with debris and then cleared when the debris is removed; and
- Water level changes at SW7 (Erin Branch of Credit River) in the past may be due to upstream work or changes in the Hillsburgh reservoir level. Due to the changing stream conditions at SW7, a new station (SW7A-16) was installed in May 2016. Water levels in the creek at SW7A-16 have shown minimal fluctuation with no increasing or decreasing trend.

5.4 Surface Water Flow

Surface water flow is measured at three stations in accordance with the PTTW; SW1 (creek downgradient of the on-Site pond and wetland), SW3 (outlet from the on-Site pond) and SW7 (Erin Branch of Credit River). Surface water flows are also measured at SW7A (Erin Branch of Credit River), which is not a requirement of the PTTW. The surface water flows for the four stations are shown on Figures I1 to I3 in Appendix I.

Flow from the on-Site pond (SW3) is measured with a flow meter while flows at SW1 and SW7 are estimated with stage-discharge curves. The stage-discharge curves for both SW1 and SW7 have been re-evaluated and adjusted in recent years in an attempt to more accurately reflect the monitoring data and stream characteristics. The stage-discharge curves are generally adjusted to account for changing stream conditions and hydraulic controls.

Monitoring data at SW7A-16 have been collected since May 2016 and have been used to generate stage-discharge relationships for this station. Water levels at this station remain constant at most stream discharge levels and therefore development of the stage-discharge curve has been challenging and may require further investigation of the stream geometry in the future.

A summary of flow at the stations is as follows:

- Surface water flows at SW1 (combined flow from on-Site pond and wetland) show seasonal variations with higher flows in the spring (Figure I1). Stream flows during the spring melts are approximately 20 L/s to 100 L/s and are generally less than 20 L/s during the remainder of the year. There is no evidence of a decline in stream flow at SW1. Lower flows were recorded during the summers of 2015 and 2018. It should be noted that some of the logger recordings during the winter months are suspected to be influenced by ice conditions and should be assigned lower reliabilities.
- Flow from the on-Site pond (SW3) also shows seasonal variations with higher flow observed in the spring. The spring flows are typically between 10 L/s to 30 L/s, while the summer low flows are generally less than 10 L/s. There are some spikes in flows related to precipitation events and spring melt.
- Stream flow at SW7 is typically less than at the other stations, with flow less than 10 L/s most of the time. In the past, it has been speculated that increases in flow may be related to changes in the Hillsburgh reservoir or potential work upstream. The flow at SW7 has been similar over the years, with changes related to changing stream conditions. Due to the multiple stream channels in the reach, there have been times when stream station SW7 was dry while other parts of the channel remained flowing.

- Stream flow at the new station (SW7A) has been consistent in 2016 and 2017 around 40 L/s. In 2018, flow was around 30 L/s to 40 L/s during the first half of the year and then increased during the second half of the year with flows up to 60 L/s. The flow at SW7A is approximately 30 L/s to 50 L/s greater than the flow at SW7. This is due to the fact that SW7A is located in a defined channel as opposed to multiple channels at SW7, where only part of the total flow is measured.
- Surface water flow at all the stations is influenced by precipitation and/or melt events and does not appear to be influenced by pumping at TW1-88.

5.5 Water Quality

The following section discusses groundwater quality monitoring conducted at Erin. The relative distribution of anions and cations at TW1-88 is presented on a tri-linear Piper plot (Figure J1 in Appendix J) and time series graph (Figure J2 in Appendix J).

Water quality at TW1-88 has been relatively stable over the years and parameters tested have remained below the Ontario Drinking Water Aesthetic Objectives. Groundwater is characterized as a calcium-magnesium-bicarbonate type, consistent with a carbonate aquifer.

Nestlé also monitors TW1-88 annually for volatile organic compounds (VOCs) that are some of the most common environmental contaminants, and the most readily transported through groundwater. To date, no VOCs have been detected in the groundwater at TW1-88.

5.6 Biological Monitoring

A summary of the Biological Monitoring findings are summarized below. For results of annual monitoring, refer to the annual biological monitoring reports.

5.6.1 Aquatic Resources

Electrofishing has shown that the fish community in the Eramosa River tributary within the Nestlé property includes Creek Chub (*Semotilus atromaculatus*), Brook Stickleback (*Culaea inconstans*), Central Mudminnow (*Umbra limi*), Blacknose Dace (*Rhinichthys atratulus*), Northern Redbelly Dace (*Phoxinus eos*), Pumpkinseed (*Lepomis gibbosus*) and Blacknose Shiner (*Notropis heterolepis*).

No evidence of trout spawning was observed during the spawning surveys conducted through the Nestlé property in 2011 and in 2014. A Brook Trout (*Salvelinus fontinalis*) was observed exhibiting spawning behaviour downstream, at Fourth Line, in 2015 and 2016, confirming that Brook Trout are present and do spawn in this creek. The temperature of the creek is suitable for trout much of the time during the summer and the stream temperature rarely, if ever, reaches levels that are lethal for trout. The warm surface water leaving the on-Site pond increases the creek temperature during the summer.

5.6.2 Terrestrial Resources

Monitoring has revealed that the forests and wetlands on the Erin property support a high level of species diversity and many species that are indicators of high-quality habitats and some species that are recognized as provincially and regionally significant.

Monitoring of vegetation since 2008 has identified some minor changes in species composition in the sampled wetland communities. The observed changes are attributable to natural variation, succession, beaver activity,

and colonization of some plots by non-native Common Reed. All of the observed changes are considered to be within the expected range of natural variation for the types of ecosystems present.

6.0 IMPACT ASSESSMENT

The Technical Guidance Document notes that a water taking may result in some degree of impact to an established water use or to the natural function of the ecosystem. When the impact affects an established water use, this is also referred to as interference. An unacceptable impact is normally considered to occur when 1) an impact hinders the ability of the water resource to support existing natural functions of the ecosystem, and/or 2) an impact prevents an established water user from continuing their established pattern of use.

Water taking shall not cause unacceptable impacts to the following:

- Natural function of the ecosystem – this includes any function of the aquifer to provide baseflow to streams, maintain water levels in wetlands or lakes, support habitat and species or provide recharge to other aquifers;
- Established pattern of water use – this includes water taking for which a PTTW is required and any uses for which a PTTW is not required; and
- Irreversible impacts – this includes impacts such as those that might occur if an aquifer is over-pumped or a taking that results in the deterioration of groundwater quantity or quality on a neighbouring property.

6.1 Impact to Groundwater Users

The Long-Term Monitoring (LTM) program indicates that variations in pumping from TW1-88 cause water levels to fluctuate within the pumped bedrock aquifer around TW1-88. The effects from pumping diminish with distance from the pumping well and no long-term declining trends have been observed.

6.1.1 Municipal Groundwater Users

The closest municipal wells to TW1-88 are the Hillsburgh wells (Town of Erin wells H2 and H3). The Hillsburgh wells are located approximately 1.5 km north-northeast of TW1-88 (Figure 2). Data from the monitoring wells between TW1-88 and H2 and H3 and from almost 20 years of monitoring at H2 and H3 have shown that the taking from TW1-88 does not impact the municipal water supply under historical pumping conditions.

Maps of the potential additional drawdown caused by an increase in TW1-88 pumping from the current average of 207 m³/d to the maximum permitted rate of 1,113 m³/d are presented in Matrix Solutions (2019; Figures 27 and 28). The additional simulated drawdown is predicted to be 0.3 m at the wells H2 and H3. During the GGET and Region of Waterloo Tier Three water quantity risk assessments, a contour interval of 2 m was specified to delineate the drawdown cones of municipal wells (WHPA-Q1) (Matrix Solutions and S.S. Papadopoulos & Associates, 2014). The contour interval of 2 m was selected as a threshold to account for the natural seasonal variability typically observed at monitoring wells located beyond the effects of municipal pumping. The 2 m threshold represents a “detection limit” for the effects of additional declines in groundwater levels caused by increased pumping. The predicted additional drawdown of 0.3 m at the Hillsburgh wells is well below the 2 m threshold, suggesting that it is unlikely that the effects of an increase in Nestlé pumping could be detected.

Plots of simulated water levels in wells H2 and H3 over a 45-year duration climate record are presented in Matrix Solutions (2019; Figures 30 and 31). The additional water level decline in H2 and H3 associated with increased Nestlé pumping is predicted to range between 0.3 m and 0.4 m over the 45-year duration of the simulation. To put these results in perspective, the water levels in the Hillsburgh wells are predicted to vary by more than 4 m in response to normal climate variability over the same period. With the wells pumping at their current average rates the available additional drawdowns in wells H2 and H3 are 48 m and 52 m, respectively. The results of the

analysis suggest that an increase in pumping TW1-88 up to its maximum permitted rate is unlikely to limit the yields of the wells.

6.1.2 Private Groundwater Users

Nestlé monitors water levels in 10 private wells in the area to track long-term changes or trends in the water level. The monitoring has never shown impacts to private well use. Nestlé has not received any interference complaints from its neighbours that have wells completed in the overburden or bedrock aquifers.

6.2 Impact to Surface Water and Natural Functions of the Ecosystem

There does not appear to be an ecologically meaningful hydraulic connection between the surface water features and the pumped aquifer that could result in ecological impacts. Flow in the unnamed creek west of the property is not hydraulically connected to the bedrock aquifer. Similarly, the wetlands on the property are not sustained by the bedrock aquifer. There is no evidence to suggest that the water taking impacts the watercourses or wetlands.

TW1-88 is identified to be within the IPZ-Q for the City of Guelph Eramosa Intake; however, since the influence of pumping does not extend to the surface water system, no impact to the Guelph Eramosa Intake is anticipated.

The analysis of potential cumulative impacts to surface water features has been assessed in terms of the predicted changes in simulated groundwater discharge to Nestlé surface water monitoring station SW1. Referring to Matrix Solutions (2019; Table 12), an increase in pumping to the maximum permitted rate is predicted to cause a reduction of 3% of accumulated groundwater discharge at SW1. This is substantially less than the threshold of 10% of the results for baseline conditions indicated in the Interim Procedural and Technical Guidance Document.

The predicted changes in accumulated groundwater discharge at the SW1 gauge for the drought scenarios are presented in Matrix Solutions (2019; Figures 32 and 33 and Table 13). As shown in Figure 32, the differences in simulated groundwater discharge between average Nestlé pumping and permitted Nestlé pumping are relatively small. For accumulated groundwater discharges that are equal or exceeded 20%, 50% and 80% of the time, the reductions in groundwater discharge are predicted to be 3%, 3% and 4%, respectively. These predicted reductions in the accumulated groundwater discharge are less than the threshold of 10% indicated in the Interim Procedural and Technical Guidance Document. The results suggest that the predicted reductions in groundwater discharge are within the typical error associated with streamflow measurements and that it is unlikely the effects of an increase in pumping could be detected.

Additionally, the MECP indicates that the withdrawal and use cannot result in potential ecological impacts to surface water systems resulting from losses of groundwater input. The surface water system is isolated from the bedrock groundwater system and there are no impacts.

6.3 Water Quality Potential Impacts

As discussed in previous sections, well TW1-88 withdraws water from an aquifer in the Guelph Formation, which is composed of dolostone bedrock. Well TW1-88 is cased from the ground surface to 21.8 m below grade, preventing any water in the overlying glacial overburden from locally entering the borehole. Water recharges regionally through the glacial overburden and into the Guelph aquifer on the Orangeville Moraine, generally north and northwest of the Erin property.

Nestlé also constructs its monitoring wells so that the well screens are completed in individual aquifers with the remaining portions of the holes sealed so that water can't move up or down through the borehole. This prevents the movement of water between aquifers.

According to Appendix 2 of the Technical Guidance Document, the bottled water taking shall not result in water quality impacts that unacceptably interfere with existing or future municipal groundwater uses, or with natural functions of the ecosystem. Specific examples of unacceptable water quality impacts cited in the Technical Guidance Document include (1) mixing of groundwater of different (poor) quality that can potentially change the overall water quality, and therefore impact the taste or appearance of the water; and (2) induced migration of contaminated groundwater across nearby properties, such as dissolved-phase organic contaminants related to petroleum releases, or industrial processes.

According to land use mapping, there are no known or potential contaminant sources within 1 km of TW1-88 (the approximate area of influence). Nestlé monitors TW1-88 water quality for volatile organic compounds (VOCs), which are among the most common and mobile of anthropogenic contaminants. No VOCs have been detected at well TW1-88 at any time during its operation as a Nestlé bottled water source. The water quality results presented in Section 5.5 indicate that water quality has been consistent over the years. The water quality at TW1-88 does not show any impacts from mixing of water or capturing contaminated water from surface.

Additionally, the MECP indicates that the withdrawal and use cannot result in physical impacts to surface waters associated with discharge water (i.e., turbidity resulting from erosion or sedimentation). There is no water discharge in Erin.

In order to reduce or eliminate water quality impacts, Nestlé controls the actions that take place on its property (i.e., no pesticide or herbicide use and reduced road salt use). Water quality from this spring water source is regulated by CFIA and CBWA.

6.4 Drought and Cumulative Effects Water Quantity Risk Assessment

Environment Canada monitors drought conditions across Canada. In the 16 ½ year record (198 months, November 2002 – April 2019), available on-line, there has never been an “Exceptional Drought (D4)” condition anywhere in Southern Ontario. Additionally, in only 5 of 198 months (2.5%) has an “Extreme Drought (D3)” been reported anywhere in Southern Ontario. Of those five months experiencing “Extreme Drought”, two included the area around Erin (September and October of 2007), while the other three included areas to the south of Erin (Figure 21). There have been other drought periods prior to 2002, such as the drought in the 1960's.

A review of stream flow and groundwater levels was conducted for 2012 and 2016 during two of the periods of low-water Level 2 declarations. Some of the lowest flows were observed at SW1 (Figure 14) and at the Eramosa River Above Guelph Station (Figure 15) during these periods. A review of the average water levels in the overburden (Appendix E) indicates that some of the lowest water levels were observed during these periods in recharge areas (elevated topography) but water levels in the discharge areas (lower topography) did not decline significantly. The average water levels in the bedrock aquifer fluctuated in response to pumping TW1-88 and not to the declines in precipitation during the low-water declarations in 2012 and 2016. This indicates that the water levels in the bedrock aquifer fluctuate more in response to pumping at TW1-88 whereas water levels in the overburden aquifer are influenced by precipitation mainly in the recharge areas with higher topographic elevation.

There does not appear to be an ecologically meaningful hydraulic connection between the surface water features and the pumped bedrock aquifer that could result in ecological impacts. Surface water features are affected directly by long-term trends in precipitation but groundwater levels in the bedrock aquifer are not as affected by periods of below-average rainfall.

The results presented in Matrix Solutions (2019; Figures 30 and 31) provide indications of the likely responses of the Hillsburgh municipal wells H2 and H3 if the sustained period of below-average precipitation that was observed in the early to mid-1960s were to reoccur. As shown in the two figures, if the pumping from TW1-88 were to increase from the current average to the maximum permitted rate during drought conditions similar to those observed in the early to mid-1960s, water levels are predicted to decline by approximately 2.3 m. To put these results in perspective, the water levels in the Hillsburgh wells are predicted to vary by more than 4 m in response to normal climate variability over the same 45-year record. With H2 and H3 pumping at their current average rates the available additional drawdowns are 48 m and 52 m, respectively. The modeling predictions suggest that it is unlikely that the cumulative effects of increased pumping and drought conditions would limit the yields of the wells.

Plots of the predicted water levels at the Hillsburgh municipal wells under conditions of long-term climate change are presented in Matrix Solutions (2019; Figures 35 and 36). As shown in the figures, the future climate change simulations predict that for ongoing pumping of TW1-88 at its current average rate, groundwater levels in wells H2 and H3 will increase by between about 0.5 m and 2 m as compared to historical climate.

7.0 CONCLUSIONS

The following key facts provide evidence of the sustainability of pumping at TW1-88:

- Water levels in TW1-88 remain above the top of the pumped aquifer during operating conditions.
- Variations in water levels at TW1-88 correspond to pumping in the well and water levels recover to near-static conditions when pumping ceases. The response is consistent and predictable.
- There are no ongoing long-term declining trends in water levels measured in monitoring wells in the bedrock or overburden.
- There have not been any declines in water levels in neighbouring private wells that impaired the ability of the wells to produce water and there have been no well interference complaints.
- There is no apparent correlation between increases in pumping and decreases in stream flow resulting from declines in groundwater discharge to streams that are sufficient to affect the ecology of the stream.

The following conclusions are presented based on the findings of the study and the long-term monitoring:

- The water taking does not hinder the ability of the water resource to support existing natural functions of the ecosystem. The withdrawal does not result in physical and ecological impacts to the wetlands in the Eramosa River headwaters.
- The water taking does not prevent water users from continuing their established pattern of use. The groundwater withdrawal from TW1-88 does not interfere with existing municipal uses or private uses. There have been no well interference complaints at Erin due to the water taking from TW1-88.
- No irreversible impacts have been observed due to over-pumping of the aquifer or deterioration of groundwater quantity or quality on neighbouring properties.

8.0 RECOMMENDED MONITORING PLAN

It is recommended that the existing monitoring program be kept in place with the following changes:

- 1) Surface Water Monitoring changes:
 - a. The current SW1 and SW7 stations should be relocated to areas with more favourable hydraulics (i.e., single channel, stable conditions and no backwater). The observed relationship between water level and stream flow at the existing SW1 and SW7 locations is variable or has deteriorated in recent years. Relocation of SW1 and SW7 will achieve a better relationship between water levels and flow (i.e., further development of a stage discharge curve). It is recommended that SW1 be relocated to the northeast side of 6th Line, upstream of the road crossing. A new station has been developed at SW7A in the stream channel by D7B that can be used for flow monitoring to replace SW7. To improve the quality of water level data collected at the on-Site pond, it is also recommended that an additional logger be installed upstream of the pond outlet. This station would improve pond outlet estimates through a stage-discharge relationship. There should be an overlap in the monitoring of the new and existing stations until the stage discharge curves are developed. We note that there has been an overlap in the data recorded at SW7 and SW7A and therefore SW7 should be removed from the monitoring conditions.
- 2) Mini-piezometer changes:
 - a. Monitoring at P06A/B should be discontinued. P06A/B and P03A/B are both located in the on-Site pond and provide similar data. In addition, P01A/B is located in the creek just outside the pond.
- 3) Overburden Private Well changes:
 - a. The monitoring at the private wells in the overburden should be discontinued. The monitoring program has been ongoing for more than 15 years and no impacts to private wells or the surrounding aquifer have been noted. In addition, the monitoring data from these private wells are often influenced by pumping at the private well itself. The following changes to the monitoring program should be implemented:
 - b. Discontinue monitoring at overburden wells D2B (homeowner does not want well monitored), D7B, D26C and D27, as there are no impacts to the overburden aquifer. On-site monitoring wells (MW3A/B-00, MW5B-05, MW6B-05, MW11B-08 and MW12B-08) would still be used for monitoring water levels in the overburden including four nested wells. Two new monitoring wells will also be installed by the D24 and D26 wells that will include an overburden monitoring point.
- 4) Overburden Monitoring Well Changes:
 - a. Discontinue monitoring at overburden wells MW2-00, TW1-99 and D36A. There are no impacts to the overburden aquifer and these wells provide similar data to other on-site monitoring wells constructed in the overburden aquifer. On-site monitoring wells (MW3A/B-00, MW5B-05, MW6B-05, MW11B-08 and MW12B-08) would still be used for monitoring water levels in the overburden including four nested wells. Two new monitoring wells will also be installed by the D24 and D26 wells that will include an overburden monitoring point.

5) Bedrock Private Well Changes:

- a. Monitoring at some of the private wells should be discontinued or replaced with dedicated monitoring wells. The monitoring program has been on-going for more than 15 years and no impacts to private wells or the surrounding aquifer have been noted. In addition, the monitoring data from these private wells are often influenced by pumping at the private well itself. The following changes to the monitoring program should be implemented:
- b. Discontinue monitoring at D19 as the homeowner does not want the well monitored. Private well D3 is located in the same direction from TW1-88 and is closer to the pumping well allowing for sufficient monitoring in that area.
- c. Discontinue monitoring at D8 and D15. A new monitoring well (MW1-18A/B) has been completed in the general area of D8 and D15 which can replace the monitoring at the private wells (see well log in Appendix B).
- d. Discontinue monitoring at D24A and D24B and install a new monitoring well in the same area. Note that this monitoring well will be completed with intervals in both the overburden and bedrock.
- e. Discontinue monitoring at D26A and D26B and install a new monitoring well in the same area. Note that this monitoring well will be completed with intervals in both the overburden and bedrock.
- f. Discontinue monitoring at D2A as the homeowner does not want their well monitored. The new monitoring wells to be installed by D24 and D26 would provide sufficient coverage for monitoring at D2A.

6) Bedrock Monitoring Well Changes:

- a. Discontinue monitoring at D32 and D36B as these wells provide similar data to other wells in the area and are outside of the 1 m drawdown area. On-site monitoring wells (MW6A-05 and MW12A-08) are in the same area as these wells and would still be used for monitoring water levels in the bedrock.

7) The PTTW should be updated with the following administrative changes:

- a. MW11B-08 is listed as monthly monitoring under bedrock wells and it should be listed as monthly monitoring under overburden wells.
- b. MW12B-08 is listed as monthly monitoring under bedrock wells and it should be listed as monthly monitoring under overburden wells.
- c. D27 is listed as both continuous and monthly monitoring under overburden wells and it should only be monthly monitoring (note that this well is recommended to be removed from the monitoring conditions).

9.0 CONTINGENCY PLAN

The following sub-sections provide contingency plans that provide mitigative measures to be taken in the event that unforeseen or unacceptable impacts occur as a result of the takings from TW1-88.

9.1 Low Flow Response Plan

Below-normal rainfall and hot conditions, which increase evapotranspiration, can result in relatively low stream flows and low groundwater levels in the overburden aquifer. The Grand River Conservation Authority (GRCA) coordinates and supports Ontario's Low Water Response Program for the Grand River watershed. The program is directed at those who hold a PTTW to support water conservation for drinking water, agriculture, industry, and the health of the ecosystem during low-water conditions. Nestlé is part of the GRCA Low Water Response Team representing the bottled water industry. The Low Water Response Program has three condition levels which are based on trends in flows and rainfall, which are summarized as follows (from the GRCA website):

- Level 1 – flows are less than 70% of their normal summer low flow and/or precipitation has been less than 80% of average. Water users are asked to voluntarily reduce consumption by 10%;
- Level 2 – flows are less than 50% of their normal summer low flow and/or precipitation has been less than 60% of average. The MECP will send out letters to holders of PTTWs to ask them to voluntarily reduce their consumption by 20%; and
- Level 3 – flows are less than 30% of their normal summer low flow and/or precipitation has been less than 40% of average. There is also potential for economic harm to water takers and/or significant harm to the ecosystem. The Water Response Team may ask the province to impose mandatory restrictions on those holding PTTW.

Trigger levels are reviewed along with other information (e.g., weather forecast, local water use and time of year) by the Low Water Response Team (including the GRCA) to determine if a low-water response should be recommended. The low-water response can occur on the subwatershed level or over the entire watershed.

Level 1 declarations were issued in 2005, 2007, 2012, 2015, 2016, 2017 and 2018. Grand River watershed-wide Level 2 declarations were issued in 2007, 2012, 2016 and 2017. A Level 3 declaration has never been issued for the Eramosa River subwatershed. There are additional times when the low-flow thresholds were exceeded but the Low Water Response was not declared based on the review of other information.

Because the volume of water withdrawn by Nestlé fluctuates daily based on demand and other operational aspects of the bottling facility, there are days when the withdrawal is near the permitted amount and days when it is well below the permitted amount. Nestlé monitors the withdrawals during the summer (including during drought conditions) to ensure that the water taking does not negatively affect groundwater levels in the bedrock and overburden aquifers. These rates were established from testing to determine the maximum water taking allowed in the PTTW.

Nestlé withdraws water from a bedrock aquifer that has been monitored for 19 years, including both dry and wet years. This extensive amount of monitoring has confirmed that the source is being managed for long-term sustainability. The data have shown that the effects of below-average precipitation are more evident in shallow groundwater and surface water compared to the bedrock aquifer where pumping occurs.

As per the conditions of the PTTW, Nestlé is mandatorily required to reduce their taking during drought periods in accordance with the Ontario Low Water Response Protocol and ensure that the reduction is based on the maximum taken per day as outlined in the PTTW.

To allow for some flexibility in operation, Nestlé's commitment to reducing takings during times of drought is to meet the PTTW requirements and reduce by these amounts:

- During a Level 1 Condition Nestlé limits the water taking to 90% of the daily maximum permitted volume;
- During a Level 2 Condition Nestlé limits the water taking to 80% of the daily maximum permitted volume; and
- During a Level 3 Condition Nestlé limits the water taking to 70% of the daily maximum permitted volume.

Nestlé's bottled water products are for human consumption and are essential for human hydration. Bottled water is also essential in time of emergencies. In 2017 and 2018, Nestlé donated over 2 million bottles of water to Canadians in crises during floods and fires, charitable donations and homelessness initiatives. Nestlé also has a partnership with the Canadian Red Cross to support the organization in times of need. Nestlé is a highly efficient water user and only bottles what is needed to meet customer demand. However, that demand varies from day to day and week to week and consequently, Nestlé needs some flexibility in running an efficient business. Since the drought conditions came into effect, Nestlé has been committed to limiting the daily maximum withdrawal by the percentages noted above.

9.2 Well Interference Plan

Nestlé has a well interference plan with the Town and is currently working to update the plan. A copy of the current and updated plans are included in Appendix L. The well interference plan details the steps to be taken when a complaint is received.

9.3 Other Impacts Identified by the MECP

Should the MECP determine that unacceptable interference is occurring, Nestlé will work with the MECP to investigate the cause of the interference until the problem is resolved.

10.0 REFERENCES

- AquaResource Inc., 2009. Integrated Water Budget Report, Grand River Watershed, final report prepared for the Lake Erie Source Protection Region, March 2017.
- Beacon Environmental, 2019. 2018 Biological Monitoring Program Nestlé Waters Canada Erin Property.
- Bear, J., 1979: Hydraulics of Groundwater, McGraw Hill, Inc., New York, New York.
- Bird Studies Canada, 2009. Marsh Monitoring Program Participant's Handbook for Surveying Amphibians. 2009 Edition. 13 pages. Published by Bird Studies Canada in cooperation with Environment Canada and the U.S. Environment Protection Agency. February 2009.
- Blackport Hydrogeology Inc., 2005. Groundwater Management and Protection Strategies, Groundwater Management Study, Town of Erin, prepared for the Town of Erin through funding by the Ministry of the Environment.
- Blackport Hydrogeology Inc. and Golder Associates Ltd., 2010. WHPA Delineation and Vulnerability Assessment, Town of Erin Municipal Wells, Final Report, prepared for the Town of Erin and Credit Valley Conservation, April 2010.
- Cadman, M.D., D.A. Sutherland, G.G. Beck, D. Lepage, and A.R. Couturier (eds.) 2007. Atlas of the Breeding Birds of Ontario, 2001 – 2005. Bird Studies Canada, Environment Canada, Ontario Field Ornithologist, Ontario Ministry of Natural Resources, and Ontario Nature, Toronto. Xxii + 706 pp.
- Canadian Heritage Rivers System, 2019. <http://chrs.ca/the-rivers/grand/>
- Canadian Wildlife Services. 2006. Forest Bird Monitoring Program: Site Set-up and Bird Survey Instructions. 6p.
- Chapman, L.J., and D.F. Putnam, 1984. The Physiography of Southern Ontario. Geological Survey, Special Volume 2.
- Conestoga Rovers & Associates Limited, 1989. Well Construction and Testing Investigation, Supply Well TW1-88.
- Conestoga Rovers & Associates Limited, 2006. Test Pumping Investigation Supply Well TW1-88 (Draft).
- Conestoga Rovers & Associates Limited, 2014. 2013 Annual Monitoring Report, Nestlé Waters Canada.
- Cooper, H.H., and C.E. Jacob, 1946: A generalized graphical method for evaluation formation constants and summarizing well field history, Transactions of the American Geophysical Union, vol. 27, no. 4, pp. 526-534.
- Cowan, W.R., 1976. Quaternary Geology of the Orangeville Area, Southern Ontario, Ontario Division of Mines, GR141, accompanied by Maps 2326, 2327 and 2328.
- Credit Valley Conservation, Aquafor Beech Inc., Blackport Hydrogeology Inc., 2011. Erin Servicing and Settlement Master Plan, Phase 1 – Environmental Component – Existing Conditions Report, May 2011.
- Driscoll, F.G., 1986: Groundwater and Wells, Johnson Division, St. Paul, Minnesota.
- Ferguson, H.; O'Neill, A.; and Cork, H. (1970). Mean Evapotranspiration over Canada, Water Resources Research, 6(6):1618-1633.

- Golder Associates Ltd., 2006. County of Wellington Groundwater Protection Study, September 2006.
- Grand River Conservation Authority, 2019. <https://www.grandriver.ca/en/our-watershed/Heritage-River-Designation.aspx>
- Howe, R.W., G.J. Niemi, S.J. Lewis, and D.A. Welsh. 1997. A standard method for monitoring songbird populations in the Great Lakes Region. *The Passenger Pigeon* 59(3): 189-194.
- Lee, H.T., W.D. Bakowsky, J. Riley, J. Bowles, M. Puddister, P. Uhlig and S. McMurray. 1998. Ecological Land Classification for Southern Ontario: First Approximation and Its Application. Ontario Ministry of Natural Resources. SCSS Field Guide FG-02. 225 pp.
- Liberty, B.A.; 1975: Map 2339, Paleozoic Geology, Orangeville, Scale 1:50,000. Produced from original mapping by:
- Bond, I.J., 1972: Geology of Orangeville East map-sheet
 - Telford, P.G., 1973: Geology of Orangeville West map-sheet
- Matrix Solutions Inc., 2019. Groundwater Flow Modelling Report for Renewal of the Permit to Take Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities, prepared for the City of Guelph and Nestlé Waters Canada, February 2019.
- Matrix Solutions Inc., 2018a. Guelph-Guelph/Eramosa Water Quantity Policy Development Study: Threats Management Strategy. Prepared for the Lake Erie Source Protection Region.
- Matrix Solutions Inc., 2018b. Assessment of Climate Change and Assessment of Water Quantity Threats in the IPZ-Q in Support of the Guelph-Guelph/Eramosa Water Quantity Policy Study. Prepared for the Lake Erie Source Protection Region.
- Matrix Solutions Inc., 2017. City of Guelph and Township of Guelph/Eramosa Tier 3 Water Budget and Local Area Risk Assessment. Prepared for the Lake Erie Source Protection Region.
- Matrix Solutions Inc., 2014. City of Guelph Tier Three Water Budget and Local Area Risk Assessment, Appendix B: Groundwater Flow Model Report, prepared for the Lake Erie Source Protection Region, July 2014. [Appendix B of the City of Guelph and Township of Guelph/Eramosa Tier Three Water Budget and Local Area Risk Assessment report.]
- Matrix Solutions Inc., and S.S. Papadopoulos & Associates, 2014. Region of Waterloo Tier Three Water Budget and Local Area Risk Assessment, Appendix B: Selection of Appropriate WHPA Q1 Drawdown Contour, prepared for the Region of Waterloo, September 2014.
- Oldham, M.J. and S.R. Brinker, S.R. 2009. Rare Vascular Plants of Ontario. Fourth Edition. Natural Heritage Information Centre, Ontario Ministry of Natural Resources, Peterborough, Ontario. 188 pages.
- Ontario Ministry of the Environment and Climate Change, 2017. Interim Procedural and Technical Guidance Document for Bottled Water Renewals: Permit to Take Water Applications and Hydrogeological Study Requirements, Ontario Ministry of the Environment and Climate Change Operations Division, April 2017.

Signature Page

Golder Associates Ltd.



Greg Padusenko, M.Sc., P.Eng., P.Geol.
Hydrogeologist



John Piersol, M.Sc., P.Geol.
Associate/Hydrogeologist

S.S. Papadopoulos & Associates, Inc.



Christopher J. Neville, M.Sc., P.Eng.
Hydrogeologist

C. Portt & Associates

Cam Portt, M.Sc.
Fisheries Consultant

Beacon Environmental




Ken Ursic, M.Sc.
Senior Ecologist

GRP/JAP/II

Golder and the G logo are trademarks of Golder Associates Corporation

FIGURES



LEGEND

- City/Town
- Surface Water Flow Station
- Main Road
- - - Local Road
- + Railway
- Watercourse
- ▨ Evaluated-Other
- ▨ Evaluated-Provincial
- Waterbody
- Wooded Area
- Provincial Park
- ▭ Municipal Boundary
- ▭ Property Boundary

Watersheds

- Credit - 16 Mile
- Humber - Don
- Upper Grand

Sub-Watersheds

- Eramosa River Sub-Watershed



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDR ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.


CLIENT
 NESTLE WATERS CANADA

PROJECT
 HYDROGEOLOGICAL STUDY

TITLE
 SITE LOCATION

CONSULTANT	
YYYY-MM-DD	2018-07-17
DESIGNED	KD
PREPARED	JMC/MM
REVIEWED	GP
APPROVED	JAP

PATH: S:\Client\Nestle\Erin\09_PROD\1311520250_Hydro_G100_PROD\0015_2018_Hydro\GIS\Site_Location.mxd PRINTED ON: 2018-07-18 AT: 12:25:56 PM
 28mm IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM:



LEGEND

- Production Well
- Municipal Production Well
- Watercourse
- Property Boundary



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDER ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.

CLIENT
 NESTLE WATERS CANADA

PROJECT
 HYDROGEOLOGICAL STUDY

TITLE
SITE SETTING


CONSULTANT	YYYY-MM-DD	2018-08-14
	DESIGNED	KD
	PREPARED	JMC
	REVIEWED	GP
	APPROVED	JAP

PROJECT NO. 13-1152-0250 (9000) CONTROL 0015 REV. 1.0 **FIGURE 2**

PATH: S:\Client\New\Kiering\PROJ\1311520250_Hydro_GI\40_PROJ\0015_2018_HydroGIS\Study_PTTW_Renewal\1311520250-015-CH-002.mxd PRINTED ON: 2018-08-14 AT: 1:27:49 PM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM 28mm

Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus



Annual Permitted Taking - 406,245,000L

PROJECT

NESTLE WATERS CANADA
Town of Erin, Ontario

TITLE

TW1-88 ANNUAL WATER TAKING (2000 TO 2018)



DATE DECEMBER 2018

DESIGN KS


REVIEW GP

APPROVED GP

PROJECT NO.
13-1152-0250 (9000)

REV
A

FIGURE
3



CLIENT
NESTLE WATERS CANADA

PROJECT
HYDROGEOLOGICAL STUDY

CONSULTANT

YYYY-MM-DD 2017-04-06

TITLE

ERIN TW1-88



PREPARED MR

DESIGN MR

REVIEW GP

APPROVED GP

PROJECT No.
13-1152-0250

PHASE
9000


Rev.
1.0

FIGURE
4

Path: \\golder\gis\m\1311520250_Hydro_G40_PROD\0009_Water_Resource_Review_2016 | File Name: 1311520250-0015-CH-0003.dwg

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM ANSIA

25 mm



LEGEND

- Production Well
- City/Town
- Watercourse
- TW1-88 1 km Buffer
- Property Boundary

Landuse Category

- Automotive or Fuel Station
- Commercial
- Farm/Agriculture
- Industrial
- Institutional
- Residential
- Vacant or Conservation Authority Land
- Water Supply

0 200 400 600 800
1:20,000 Meters

REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDER ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.

CLIENT
 NESTLE WATERS CANADA

PROJECT
 HYDROGEOLOGICAL STUDY

TITLE
 LAND USE


CONSULTANT	DATE
GOLDER	2018-07-17
DESIGNED	JMC
PREPARED	JMC
REVIEWED	GP
APPROVED	JAP

PROJECT NO. 13-1152-0250 (9000) CONTROL 0015 REV. 1.0

PATH: S:\Clients\Nestle\Eng\09_PROD\1311520250_Hydro_GI\0_PROD\0015_2018_HydroGISStudy_PTTW_Review\1311520250-0015-CH-000.mxd PRINTED ON: 2018-07-17 AT: 6:20:05 PM

Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 28mm




LEGEND

- City/Town
- Main Road
- Local Road
- Railway
- Topographic Elevation Contour (masl)
- Watercourse
- ▨ Wetland
- ▨ Provincially Significant Wetland
- Waterbody
- ▭ Municipal Boundary
- ▭ Property Boundary

Topographic Elevation (masl)

High : 505

Low : 307



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDER ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.

CLIENT
 NESTLE WATERS CANADA


PROJECT
 HYDROGEOLOGICAL STUDY

TITLE
 TOPOGRAPHY AND DRAINAGE

CONSULTANT	DATE
DESIGNED	2018-07-17
PREPARED	KD
REVIEWED	JMC
APPROVED	GP
	JAP


PROJECT NO. 13-1152-0250 (9000) CONTROL 0015 REV. 1.0 FIGURE 6

P:\14 - S:\Client\Nestle\Erin\09_PROD\1311520250_Hydro_GI\0_PROD\0015_Hydro_GI\0_PROD\0015_1311520250-015-Ch-0002.mxd PRINTED ON: 2018-07-17 AT: 6:19:46 PM
 IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 29mm



LEGEND

- City/Town
- Cross-Section Location
- Main Road
- Local Road
- Railway
- Watercourse
- Wetland
- Provincially Significant Wetland
- Waterbody
- Municipal Boundary
- Property Boundary
- 3: Paleozoic bedrock
- 5b: Stone-poor, carbonate-derived silty to sandy till
- 5d: Glaciolacustrine-derived silty to clayey till
- 6: Ice-contact stratified deposits
- 7: Glaciofluvial deposits
- 7a: Sandy deposits
- 7b: Gravelly deposits
- 8a: Massive-well laminated
- 9c: Foreshore-basinal deposits
- 19: Modern alluvial deposits
- 20: Organic deposits



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDER ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.

CLIENT
 NESTLE WATERS CANADA

PROJECT
 HYDROGEOLOGICAL STUDY

TITLE
 REGIONAL QUATERNARY GEOLOGY


CONSULTANT	DATE
DESIGNED	2018-07-17
PREPARED	KD
REVIEWED	JMC
APPROVED	GP
	JAP

PROJECT NO. 13-1152-0250 (9000) CONTROL 0015 REV. 1.0



PATH: S:\Clients\Nestle\Erin\09_PROD\1311520250_Hydro_GI\0_PROD\0015_2018_HydroGIS\Study_PTTM_Review\1311520250-0015-Ch-0000.mxd PRINTED ON: 2018-07-17 AT: 6:19:06 PM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 28mm



HORIZONTAL DISTANCE (metres)
 VERTICAL TO HORIZONTAL EXAGGERATION: 10:1



LEGEND

WELL DESIGNATION
 GROUND SURFACE
 WATER LEVEL
 ON WELL COMPLETION
 (MONTH / YEAR)
 STATIC WATER LEVEL
 (NOV. 3/05)

- PRDG - PRE DUG
- OB - OVERBURDEN
- CL - CLAY
- SI - SILT
- SA - SAND
- GR - GRAVEL
- STNS - STONES
- HP - HARDPAN
- RK - ROCK (BEDROCK)
- LMSN - LIMESTONE (BEDROCK)
- DST - DOLOSTONE
- CL, SA - FIRST COMPONENT IS MOST COMMON MATERIAL


REFERENCE(S)
 CROSS-SECTION A-A' OBTAINED FROM CRA 2013 ANNUAL MONITORING REPORT, APRIL 2014.

CLIENT		NESTLE WATERS CANADA	
PROJECT		HYDROGEOLOGICAL STUDY	
TITLE		HYDROGEOLOGIC CROSS-SECTION A-A'	
CONSULTANT	YYYY-MM-DD	2018-07-17	
DESIGNED		KD	
PREPARED		JMC	
REVIEWED		GP	
APPROVED		JAP	




PATH: S:\Clients\Nestle\09_1311520250_Hydro_GI\0_PROD\0015_2018_Hydrogeology_PTTW_Review\1311520250-0015-01-0007.mxd PRINTED ON: 2018-07-17 AT: 8:19:36 PM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 28mm



HORIZONTAL DISTANCE (metres)
 VERTICAL TO HORIZONTAL EXAGGERATION: 10:1





- LEGEND**
- PRDG - PRE DUG
 - CL - CLAY
 - SI - SILT
 - SA - SAND
 - GR - GRAVEL
 - STNS - STONES
 - HP - HARDPAN
 - RK - ROCK (BEDROCK)
 - LMSN - LIMESTONE (BEDROCK)
 - DST - DOLOSTONE
 - CL, SA - FIRST COMPONENT IS MOST COMMON MATERIAL

REFERENCE(S)
 CROSS-SECTION B-B' OBTAINED FROM CRA 2013 ANNUAL MONITORING REPORT, APRIL 2014.

CLIENT NESTLE WATERS CANADA		
PROJECT HYDROGEOLOGICAL STUDY		
TITLE HYDROGEOLOGIC CROSS-SECTION B-B'		
CONSULTANT	YYYY-MM-DD	2017-07-17
	DESIGNED	KD
	PREPARED	JMC
	REVIEWED	GP
	APPROVED	JAP
PROJECT NO. 13-1152-0250 (9000)	CONTROL 0015	REV. 1.0
		FIGURE 9

PATH: S:\Clients\Nestle\09_PROD\1311520250_Hydro_GI\0_PROD\0015_2018_Hydrogeology_PTTW_Renewal\1311520250-0015-CH-0008.mxd PRINTED ON: 2018-07-17 AT: 8:19:34 PM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 28mm




- LEGEND**
- PRDG - PRE DUG
 - OB - OVERBURDEN
 - CL - CLAY
 - SI - SILT
 - SA - SAND
 - GR - GRAVEL
 - BL - BOULDER
 - STNS - STONES
 - HP - HARDPAN
 - RK - ROCK (BEDROCK)
 - LMSN - LIMESTONE (BEDROCK)
 - DST - DOLOSTONE
 - CL, SA - FIRST COMPONENT IS MOST COMMON MATERIAL

REFERENCE(S)
CROSS-SECTION C-C' OBTAINED FROM CRA 2013 ANNUAL MONITORING REPORT, APRIL 2014.

CLIENT NESTLE WATERS CANADA		
PROJECT HYDROGEOLOGICAL STUDY		
TITLE HYDROGEOLOGIC CROSS-SECTION C-C'		
CONSULTANT	YYYY-MM-DD	2018-07-17
	DESIGNED	KD
	PREPARED	JMC
	REVIEWED	GP
	APPROVED	JAP
PROJECT NO. 13-1152-0250 (9000)	CONTROL 0015	REV. 1.0
		FIGURE 10


PATH: S:\chem\water\enr\09_PROJ\1311520250_Hydro_G140_PROD\0015_2018_HydrogeolStudy_PTTW_Review\1311520250-0015-CH-0009.mxd PRINTED ON: 2018-07-17 AT: 6:19:32 PM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 28mm



LEGEND

- City/Town
- Main Road
- Local Road
- Railway
- Watercourse
- ▨ Wetland
- ▨ Provincially Significant Wetland
- Waterbody
- ▭ Municipal Boundary
- ▭ Property Boundary
- 20: Guelph
- 19: Amabel
- 17: Clinton-Cataract Group
- 16: Queenston



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDR ASSOCIATES LTD UNDER LICENCE FROM ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.

CLIENT
NESTLE WATERS CANADA

PROJECT
HYDROGEOLOGICAL STUDY


TITLE
REGIONAL BEDROCK GEOLOGY

CONSULTANT	DATE
	YYYY-MM-DD 2018-07-17
	DESIGNED KD
	PREPARED JMC
	REVIEWED GP
	APPROVED JAP

PROJECT NO. 13-1152-0250 (9000) CONTROL 0015 REV. 1.0

PATH: S:\chem\mex\er\09_P\PROJ\1311520250_Hydro_G140_PROD\0015_Hydro_G140_PROD\0015_Hydro_G140_PROD\1311520250-0015-CH-0010.mxd PRINTED ON: 2018-07-17 AT: 6:19:28 PM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 25mm



LEGEND

- City/Town
- ⊕ Monitoring Well (Bedrock)
- ⊕ Monitoring Well (Overburden)
- ⊕ Production Well
- Private Well (Bedrock)
- Private Well (Overburden)
- Private Well (Deep Overburden)
- ▲ Piezometer
- Surface Water Station
- Water Level Elevation Contour (Jan. 24, 2000)
- Main Road
- Local Road
- Railway
- Watercourse
- ▨ Wetland
- ▨ Provincially Significant Wetland
- Waterbody
- ▭ Property Boundary



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDR ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.
 WATER LEVEL ELEVATION CONTOUR OBTAINED FROM CRA 2013 ANNUAL MONITORING
 REPORT, APRIL 2014.

CLIENT
NESTLE WATERS CANADA

PROJECT
HYDROGEOLOGICAL STUDY

TITLE
**POTENTIOMETRIC SURFACE OF BEDROCK AQUIFER
 (NON-PUMPING CONDITION JANUARY 2000)**

CONSULTANT	YYYY-MM-DD	2018-07-17
DESIGNED		KD
PREPARED		JMC
REVIEWED		GP
APPROVED		JAP


PROJECT NO. 13-1152-0250 (9000) CONTROL 0013 REV. 1.0



Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

PATH: S:\Clients\Nestle\Proj\13-1152-0250_Hydro_GI\40_PROD\0015_2018_Hydro\Study_PTTM_Renewal\1311520250-0015-CH-0011.mxd PRINTED ON: 2018-07-17 AT: 6:19:08 PM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 28mm



LEGEND

- City/Town
- ⊕ Monitoring Well (Bedrock)
- ⊕ Monitoring Well (Overburden)
- ⊕ Production Well
- Private Well (Bedrock)
- Private Well (Overburden)
- Private Well (Deep Overburden)
- ▲ Piezometer
- Surface Water Station
- Drawdown Contour (June 13/15, 2001)
- Main Road
- Local Road
- Railway
- Watercourse
- ▨ Wetland
- ▨ Provincially Significant Wetland
- Waterbody
- ▭ Property Boundary




REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDR ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.
 DRAWDOWN CONTOURS FROM CRA FIGURE 4.2 FILE 13764-10(017)GN-WA012.DWG.

CLIENT		NESTLE WATERS CANADA	
PROJECT		HYDROGEOLOGICAL STUDY	
TITLE		INTERPRETED DRAWDOWN IN BEDROCK AQUIFER (JUNE 2001)	
CONSULTANT	YYYY-MM-DD	2018-07-17	
	DESIGNED	KD	
	PREPARED	JMC	
	REVIEWED	GP	
	APPROVED	JAP	

Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

PATH: S:\Clients\Nestle\13-1152-0250_Hydro_GI\40_PROD\0015_2018_Hydro\Study_PTTM_Renewal\1311520250-0015-CH-0013.mxd PRINTED ON: 2018-07-17 AT: 6:18:06 PM
 IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 28mm



● SW1 Flow

PROJECT

NESTLE WATERS CANADA
Town of Erin, Ontario

TITLE

**FLOW IN CREEK AT SW1
ON NESTLE PROPERTY IN ERIN**



DATE	DECEMBER 2018
DESIGN	KJ
REVIEW	GP
APPROVED	GP

PROJECT NO.


13-1152-0250 (9000)

REV

A

FIGURE

14



— Eramosa River Above Guelph Station


PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario



DATE DECEMBER 2018
 DESIGN KJ
 REVIEW GP
 APPROVED GP

TITLE
FLOW IN THE ERAMOSIA RIVER ABOVE GUELPH

PROJECT NO. 13-1152-0250 (9000) REV A FIGURE 15



LEGEND

- 2018 Well Survey Location
- Private Wells Monitored by Nestle
- MECP Water Well Location
- ⊕ Production Well
- ⊙ City/Town
- Main Road
- Local Road
- Watercourse
- TW1-88 1 km Buffer
- Property Boundary



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDER ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.
 MECP WATER WELL LOCATION - WATER WELL INFORMATION SYSTEM (WWIS) - WELL RECORD DATA, MECP FORMERLY MOECC, 2018

CLIENT
 NESTLE WATERS CANADA

PROJECT
 HYDROGEOLOGICAL STUDY

TITLE
 MECP WATER WELL RECORDS


CONSULTANT	YYYY-MM-DD	2018-08-14
GOLDER	DESIGNED	JMC
	PREPARED	JMC/PR
	REVIEWED	GP
	APPROVED	JAP

PROJECT NO. 13-1152-0250 (9000) CONTROL 0015 REV. 1.0 FIGURE 16

Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

S:\Client\Nestle\Envi\08_PROD\1311520250_Hydro_GIS\PROJ\0015_2018_Hydro\Study_PTTM_Renewal\1311520250\0015-Ch-0014.mxd

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM 28mm




PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario

TITLE
HISTORICAL ANNUAL PRECIPITATION (2008 TO 2018)

PROJECT NO. 13-1152-0250 (9000) REV A FIGURE 17



DATE DECEMBER 2018
 DESIGN KJ
 REVIEW GP
 APPROVED GP



LEGEND

- City/Town
- Production Well
- ⊕ Monitoring Well (Bedrock)
- ⊕ Monitoring Well (Overburden)
- Private Well (Bedrock)
- Private Well (Overburden)
- Private Well (Deep Overburden)
- ▲ Piezometer
- Surface Water Station
- Private Well (Overburden - not monitored)
- Private Well (Bedrock - not monitored)
- Main Road
- Local Road
- Railway
- Watercourse
- ▨ Wetland
- ▨ Provincially Significant Wetland
- Waterbody
- ▭ Municipal Boundary
- ▭ Property Boundary



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDER ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.

CLIENT
NESTLE WATERS CANADA

PROJECT
HYDROGEOLOGICAL STUDY

TITLE
MONITORING LOCATIONS


CONSULTANT	DATE
	YYYY-MM-DD 2018-07-17
	DESIGNED KD
	PREPARED JMC
	REVIEWED GP
	APPROVED JAP

PROJECT NO. 13-1152-0250 (9000)	CONTROL 0005	REV. 1.0	FIGURE 18
------------------------------------	-----------------	-------------	---------------------


Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

PATH: S:\chem\h2o\proj\1311520250_Hydro_GI\40_PROD\0015_2018_Hydro\Map\Study_PTTW_Renewal\1311520250-0015-Ch-0013.mxd PRINTED ON: 2018-07-17 AT: 6:18:46 PM

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: 28mm



- LEGEND**
- Production Well
 - Watercourse
 - Property Boundary
 - Vegetation Monitoring Station
 - Amphibian Call Monitoring Station (with 250 m radius)
 - Breeding Bird Monitoring Station (with 125 m radius)



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDER ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.

CLIENT
NESTLE WATERS CANADA

PROJECT
HYDROGEOLOGICAL STUDY

TITLE
NATURAL ENVIRONMENT MONITORING

CONSULTANT	YYYY-MM-DD	2018-07-25
	DESIGNED	JMC
	PREPARED	JMC
	REVIEWED	GP
	APPROVED	JAP

PROJECT NO. 13-1152-0250 (9000) CONTROL 0015 REV. 1.0

FIGURE
19

Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

S:\Clients\Keele\Enr\09_PRC\1311520250_Hydr_GW4_PROD\0015_2018_Hydrogeol_Study_PTTV_Review\1311520250-0015-CH-0015.mxd

25mm IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM:



- LEGEND**
- City/Town
 - Production Well
 - Monitoring Well (Bedrock)
 - Private Well (Bedrock)
 - Water Elevation (August, 2018)
 - Water Elevation Contour (masl)
 - Railway
 - Watercourse
 - Wetland
 - Provincially Significant Wetland
 - Waterbody
 - Municipal Boundary
 - Property Boundary



REFERENCE(S)
 BASE DATA - MNR LIO, OBTAINED 2015
 PRODUCED BY GOLDR ASSOCIATES LTD UNDER LICENCE FROM
 ONTARIO MINISTRY OF NATURAL RESOURCES, © QUEENS PRINTER 2013
 PROJECTION: UTM NAD83 ZONE 17
 PROPERTY BOUNDARY FROM CRA FILE 13764-10(017)GN-WA002.DWG.

CLIENT
NESTLE WATERS CANADA

PROJECT
HYDROGEOLOGICAL STUDY


TITLE
**POTENTIOMETRIC SURFACE OF BEDROCK AQUIFER
 (AUGUST 2018)**

CONSULTANT	DATE
YYYY-MM-DD	2019-05-14
DESIGNED	JMC
PREPARED	PR
REVIEWED	GP
APPROVED	JAP

PROJECT NO. 13-1152-0250 (2000) CONTROL 0016 REV. 1.0


S:\Clients\Nestle\Erin\13-1152-0250_Hydro_GW6_PROD\0115_2019_Hydrogeology\Study_PTTW_Renewal\1311520250-0115-GH-0016.mxd

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM 28mm



September 30, 2007

October 31, 2007



July 31, 2012

August 31, 2012

September 30, 2012

APPENDIX A

Permit To Take Water

Ministry of the Environment

West-Central Region
Technical Support Section
12th Floor
119 King St W
Hamilton ON L8P 4Y7
Fax: (905)521-7820
Tel: (905) 521-7720

Ministère de l'Environnement

Direction régionale du Centre-Ouest
Secteur du Soutien Technique
12e étage
119 rue King W
Hamilton ON L8P 4Y7
Télécopieur: (905)521-7820
Tél:(905) 521-7720



February 25, 2014

Nestle Canada Inc.
101 Brock Road S.
Puslinch, Ontario N1H 6H9

Attention: Ms. Andreanne Simard

Dear Ms. Simard:

RE: Amendments to monitoring program
Permit to Take Water 3716-8UZMCU
Reference Number 8420-8TAMGM

NOTICE

Pursuant to s. 100, Ontario Water Resources Act, R.S.O. 1990, c. O.40 as amended, I am issuing notice that, as Director of Section 34 of the Ontario Water Resources Act, I am exercising my discretion to amend Permit to Take Water 3716-8UZMCU part of condition 4.1. All other terms and conditions of Permit to Take Water 3716-8UZMCU shall continue in force.

Per condition 4.4, the Permit Holder notified the Director on July 25, 2013 of inaccuracies in condition 4.1 and certain monitoring locations becoming inaccessible or requiring replacement. The notification included suggested replacements. Further reasoning was provided by the Permit Holder on January 31, 2014. The delay in approving the amendment was due to other processes regarding the Permit. On February 24, 2014 Ms. Simard clarified the monitoring locations of condition 4.1(ii).

This Notice supersedes the Notice issued February 3, 2014. Condition 4.1 is hereby revoked and replaced as follows:

4.1 The Permit Holder shall establish the following monitoring program for the duration of the Permit:

Bedrock Wells

(i) Continuous monitoring of ground water levels at the following locations:

- TW1-88
- D2A
- D3 (MOE #6710228)
- MW5A
- MW6A
- D36B (MOE Tag#A001807)

(ii) Monthly monitoring of ground water levels at the following locations:

- D19 (MOE #6709207)
- MW11A/B-08
- D24B (MOE #6708146) and D24A (MOE #6711344)
- D26A (MOE #6700678) and D26B
- MW12A/B-08
- D8 (MOE#6708720)
- D15 (MOE#6709532)
- D32 (MOE#6708153)

Overburden Wells

(i) Continuous monitoring of ground water levels at the following locations:

- MW3A/B
- D2B
- MW5B
- MW6B
- D26C
- D36A
- D27

(ii) Monthly monitoring of ground water levels at the following locations:

- TW1-99 (MOE #6712960)
- D27 (MOE #6712147)
- D7B
- MW2

Piezometers

i) Continuous monitoring of water level and vertical hydraulic gradients at the following locations:

- P01A/B-07
- P03A/B-05
- P06A/B-07
- P10A/B-05
- P11A/B-05
- P12A/B-07
- P13A/B-07

Surface Water

(i) Continuous monitoring of surface water levels at the following locations:

- ST03-05
- SW1
- SW3
- SW4
- SW5
- SW7

(ii) Monthly monitoring of flow and development of appropriate stage-discharge curves at the following locations:

- SW1
- SW3
- SW7

This Notice now forms part of the current permit and must be attached to the original Permit to Take Water, if available. If the original is no longer available, this letter must be kept attached to a certified copy of the Permit to Take Water.

Any change in circumstances related to this permit should be reported promptly to a Director.

It is your responsibility to ensure that any person taking water under the authority of this permit is familiar with and complies with the terms and conditions.

In accordance with Section 100 of the Ontario Water Resources Act, R.S.O. 1990, you may by written notice served upon me, the Environmental Review Tribunal and the Environmental Commissioner, Environmental Bill of Rights, R.S.O. 1993, Chapter 28, within 15 days after receipt of this Notice, require a hearing by the Tribunal. The Environmental Commissioner will place notice of your appeal on the Environmental Registry. Section 101 of the Ontario Water Resources Act, as amended provides that the Notice requiring a hearing shall state:

1. The portions of the Permit or each term or condition in the Permit in respect of which the hearing is required, and;
2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

In addition to these legal requirements, the Notice should also include:

3. The name of the appellant;
4. The address of the appellant;
5. The Permit to Take Water number;
6. The date of the Permit to Take Water;
7. The name of the Director;
8. The municipality within which the works are located;

This notice must be served upon:

<i>The Secretary Environmental Review Tribunal 2300 Yonge Street, Suite 1700 Toronto, Ontario M4P 1E4</i>	<u>AND</u>	<i>The Director, Section 34 Ministry of the Environment 12th Floor 119 King St W Hamilton ON L8P 4Y7 Fax: (905)521-7820</i>
---	------------	---

Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal:


by telephone at (416) 314-4600

by fax at (416) 314-4506

by e-mail at

www.ert.gov.on.ca

Yours truly,



Carl Slater
Director, Section 34, Ontario Water Resources Act
West Central Region

File Storage Number: AP28 ERNE

PERMIT TO TAKE WATER
Ground Water
NUMBER 3716-8UZMCU

Pursuant to Section 34 of the Ontario Water Resources Act, R.S.O. 1990 this Permit To Take Water is hereby issued to:

Nestle Canada Inc.
101 Brock Road S.
Puslinch, Ontario N1H 6H9

For the water taking from: One bedrock drilled well (TW1-88) MOE Well Tag No.: A095193

Located at: Lot 24, Concession 7, Geographic Township of Erin
Erin, County of Wellington

For the purposes of this Permit, and the terms and conditions specified below, the following definitions apply:

DEFINITIONS

- (a) "Director" means any person appointed in writing as a Director pursuant to section 5 of the OWRA for the purposes of section 34, OWRA.
- (b) "Provincial Officer" means any person designated in writing by the Minister as a Provincial Officer pursuant to section 5 of the OWRA.
- (c) "Ministry" means Ontario Ministry of the Environment.
- (d) "District Office" means the Guelph District Office.
- (e) "Permit" means this Permit to Take Water No. 3716-8UZMCU including its Schedules, if any, issued in accordance with Section 34 of the OWRA.
- (f) "Permit Holder" means Nestle Canada Inc..
- (g) "OWRA " means the *Ontario Water Resources Act*, R.S.O. 1990, c. O. 40, as amended.

You are hereby notified that this Permit is issued subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. Compliance with Permit

- 1.1 Except where modified by this Permit, the water taking shall be in accordance with the application for this Permit To Take Water, dated March 22, 2012 and signed by Don DeMarco, and all Schedules included in this Permit.
- 1.2 The Permit Holder shall ensure that any person authorized by the Permit Holder to take water under this Permit is provided with a copy of this Permit and shall take all reasonable measures to ensure that any such person complies with the conditions of this Permit.
- 1.3 Any person authorized by the Permit Holder to take water under this Permit shall comply with the conditions of this Permit.
- 1.4 This Permit is not transferable to another person.
- 1.5 This Permit provides the Permit Holder with permission to take water in accordance with the conditions of this Permit, up to the date of the expiry of this Permit. This Permit does not constitute a legal right, vested or otherwise, to a water allocation, and the issuance of this Permit does not guarantee that, upon its expiry, it will be renewed.
- 1.6 The Permit Holder shall keep this Permit available at all times at or near the site of the taking, and shall produce this Permit immediately for inspection by a Provincial Officer upon his or her request.
- 1.7 The Permit Holder shall report any changes of address to the Director within thirty days of any such change. The Permit Holder shall report any change of ownership of the property for which this Permit is issued within thirty days of any such change. A change in ownership in the property shall cause this Permit to be cancelled.

2. General Conditions and Interpretation

- 2.1 Inspections
The Permit Holder must forthwith, upon presentation of credentials, permit a Provincial Officer to carry out any and all inspections authorized by the OWRA, the *Environmental Protection Act*, R.S.O. 1990, the *Pesticides Act*, R.S.O. 1990, or the *Safe Drinking Water Act*, S. O. 2002.
- 2.2 Other Approvals
The issuance of, and compliance with this Permit, does not:
 - (a) relieve the Permit Holder or any other person from any obligation to comply with any other applicable legal requirements, including the provisions of the *Ontario Water Resources Act*, and the *Environmental Protection Act*, and any regulations made thereunder; or

(b) limit in any way any authority of the Ministry, a Director, or a Provincial Officer, including the authority to require certain steps be taken or to require the Permit Holder to furnish any further information related to this Permit.

2.3 Information

The receipt of any information by the Ministry, the failure of the Ministry to take any action or require any person to take any action in relation to the information, or the failure of a Provincial Officer to prosecute any person in relation to the information, shall not be construed as:

(a) an approval, waiver or justification by the Ministry of any act or omission of any person that contravenes this Permit or other legal requirement; or

(b) acceptance by the Ministry of the information's completeness or accuracy.

2.4 Rights of Action

The issuance of, and compliance with this Permit shall not be construed as precluding or limiting any legal claims or rights of action that any person, including the Crown in right of Ontario or any agency thereof, has or may have against the Permit Holder, its officers, employees, agents, and contractors.

2.5 Severability

The requirements of this Permit are severable. If any requirements of this Permit, or the application of any requirements of this Permit to any circumstance, is held invalid or unenforceable, the application of such requirements to other circumstances and the remainder of this Permit shall not be affected thereby.

2.6 Conflicts

Where there is a conflict between a provision of any submitted document referred to in this Permit, including its Schedules, and the conditions of this Permit, the conditions in this Permit shall take precedence.

3. **Water Takings Authorized by This Permit**

3.1 **Expiry**

This Permit expires on **August 31, 2017**. No water shall be taken under authority of this Permit after the expiry date.

3.2 Amounts of Taking Permitted

The Permit Holder shall only take water from the source, during the periods and at the rates and amounts of taking specified in Table A. Water takings are authorized only for the purposes specified in Table A.

Table A

	Source Name / Description:	Source: Type:	Taking Specific Purpose:	Taking Major Category:	Max. Taken per Minute (litres):	Max. Num. of Hrs Taken per Day:	Max. Taken per Day (litres):	Max. Num. of Days Taken per Year:	Zone/ Easting/ Northing:
1	TW1-88	Well Drilled	Bottled Water	Commercial	773	24	1,113,000	365	17 568384 4847833
							Total Taking:	1,113,000	

3.3 Notwithstanding the Maximum Taken per Minute and Maximum Taken per Day specified in the Table A of Condition 3.2, the instantaneous rate and amount of taking may increase up to a maximum of 946 litres per minute (LPM) and 1,362,240 liters per day (LPD) in each month between April 1 and September 30 for the duration of the Permit in order to provide operational flexibility. However, the average daily taking in any month between April 1 and September 30 shall not exceed 1,113,000 (LPD).

3.4 Notwithstanding Conditions 3.2 and 3.3 the maximum daily water taking shall be reduced should the Grand River Low Water Response Team declare a Level 1 or Level 2 drought condition in the watershed in which the taking is located. The reductions shall be in accordance with the Ontario Low Water Response Protocol and ensure that the reduction is based on the maximum taken per day permitted in Table A.

3.5 Notwithstanding Conditions 3.2, 3.3, and 3.4 should the Ontario Water Directors Committee declare a Level 3 drought condition in the watershed in which the taking is located, the maximum daily water taking shall be reduced in accordance with the Level 3 declaration.

4. Monitoring

4.1 The Permit Holder shall establish the following monitoring program for the duration of the Permit:

Bedrock Wells

(i) Continuous monitoring of ground water levels at the following locations:

- TW1-88
- D2A
- D3 (MOE #6710228)
- MW5A
- MW6A
- D36B (MOE Tag#A001807)

(ii) Monthly monitoring of ground water levels at the following locations:

- D19 (MOE #6709207)
- D24A (MOE #6711344)
- D24B (MOE #6708146)

- D26A (MOE #6700678)
- D26D
- D27
- MOE #6714441
- MOE # 6705153
- D7 (MOE#6708388)
- D8 (MOE#6708720)
- D12
- D32 (MOE#6708153)

Overburden Wells

(i) Continuous monitoring of ground water levels at the following locations:

- MW3A/B
- D2B
- MW5B
- MW6B
- D26C
- D36A

(ii) Monthly monitoring of ground water levels at the following locations:

- TW1-99 (MOE #6712960)
- D27 (MOE #6712147)
- new overburden well replacing D5
- MW2

Piezometers

i) Continuous monitoring of water level and vertical hydraulic gradients at the following locations:

- P01A/B-05
- P03A/B-07
- P06A/B-07
- P10A/B-05
- P11A/B-05
- P12A/B-07
- P13A/B-07

Surface Water

(i) Continuous monitoring of surface water levels at the following locations:

- ST03-05
- SW1
- SW3
- SW4
- SW5
- SW7

(ii) Monthly monitoring of flow and development of appropriate stage-discharge curves at the following locations:

- SW1
- SW3

- SW7

- 4.2 Continuous ground water monitoring shall be datalogged at 60 minute intervals and downloaded monthly; however, daily minimum water levels may be used to evaluate the water level variation with respect to pumping to improve the data handling and presentation. Monthly monitoring shall be conducted in the same week each calendar month for the duration of the Permit.
- 4.3 The water level data collected in piezometers or multilevel monitoring wells (two wells at one location or multiple wells in one borehole screened at different intervals) shall be plotted as gradient vs. time and interpreted to assess the potential impact of taking on vertical hydraulic gradients (upward/downward) and hydraulic connection of the ground water with the surface water, if any.
- 4.4 The Permit Holder shall identify to the Director in writing for his or her approval, within 15 days of any monthly monitoring event, any monitoring locations identified in Condition 4.1 which become inaccessible and/or abandoned along with a recommendation for replacement of these monitoring locations. Upon approval of the Director, the monitoring program shall be appropriately modified.
- 4.5 Under section 9 of O. Reg. 387/04, and as authorized by subsection 34(6) of the Ontario Water Resources Act, the Permit Holder shall, on each day water is taken under the authorization of this Permit, record the date, the volume of water taken on that date and the rate at which it was taken. The daily volume of water taken shall be measured by a flow meter or calculated in accordance with the method described in the application for this Permit, or as otherwise accepted by the Director. The Permit Holder shall keep all records required by this condition current and available at or near the site of the taking and shall produce the records immediately for inspection by a Provincial Officer upon his or her request. The Permit Holder, unless otherwise required by the Director, shall submit, on or before March 31st in every year, the records required by this condition to the ministry's Water Taking Reporting System.
- 4.6 The Permit Holder shall submit to the Director, an annual monitoring report which presents and interprets the monitoring data to be collected under the Terms and Conditions of this Permit. This report shall be prepared, signed and stamped by a licenced professional geoscientist or a licensed professional engineer specializing in hydrogeology who shall take responsibility for its accuracy. The report shall be submitted to the Director by April 30 of each calendar year or as supporting documentation to any application for renewal of this Permit, and include monitoring data for the 12 month period ending December 31 of the previous year.
- 4.7 In addition to the requirement of Condition 4.6, the Permit Holder shall provide a letter report to the Director and Town of Erin which includes pumped volumes and water level information within 30 days of the end of each month where the water taking is in accordance with Condition 3.3.
- 4.8 The Permit Holder shall include as part of the annual monitoring report required under Condition 4.6, the following information:

- (i) Location and name of the facilities to which water is delivered in bulk containers greater than 20L from this source.
- (ii) Whether or not the bulk water transported is containerized at the receiving location.
- (iii) The size of the container(s) into which the water is transferred.
- (iv) Total volume of the water transported in bulk in each calendar year to

each

remote facility.

4.9 The Permit Holder shall investigate any complaints received from the public or agency with regard to this water taking in accordance with the interference complaints resolution protocol and notify the District Manager, District Office within two (2) working days of receiving the complaint. Details of any complaints and its resolution shall be outlined to the Director in the annual monitoring report required under Condition 4.6.

5. Impacts of the Water Taking

5.1 Notification

The Permit Holder shall immediately notify the local District Office of any complaint arising from the taking of water authorized under this Permit and shall report any action which has been taken or is proposed with regard to such complaint. The Permit Holder shall immediately notify the local District Office if the taking of water is observed to have any significant impact on the surrounding waters. After hours, calls shall be directed to the Ministry's Spills Action Centre at 1-800-268-6060.

5.2 For Groundwater Takings

If the taking of water is observed to cause any negative impact to other water supplies obtained from any adequate sources that were in use prior to initial issuance of a Permit for this water taking, the Permit Holder shall take such action necessary to make available to those affected, a supply of water equivalent in quantity and quality to their normal takings, or shall compensate such persons for their reasonable costs of so doing, or shall reduce the rate and amount of taking to prevent or alleviate the observed negative impact. Pending permanent restoration of the affected supplies, the Permit Holder shall provide, to those affected, temporary water supplies adequate to meet their normal requirements, or shall compensate such persons for their reasonable costs of doing so.

If permanent interference is caused by the water taking, the Permit Holder shall restore the water supplies of those permanently affected.

6. Director May Amend Permit

The Director may amend this Permit by letter requiring the Permit Holder to suspend or reduce the taking to an amount or threshold specified by the Director in the letter. The suspension or reduction in taking shall be effective immediately and may be revoked at any time upon notification by the Director. This condition does not affect your right to appeal the suspension or reduction in taking to the Environmental Review Tribunal under the *Ontario Water Resources Act*, Section 100 (4).

The reasons for the imposition of these terms and conditions are as follows:

1. Condition 1 is included to ensure that the conditions in this Permit are complied with and can be enforced.
2. Condition 2 is included to clarify the legal interpretation of aspects of this Permit.
3. Conditions 3 through 6 are included to protect the quality of the natural environment so as to safeguard the ecosystem and human health and foster efficient use and conservation of waters. These conditions allow for the beneficial use of waters while ensuring the fair sharing, conservation and sustainable use of the waters of Ontario. The conditions also specify the water takings that are authorized by this Permit and the scope of this Permit.

*In accordance with Section 100 of the Ontario Water Resources Act, R.S.O. 1990, you may by written notice served upon me, the Environmental Review Tribunal and the Environmental Commissioner, **Environmental Bill of Rights**, R.S.O. 1993, Chapter 28, within 15 days after receipt of this Notice, require a hearing by the Tribunal. The Environmental Commissioner will place notice of your appeal on the Environmental Registry. Section 101 of the Ontario Water Resources Act, as amended provides that the Notice requiring a hearing shall state:*

1. The portions of the Permit or each term or condition in the Permit in respect of which the hearing is required, and;
2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

In addition to these legal requirements, the Notice should also include:

3. The name of the appellant;
4. The address of the appellant;
5. The Permit to Take Water number;
6. The date of the Permit to Take Water;
7. The name of the Director;
8. The municipality within which the works are located;

This notice must be served upon:

*The Secretary
Environmental Review Tribunal
655 Bay Street, 15th Floor
Toronto ON
M5G 1E5
Fax: (416) 314-4506
Email:
ERTTribunalsecretary@ontario.ca*

AND

*The Environmental Commissioner
1075 Bay Street
6th Floor, Suite 605
Toronto, Ontario M5S 2W5*

AND

*The Director, Section 34
Ministry of the Environment
12th Floor
119 King St W
Hamilton ON L8P 4Y7
Fax: (905)521-7820*

Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal:

by telephone at (416) 314-4600

by fax at (416) 314-4506

by e-mail at www.ert.gov.on.ca

*This instrument is subject to Section 38 of the **Environmental Bill of Rights** that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek to appeal for 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry, you can determine when the leave to appeal period ends.*

This Permit cancels and replaces Permit Number 6480-74BKR4, issued on 2007/08/24.

Dated at Hamilton this 28th day of September, 2012.



Carl Slater
Director, Section 34
Ontario Water Resources Act , R.S.O. 1990

Schedule A

This Schedule "A" forms part of Permit To Take Water 3716-8UZMCU, dated September 28, 2012.

Ministry of the Environment
West Central Region

119 King Street West
12th Floor
Hamilton, Ontario L8P 4Y7
Tel.: 905 521-7640
Fax: 905 521-7820

Ministère de l'Environnement
Direction régionale du Centre-Ouest

119 rue King ouest
12e étage
Hamilton (Ontario) L8P 4Y7
Tél. : 905 521-7640
Télééc. : 905 521-7820



April 28, 2014

Ms. Andreeanne Simard
Natural Resource Manager
Nestlé Waters Canada
101 Brock Road South
Guelph, Ontario.
N1H 6H9

Dear Ms. Simard:

Re: Clarification of reporting requirements
Condition 4.7, Permit to Take Water 3716-8UZMCU

This is to clarify ministry expectations with respect the reporting requirements of Condition 4.7 of Permit to Take Water 3716-8UZMCU.

Condition 4.7 states:

"In addition to the requirement of Condition 4.6, the Permit Holder shall provide a letter report to the Director and Town of Erin which includes pumped volumes and water level information within 30 days of the end of each month where the water taking is in accordance with Condition 3.3."

For greater certainty the Letter Report is expected to include the following:

1. Pumped volumes are the total daily volume for each day in the month from the production well TW1-88.
2. Water Level information is the level data for the following locations:
 - a. P01A/B-07 pond
 - b. P12A/B-07 Roman Lake
 - c. P13A/B-07 Erin Branch of the Credit
 - d. P10A/B-05
3. No interpretation of the data is expected for the monthly report.
4. Data interpretation is expected in the annual report required by Condition 4.6.

I trust that you find this satisfactory. If you require further information or clarification, please contact Ms. Belinda Koblik at (905)521-7615 or at Belinda.Koblik@ontario.ca.

Yours truly,

Carl Slater
Technical Support Manager, West Central Region
Director, Section 34, Ontario Water Resources Act.

C: Ms. B. Koblik/Mr. A. Quyum

Ministry of the Environment
and Climate Change
West Central Region

119 King Street West
12th Floor
Hamilton, Ontario L8P 4Y7
Tel.: 905 521-7640
Fax: 905 521-7820

Ministère de l'Environnement
et de l'Action en matière de changement climatique
Direction régionale du Centre-Ouest

119 rue King Ouest
12e étage
Hamilton (Ontario) L8P 4Y7
Tél. : 905 521-7640
Télec. : 905 521-7820



February 5, 2015

Nestle Canada Inc.
101 Brock Road S.
Puslinch, Ontario
N1H 6H9

Attention: Ms. Andreeanne Simard

Dear Ms. Simard:

**RE: Amendments to monitoring program and well sanitization conditions
Permit to Take Water 3716-8UZMCU**

NOTICE

Pursuant to s. 100, Ontario Water Resources Act, R.S.O. 1990, c. O.40 as amended, I am issuing notice that, as Director of Section 34 of the Ontario Water Resources Act, I am exercising my discretion to amend Permit to Take Water 3716-8UZMCU condition 3.6 and part of condition 4.1. All other terms and conditions of Permit to Take Water 3716-8UZMCU shall continue in force.

An inaccuracy in the monitoring program listed in condition 4.1(ii) of a Notice issued February 25, 2014 was brought to the attention of the ministry in an email from Ms. Andreeanne Simard, Natural Resources Manager dated May 29, 2014. In an email dated November 27, 2014, Ms. Simard, requested the sanitation Notice issued on January 20, 2014 be applicable for all years remaining on the permit.

This Notice supersedes the Notices issued on January 20, 2014 and February 25, 2014.

Condition 3.6 is hereby revoked and replaced as follows:

3.6 Notwithstanding Table A, the maximum pumping of water extracted from Source TW1-88 may be increased to 1040 litres per minute (275 U.S. gallons per minute) annually, or as needed, for the sole purpose of sanitization of the well. The maximum amount of water taken shall not exceed 1,113,000 litres/day.

Condition 4.1 is hereby revoked and replaced as follows:

4.1 The Permit Holder shall establish the following monitoring program for the duration of the Permit:

a. Bedrock Wells

(i) Continuous monitoring of ground water levels at the following locations:

- TW1-88
- D2A
- D3 (MOE #6710228)
- MW5A
- MW6A
- D36B (MOE Tag#A001807)

(ii) Monthly monitoring of ground water levels at the following locations:

- D19 (MOE #6709207)
- MW11A/B-08
- D24B (MOE #6708146) and D24A (MOE #6711344)
- D26A (MOE #6700678) and D26B
- MW12A/B-08
- D8 (MOE#6708720)
- D15 (MOE#6709532)
- D32 (MOE#6708153)

b. Overburden Wells

(i) Continuous monitoring of ground water levels at the following locations:

- MW3A/B
- D2B
- MW5B
- MW6B
- D26C
- D36A

(ii) Monthly monitoring of ground water levels at the following locations:

- TW1-99 (MOE #6712960)
- D27 (MOE #6712147)
- D7B
- MW2

c. Piezometers

(i) Continuous monitoring of water level and vertical hydraulic gradients at the following locations:

- P01A/B-07
- P03A/B-05
- P06A/B-07
- P10A/B-05
- P11A/B-05
- P12A/B-07
- P13A/B-07

d. Surface Water

(i) Continuous monitoring of surface water levels at the following locations:

- ST03-05
- SW1
- SW3
- SW4
- SW5
- SW7

(ii) Monthly monitoring of flow and development of appropriate stage-discharge curves at the following locations:

- SW1
- SW3
- SW7

This Notice now forms part of the current permit and must be attached to the original Permit to Take Water, if available. If the original is no longer available, this letter must be kept attached to a certified copy of the Permit to Take Water.

Any change in circumstances related to this permit should be reported promptly to a Director.

It is your responsibility to ensure that any person taking water under the authority of this permit is familiar with and complies with the terms and conditions.

*In accordance with Section 100 of the Ontario Water Resources Act, R.S.O. 1990, you may by written notice served upon me, the Environmental Review Tribunal and the Environmental Commissioner, **Environmental Bill of Rights**, R.S.O. 1993, Chapter 28, within 15 days after receipt of this Notice, require a hearing by the Tribunal. The Environmental Commissioner will place notice of your appeal on the Environmental Registry. Section 101 of the Ontario Water Resources Act, as amended provides that the Notice requiring a hearing shall state:*

1. The portions of the Permit or each term or condition in the Permit in respect of which the hearing is required, and;
2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

In addition to these legal requirements, the Notice should also include:

3. The name of the appellant;
4. The address of the appellant;
5. The Permit to Take Water number;
6. The date of the Permit to Take Water;
7. The name of the Director;
8. The municipality within which the works are located;

This notice must be served upon:


<p><i>The Secretary Environmental Review Tribunal 2300 Yonge Street, Suite 1700 Toronto, Ontario M4P 1E4</i></p>	<p><u>AND</u></p>	<p><i>The Director, Section 34 Ministry of the Environment 12th Floor 119 King St W Hamilton ON L8P 4Y7 Fax: (905)521-7820</i></p>
--	-------------------	--

Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal:

by telephone at (416) 314-4600 by fax at (416) 314-4506

by e-mail at www.ert.gov.on.ca

Yours truly,



Dan Dobrin
Director, Section 34, Ontario Water Resources Act
West Central Region

File Storage Number: AP28 ERNE

APPENDIX B

Well Information

STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

(L-1)

PROJECT NAME: HILLSBURGH
 PROJECT NO.: 2603
 CLIENT: IHOR PASHYNSKY
 LOCATION: LOT 24, CONCESSION 7, ERIN TOWNSHIP

HOLE DESIGNATION: TW1-88
 (Page 1 of 2)
 DATE COMPLETED: AUGUST 11, 1988
 DRILLING METHOD: WET/AIR ROTARY
 CRA SUPERVISOR: S. CROSSMAN

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	ELEVATION m AMSL	MONITOR INSTALLATION	SAMPLE		
				NUMBER	STATE	VALUE
	GROUND SURFACE (Approximate)	430.0				
2.5	TOPSOIL—sand, some silt, little gravel, compact rootlets, humus material, brown, moist SM (SAND)—some silt, trace of fine gravel, compact, medium grained, poorly graded, brown, moist	429.5				
5.0						
7.5	GW (GRAVEL)—some sand, little silt, very dense, well graded, fine to coarse grained, grey-brown water bearing	423.9				
10.0						
12.5	SP (SAND)—trace silt, loose, uniform, medium grained, wet GW (GRAVEL)—some sand, little silt, dense, well graded, coarse to fine grained, water bearing	419.3 418.7				
15.0	ML (TILL) SILT—some sand, some gravel, trace clay, stiff, low to non-plastic, light brown, wet CL (TILL) CLAY—some silt, little sand, little gravel, stiff, low plastic, grey-brown, moist	417.8 415.7				
17.5						
20.0	LST (LIMESTONE) BEDROCK—soft, friable, fractured, light grey — becomes sound, less fractured, hard	410.5				
22.5						
25.0	— Fracture (152mm dia); brown water in return air with lumps of brown silty clay, fracture infilled; water becomes light grey immediately after passing fracture					
27.5	— Fracture (20mm dia.), no change in water colour					
30.0						
32.5	— light grey, fracture					

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE
 GRAIN SIZE ANALYSIS ○ WATER FOUND ∇ STATIC WATER LEVEL ▼



Ministry of the Environment

Well Tag No. (Place Sticker and/or Print Below)

AC95193 A095193

Well Record

Regulation 933 Ontario Water Resources Act

Measurements recorded in: Metric Imperial

Page 1 of 1

Well Owner's Information

First Name: Last Name / Organization: NESTLE WATERS CANADA E-mail Address: Well Constructed by Well Owner:
Mailing Address (Street Number/Name): 101 BROCK ROAD Municipality: GUELPH Province: ON Postal Code: N1H6H9 Telephone No. (inc area code):

Well Location

Address of Well Location (Street Number/Name): STATION STREET Township: ERN Lot: 24 Concession: 7
County/District/Municipality: WELLINGTON City/Town/Village: HILLSBURG Province: Ontario Postal Code:
UTM Coordinates Zone: Easting: Nothing Nothing: NAD 83 17 588362 4847825 Municipal Plan and Sublot Number:

Overburden and Bedrock Materials/Absorbent Sealing Record (see instructions on the back of this form)

Table with columns: General Colour, Most Common Material, Other Materials, General Description, Depth (m) From, To. Rows include SAND, SILT GRAVEL, GRAVEL, CLAY TILL, LIMESTONE, etc.

Annular Space table with columns: Depth Set (m) From, To, Type of Sealant Used, Volume Placed (m³).

Method of Construction and Well Use checkboxes including Casing Tool, Rotary, Drilling, etc.


Construction Record - Casing table with columns: Inside Diameter (mm), Depth Hole (m), Material, Wall Thickness (mm), Depth (m) From, To, Status of Well.

Construction Record - Screen table with columns: Outside Diameter (mm), Material, Size No., Depth (m) From, To.

Water Data and Hole Diameter tables with columns for depth, kind of water, freshness, and diameter.

Well Contractor and Well Technician Information: Business Name of Well Contractor: Durl Hopper Ltd. Business Address: RR#7, 2315... Business E-mail Address: hopper@cyg.net

Results of Well Yield Testing table with columns: After test of well yield, Water was, Time, Water Level (m), Recovery, etc.



Comments, Well owner's information package collected, Date Work Completed: 11/22/2010, Ministry Use Only Audit No: 2115126



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Standard of Identity Investigation

HOLE DESIGNATION: MW05B-05

PROJECT NUMBER: 013764-75

DATE COMPLETED: March 23, 2005

CLIENT: Nestle Waters Canada

DRILLING METHOD: Air Rotary

LOCATION: Town of Erin, Ontario

FIELD PERSONNEL: K. Maurice

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Observation Well	SAMPLE				
				NUMBER	INTERVAL	REC (%)	'N' VALUE	
16 17 18 19 20 21 22 23 24 25 26 27 28 29			Seal: 0.15 to 6.10m BGS Material: Cement Material: Native					

OVERBURDEN LOG 13764-75-KM24MAR05.GPJ CRA_CORP_GDT 4/7/08

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters Canada
 PROJECT NUMBER: 013764-75
 CLIENT: Nestle Waters Canada
 LOCATION: Town of Erin, Ontario

HOLE DESIGNATION: MW6A-05
 DATE COMPLETED: March 8, 2005
 DRILLING METHOD: 4 1/4" HSA
 FIELD PERSONNEL: M. Acre

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE				
				NUMBER	INTERVAL	REC (%)	'N' VALUE	
0.5	TOPSOIL - sand, medium grained, poorly graded, dark brown, damp, roots and rootlets		Concrete	1	X	100	9	
1.0	SM - Silty SAND, trace clay, fine grained, brown, moist	0.91	203 mm Ø Borehole	2	X	75	3	
1.5	SM - SAND and GRAVEL, with silt, fine to coarse grained, well graded, brown, damp	1.52		3	X	50	20	
2.5	- 51mm SW - SAND and GRAVEL, coarse grained, well graded, saturated at 2.29m BGS ML - SILT with sand, with gravel, low plasticity, brown, moist	2.31		4	X	50	22	
3.5	- decrease in sand content, fine to coarse subrounded gravel, trace angular bedrock fragments, moist at 3.05m BGS			5	X	33	>50	
4.0	SW - SAND and GRAVEL, trace silt, fine to coarse grained, well graded, brown, saturated, trace bedrock fragments	3.81		6	X	33	16	
4.5	ML - SILT, with subrounded gravel, trace sand, trace clay, stiff, low plasticity, grey, moist,	4.57		7	X	25	38	
5.5	- with clay, trace angular bedrock fragments at 5.33m BGS			8	X	25	43	
6.0	- 51mm SW - SAND trace gravel, medium grained, brown, saturated at 6.10m BGS - angular bedrock fragments at 6.35m BGS			9	X	50	27	
7.0	SW - SAND and GRAVEL, fine to medium grained, well graded, brown, saturated	6.86		10	X	50	14	
7.5				11	X	100	35	

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE

OVERBURDEN LOG 13764-75.GPJ CRA_CORP.GDT 4/7/08



STRATIGRAPHIC AND INSTRUMENTATION LOG (BEDROCK)

PROJECT NAME: Nestle Waters Canada
 PROJECT NUMBER: 013764-75
 CLIENT: Nestle Waters Canada
 LOCATION: Town of Erin, Ontario

HOLE DESIGNATION: MW6A-05
 DATE COMPLETED: March 8, 2005
 DRILLING METHOD: 4 1/4" HSA
 FIELD PERSONNEL: M. Acre

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	RUN NUMBER	CORE RECOVERY %	RQD %
20.5	- BEDROCK - Auger Refusal at 20.57m BGS	20.57	Native Cave			
21.0	LIMESTONE - grey/brown, fine grained, smooth, moderately weathered, occasional vugs, occasional strolites, occasional fossils			1	40	13
21.5	- horizontal fracture, very close, rough, slightly weathered, oxidized staining, trace infilling at 20.67m BGS					
22.0	- horizontal fracture, very close, rough, slightly weathered, oxidized staining, trace infilling at 20.73m BGS		Bentonite Holeplug	2	60	17
22.5	- horizontal mechanical fracture at 20.88m BGS					
23.0	- 1.5m highly fractured Not-Intact interval, core barrel dropping through numerous fracture voids, clay infilling, oxidized staining at 21.34m BGS					
23.5	- horizontal fracture, very close, slightly weathered, rough, trace oxidation, trace mineral infilling at 23.01m BGS			3	100	72
24.0	- 45cm vertical fracture, very close, smooth, trace oxidation, trace mineral infilling at 23.16m BGS					
24.5	- horizontal fracture, very close, smooth, trace mineral infilling at 23.41m BGS		Sand Pack			
25.0	- horizontal fracture, very close, smooth, trace black mineral infilling at 23.77m BGS		50.8 mm Ø PVC Screen	4	67	82
25.5	- horizontal fracture, very close, smooth, trace mineral infilling at 23.80m BGS		76.2 mm Ø Corehole			
26.0	- horizontal mechanical fracture at 23.98m BGS					
26.5	- horizontal fracture, close, smooth at 24.18m BGS					
27.0	- horizontal mechanical fracture at 24.54m BGS		Fractured Rock Cave	5	97	32
27.5	- horizontal fracture, close, smooth, oxidization, mineral infilling at 24.64m BGS	27.43				
	- 10cm vertical mechanical fracture at 24.64m BGS					
	- horizontal fracture, close, smooth, trace brown clay infilling at 24.92m BGS					
	- horizontal fracture, close, smooth to rough at 25.22m BGS					
	- horizontal fracture, very close smooth, oxidized at 25.37m BGS					
	- horizontal fracture, close, smooth, trace clay infilling at 25.50m BGS					
	- horizontal fracture, close, smooth, trace clay infilling at 25.63m BGS					
	- horizontal fracture, close, smooth, trace clay infilling at 25.76m BGS					

BEDROCK LOG 13764-75.GPJ CRA CORP.GDT 4/17/08

WELL DETAILS
 Screened interval:
 23.47 to 26.52m BGS

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE



STRATIGRAPHIC AND INSTRUMENTATION LOG (BEDROCK)

PROJECT NAME: Nestle Waters Canada
 PROJECT NUMBER: 013764-75
 CLIENT: Nestle Waters Canada
 LOCATION: Town of Erin, Ontario

HOLE DESIGNATION: MW6A-05
 DATE COMPLETED: March 8, 2005
 DRILLING METHOD: 4 1/4" HSA
 FIELD PERSONNEL: M. Acre

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	RUN NUMBER	CORE RECOVERY %	RQD %
28.5 29.0 29.5 30.0 30.5 31.0 31.5 32.0 32.5 33.0 33.5 34.0 34.5 35.0 35.5	<ul style="list-style-type: none"> - horizontal fracture, close, smooth, trace clay infilling at 25.86m BGS - horizontal mechanical fracture at 25.98m BGS - 23cm vertical fracture, very close, smooth at 25.98m BGS - 31cm Not-Intact interval at 26.21m BGS - 45° mechanical fracture at 26.57m BGS - horizontal fracture, close, smooth at 26.67m BGS - horizontal fracture, slightly rough, trace oxidation at 26.77m BGS - 33cm vertical fracture, very close, smooth, trace mineral infilling at 26.77m BGS - horizontal fracture, close, smooth, trace oxidation at 26.90m BGS - horizontal fracture, very close, smooth, trace oxidation, trace mineral infilling at 27.00m BGS - horizontal fracture, very close, smooth, oxidized at 27.20m BGS - horizontal fracture, very close, smooth, mineral infilling at 27.36m BGS <p>END OF BOREHOLE @ 27.43m BGS</p>		Length: 3.05m Diameter: 51mm Slot Size: 10 Material: Schedule 40 PVC Seal: 21.03 to 22.56m BGS Material: Bentonite Sand Pack: 22.56 to 26.52m BGS Material: #Silica Sand			

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE

BEDROCK LOG 13764-75.GPJ CRA_CORP.GDT 4/17/08



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters Canada
 PROJECT NUMBER: 013764-75
 CLIENT: Nestle Waters Canada
 LOCATION: Town of Erin, Ontario

HOLE DESIGNATION: MW6B-05
 DATE COMPLETED: March 9, 2005
 DRILLING METHOD: 4 1/4" HSA
 FIELD PERSONNEL: M. Acre

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE				
				NUMBER	INTERVAL	REC (%)	'N' VALUE	
0.5 1.0 1.5 2.0 2.5 3.0 3.5 4.0 4.5 5.0 5.5 6.0 6.5 7.0 7.5	Refer to MW6A-05 for stratigraphic details							


NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters Canada
 PROJECT NUMBER: 013764-75
 CLIENT: Nestle Waters Canada
 LOCATION: Town of Erin, Ontario

HOLE DESIGNATION: MW6B-05
 DATE COMPLETED: March 9, 2005
 DRILLING METHOD: 4 1/4" HSA
 FIELD PERSONNEL: M. Acre

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE				
				NUMBER	INTERVAL	REC (%)	'N' VALUE	
<div style="display: flex; flex-direction: column; align-items: center;"> <div style="margin-bottom: 5px;">8.5</div> <div style="margin-bottom: 5px;">9.0</div> <div style="margin-bottom: 5px;">9.5</div> <div style="margin-bottom: 5px;">10.0</div> <div style="margin-bottom: 5px;">10.5</div> <div style="margin-bottom: 5px;">11.0</div> <div style="margin-bottom: 5px;">11.5</div> <div style="margin-bottom: 5px;">12.0</div> <div style="margin-bottom: 5px;">12.5</div> <div style="margin-bottom: 5px;">13.0</div> <div style="margin-bottom: 5px;">13.5</div> <div style="margin-bottom: 5px;">14.0</div> <div style="margin-bottom: 5px;">14.5</div> <div style="margin-bottom: 5px;">15.0</div> <div style="margin-bottom: 5px;">15.5</div> </div>	<p style="text-align: center;">END OF BOREHOLE @ 10.67m BGS</p>	10.67	 <p style="margin-left: 20px;">Native Cave/Heaving Sand</p> <p style="margin-left: 20px;">50.8 mm Ø PVC Screen</p> <p style="margin-left: 20px;">Native Cave/Heaving Sand</p>					

WELL DETAILS
 Screened interval:
 8.53 to 10.06m BGS
 Length: 1.52m
 Diameter: 51mm
 Slot Size: 10
 Material: Schedule 40 PVC
 Seal:
 0.15 to 7.32m BGS
 Material: Bentonite
 Sand Pack:
 7.32 to 10.06m BGS
 Material: Native Cave/Heaving
 Sand

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters
 PROJECT NUMBER: 13764-25
 CLIENT: Nestle Waters Canada
 LOCATION: Station St, Hillsburgh, ON

HOLE DESIGNATION: MW11A-08
 DATE COMPLETED: January 22, 2008
 DRILLING METHOD: 4 1/4 ID HSA / HQ Wet Core
 FIELD PERSONNEL: N.Hinsperger

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE				
				NUMBER	INTERVAL	REC (%)	'N' VALUE	
7.5	GW GRAVEL AND SM SAND - medium to coarse grained, well graded, brown to grey, moist - moist to wet at 7.92m BGS	7.62		6	X	40	27	
8.0				7	X	0	50	
8.5					8	X	70	50
9.0	SM SAND - trace silt, little gravel, medium grained, poorly graded, brown, saturated - with gravel, wet at 12.19m BGS	10.97		9	X	40	90	
9.5								
10.0								
10.5	GW GRAVEL - with sand, trace silt, medium to coarse grained, well graded, grey and brown,	13.72			X			
11.0								
11.5								
12.0								
12.5								
13.0								
13.5								

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE

OVERBURDEN LOG 13764-25.GPJ CRA CORP.GDT 4/7/08



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters
 PROJECT NUMBER: 13764-25
 CLIENT: Nestle Waters Canada
 LOCATION: Station St, Hillsburgh, ON

HOLE DESIGNATION: MW11A-08
 DATE COMPLETED: January 22, 2008
 DRILLING METHOD: 4 1/4 ID HSA / HQ Wet Core
 FIELD PERSONNEL: N.Hinsperger

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE			
				NUMBER	INTERVAL	REC (%)	'N' VALUE
	moist			10	X	10	50
14.5			50.8mm Ø PVC Riser				
15.0	ML SILT (TILL) - with clay, trace gravel, trace sand, low plasticity, grey, moist	14.94	Cement Bentonite Grout	11	X	30	50
15.5							
16.0							
16.5	- little sand at 16.76m BGS						
17.0				12	X	5	50
17.5			203mm Ø Borehole				
18.0							
18.5				13	X	0	50
19.0			Cement Bentonite Grout				
19.5							
20.0	END OF OVERBURDEN HOLE @ 19.91m BGS						
20.5							

OVERBURDEN LOG 13764-25.GPJ CRA_CORP.GDT 4/7/08

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE



STRATIGRAPHIC AND INSTRUMENTATION LOG (BEDROCK)

PROJECT NAME: Nestle Waters
 PROJECT NUMBER: 13764-25
 CLIENT: Nestle Waters Canada
 LOCATION: Station St, Hillsburgh, ON

HOLE DESIGNATION: MW11A-08
 DATE COMPLETED: January 22, 2008
 DRILLING METHOD: 4 1/4 ID HSA / HQ Wet Core
 FIELD PERSONNEL: N.Hinsperger

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	RUN NUMBER	CORE RECOVERY %	RQD %
34.0 34.5 35.0 35.5 36.0 36.5 37.0 37.5 38.0 38.5 39.0 39.5 40.0	<div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <ul style="list-style-type: none"> - horizontal fracture at 45 degrees, white mineralization at 30.53m BGS - horizontal fractures at 30.58m, 30.59m, 30.68m, and at 30.89m BGS - large vug at 31.11m BGS - horizontal fractures at 31.17m and at 31.24m BGS </div> END OF BOREHOLE @ 31.85m BGS					


NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters
 PROJECT NUMBER: 13764-25
 CLIENT: Nestle Waters Canada
 LOCATION: Station St, Hillsburgh, ON

HOLE DESIGNATION: MW11B-08
 DATE COMPLETED: January 24, 2008
 DRILLING METHOD: 4 1/4 ID HSA
 FIELD PERSONNEL: N.Hinsperger

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE				
				NUMBER	INTERVAL	REC (%)	'N' VALUE	
0.5 1.0 1.5 2.0 2.5 3.0 3.5 4.0 4.5 5.0 5.5 6.0 6.5	See Stratigraphy from MW11A-08 advanced on January 22, 2008		 <p style="margin-left: 100px;">203mm Ø Borehole</p> <p style="margin-left: 100px;">Cement Bentonite Grout</p> <p style="margin-left: 100px;">50.8mm Ø PVC Riser</p>					

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE

OVERBURDEN LOG 13764-25.GPJ CRA CORP GDT 4/7/08



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters
 PROJECT NUMBER: 13764-25
 CLIENT: Nestle Waters Canada
 LOCATION: Station St, Hillsburgh, ON

HOLE DESIGNATION: MW11B-08
 DATE COMPLETED: January 24, 2008
 DRILLING METHOD: 4 1/4 ID HSA
 FIELD PERSONNEL: N.Hinsperger

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE				
				NUMBER	INTERVAL	REC (%)	'N' VALUE	
7.5 8.0 8.5 9.0 9.5 10.0 10.5 11.0 11.5 12.0 12.5 13.0 13.5	END OF BOREHOLE @ 13.72m BGS	13.72	<p style="font-size: small;">WELL DETAILS Screened interval:</p>					

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE


OVERBURDEN LOG 13764-25.GPJ CRA_CORP.GDT 4/7/08



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters
 PROJECT NUMBER: 13764-25
 CLIENT: Nestle Waters Canada
 LOCATION: Station St, Hillsburgh, ON

HOLE DESIGNATION: MW12A-08
 DATE COMPLETED: February 5, 2008
 DRILLING METHOD: 4 1/4 ID HSA / HQ Wet Core
 FIELD PERSONNEL: N.Hinsperger

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE			
				NUMBER	INTERVAL	REC (%)	'N' VALUE
0.5 1.0 1.5 2.0	SM SAND (TOPSOIL) - trace silt, trace clay, fine to medium grained, poorly graded, dark brown, little oxidation, some rootlets	2.13	 <p>203mm Ø Borehole</p> <p>50.8mm Ø PVC Riser</p> <p>Cement Bentonite Grout</p>	1	X	0	50
2.5 3.0 3.5 4.0	SM SAND - some clay, trace silt, medium grained, poorly graded, dark brown, moist to wet, some rootlets			2	X	25	26
4.5 5.0 5.5	- trace gravel, little red staining, little black staining at 4.57m BGS			3	X	5	50
6.0 6.5	- brown, moist at 6.10m BGS			4	X	30	50
6.5				5	X	5	50

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE

OVERBURDEN LOG 13764-25.GPJ CRA CORP GDT 4/7/08



STRATIGRAPHIC AND INSTRUMENTATION LOG (BEDROCK)

PROJECT NAME: Nestle Waters
 PROJECT NUMBER: 13764-25
 CLIENT: Nestle Waters Canada
 LOCATION: Station St, Hillsburgh, ON

HOLE DESIGNATION: MW12A-08
 DATE COMPLETED: February 5, 2008
 DRILLING METHOD: 4 1/4 ID HSA / HQ Wet Core
 FIELD PERSONNEL: N.Hinsperger

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	RUN NUMBER	CORE RECOVERY %	RQD %
38.0 38.5 39.0 39.5 40.0 40.5 41.0 41.5 42.0 42.5 43.0 43.5 44.0	<div style="border: 1px solid black; padding: 2px; width: fit-content; margin-bottom: 5px;">35.64m BGS</div> END OF BOREHOLE @ 36.14m BGS		31.24 to 36.14m BGS Material: No. 1 Silica Sand			

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE

BEDROCK LOG 13764-25.GPJ CRA CORP.GDT 4/7/08



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters
 PROJECT NUMBER: 13764-25
 CLIENT: Nestle Waters Canada
 LOCATION: Station St, Hillsburgh, ON

HOLE DESIGNATION: MW12B-08
 DATE COMPLETED: February 6, 2008
 DRILLING METHOD: 4 1/4 ID HSA
 FIELD PERSONNEL: N.Hinsperger

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE				
				NUMBER	INTERVAL	REC (%)	'N' VALUE	
0.5 1.0 1.5 2.0 2.5 3.0 3.5 4.0 4.5 5.0 5.5 6.0 6.5	See Stratigraphy from MW12A-08 advanced on January 31, 2008		<p style="margin-left: 100px;">Cement Bentonite Grout</p> <p style="margin-left: 100px;">50.8mm Ø PVC Riser</p> <p style="margin-left: 100px;">Bentonite Gravel</p> <p style="margin-left: 100px;">No. 1 Silica Sand</p>					

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE

OVERBURDEN LOG 13764-25.GPJ CRA_CORP.GDT 4/7/08



STRATIGRAPHIC AND INSTRUMENTATION LOG (OVERBURDEN)

PROJECT NAME: Nestle Waters
 PROJECT NUMBER: 13764-25
 CLIENT: Nestle Waters Canada
 LOCATION: Station St, Hillsburgh, ON

HOLE DESIGNATION: MW12B-08
 DATE COMPLETED: February 6, 2008
 DRILLING METHOD: 4 1/4 ID HSA
 FIELD PERSONNEL: N.Hinsperger

DEPTH m BGS	STRATIGRAPHIC DESCRIPTION & REMARKS	DEPTH m BGS	Monitoring Well	SAMPLE				
				NUMBER	INTERVAL	REC (%)	'N' VALUE	
<div style="display: flex; flex-direction: column; align-items: center;"> <div style="margin-bottom: 5px;">7.5</div> <div style="margin-bottom: 5px;">8.0</div> <div style="margin-bottom: 5px;">8.5</div> <div style="margin-bottom: 5px;">9.0</div> <div style="margin-bottom: 5px;">9.5</div> <div style="margin-bottom: 5px;">10.0</div> <div style="margin-bottom: 5px;">10.5</div> <div style="margin-bottom: 5px;">11.0</div> <div style="margin-bottom: 5px;">11.5</div> <div style="margin-bottom: 5px;">12.0</div> <div style="margin-bottom: 5px;">12.5</div> <div style="margin-bottom: 5px;">13.0</div> <div style="margin-bottom: 5px;">13.5</div> </div>	<p style="text-align: center;">END OF BOREHOLE @ 9.75m BGS</p>	9.75	<p style="margin-left: 20px;">50.8mm Ø PVC Screen</p> <p style="margin-left: 20px;">203mm Ø Borehole</p>					
			<p>WELL DETAILS</p> <p>Screened interval: 6.71 to 9.75m BGS</p> <p>Length: 3.05m</p> <p>Diameter: 51mm</p> <p>Slot Size: 10</p> <p>Material: Schedule 40 PVC</p> <p>Seal: 0.00 to 5.49m BGS</p> <p>Material: Cement Bentonite Grout</p> <p>Sand Pack: 6.10 to 9.75m BGS</p> <p>Material: No. 1 Silica Sand</p>					

NOTES: MEASURING POINT ELEVATIONS MAY CHANGE; REFER TO CURRENT ELEVATION TABLE

PROJECT: 13-1152-0250
 LOCATION: N 4848306; E 568928 (approximate)

RECORD OF BOREHOLE: MW01-18

BORING DATE: August 12 to 13, 2018

SHEET 1 OF 3
 DATUM: Ground
 STICKUP: A 0.44 m
 B 0.54 m

DEPTH SCALE METRES	BORING METHOD	SOIL PROFILE		SAMPLES		DYNAMIC PENETRATION RESISTANCE, BLOWS/0.3m				HYDRAULIC CONDUCTIVITY, k, cm/s				ADDITIONAL LAB. TESTING	PIEZOMETER OR STANDPIPE INSTALLATION		
		DESCRIPTION	STRATA PLOT	ELEV. DEPTH (m)	NUMBER	TYPE	BLOWS/0.3m	SHEAR STRENGTH				WATER CONTENT PERCENT					
								Cu, kPa		nat V. rem V.		+ Q - U				Wp	
0		GROUND SURFACE															
0		FILL - CLAYEY SAND		0.00													
2		SILTY to SANDY GRAVEL		1.83													
14		SILTY SAND with GRAVEL; (TILL)		14.02													
20		CONTINUED NEXT PAGE															

Aug. 17, 2018 (A)

Aug. 17, 2018 (B)

GTA-BHS 001 T:\PROJECTS\2013\13-1152-0250 (NWC, SOUTH ONTARIO)\LOG\13-1152-0250.GPJ GAL-MIS.GDT 02/20/19 KS

DEPTH SCALE
1 : 100



LOGGED: PGM
CHECKED: GRP

RECORD OF BOREHOLE: MW01-18

BORING DATE: August 12 to 13, 2018

DEPTH SCALE METRES	BORING METHOD	SOIL PROFILE		SAMPLES		DYNAMIC PENETRATION RESISTANCE, BLOWS/0.3m				HYDRAULIC CONDUCTIVITY, k, cm/s				ADDITIONAL LAB. TESTING	PIEZOMETER OR STANDPIPE INSTALLATION		
		DESCRIPTION	STRATA PLOT	ELEV. DEPTH (m)	NUMBER	TYPE	BLOWS/0.3m	SHEAR STRENGTH				WATER CONTENT PERCENT					
								Cu, kPa		nat V. rem V.		+				-	
20	Mud Rotary Tricone	-- CONTINUED FROM PREVIOUS PAGE -- SILTY SAND with GRAVEL; (TILL)															
22		DOLOSTONE; brown and grey, interbedded		20.73													
24		Fractures observed from 24.4 to 25.2 m															
26	Air Rotary Ballistic Carbide Head	DOLOSTONE; medium to dark brown		26.21													
28														Screen B			
30		Fractures observed at 34.7, 37.2 to 37.8 m															
32																	
34																	
36																	
38														Screen A			
40																	

CONTINUED NEXT PAGE

GTA-BHS 001 T:\PROJECTS\2013\13-1152-0250 (NWC, SOUTH ONTARIO)\LOG\13-1152-0250.GPJ GAL-MIS.GDT 02/20/19 KS

PROJECT: 13-1152-0250

LOCATION: N 4848306; E 568928 (approximate)

RECORD OF BOREHOLE: MW01-18

BORING DATE: August 12 to 13, 2018


SHEET 3 OF 3

DATUM: Ground

STICKUP: A 0.44 m
B 0.54 m

DEPTH SCALE METRES	BORING METHOD	SOIL PROFILE		SAMPLES		DYNAMIC PENETRATION RESISTANCE, BLOWS/0.3m				HYDRAULIC CONDUCTIVITY, k, cm/s				ADDITIONAL LAB. TESTING	PIEZOMETER OR STANDPIPE INSTALLATION		
		DESCRIPTION	STRATA PLOT	ELEV. DEPTH (m)	NUMBER	TYPE	BLOWS/0.3m	SHEAR STRENGTH				WATER CONTENT PERCENT					
								Cu, kPa		nat V. + rem V. ⊕	Q - U - ⊙	Wp	W			Wi	
40	Air Rotary Ballistic Carbide Head	-- CONTINUED FROM PREVIOUS PAGE --															
		DOLOSTONE; medium to dark brown															
42		Vugs observed at 40.8 m															
44		DOLOSTONE; dark grey to black		42.37													
44		END OF BOREHOLE		44.20													

Notes:
 - 6" diameter steel casing to 22.56 mbgs
 - Screen B 2" diameter schedule 40 PVC 10 slot screen from 23.77 mbgs to 29.87 mbgs
 - Screen A 2" diameter schedule 40 PVC 10 slot screen from 36.88 mbgs to 42.98 mbgs
 - Sand pack from 22.56 mbgs to 30.18 mbgs and from 35.66 mbgs to 43.28 mbgs
 - Bentonite seal to 22.56 mbgs, from 30.18 mbgs to 35.66 mbgs, and from 43.28 mbgs to 44.20 mbgs within the 6" diameter open hole or 6" diameter steel casing
 - Bentonite and cement grout in annular space outside 6" diameter steel casing from 1 mbgs to 22.56 mbgs
 - Cement in annular space outside 6" diameter steel casing to 1 mbgs



GTA-BHS 001 T:\PROJECTS\2013\13-1152-0250 (NWC, SOUTH ONTARIO)\LOG\13-1152-0250.GPJ GAL-MIS.GDT 02/20/19 KS

**TABLE B1
MECP WATER WELL RECORDS
WITHIN 1 km OF TW1-88**

Well ID	Date Completed	Depth (metres)	Well Status	Well Use
6700676	12/12/1958	24.4	Water Supply	Livestock
6700678	10/18/1965	35.1	Water Supply	Livestock
6700679	8/22/1966	28.3	Water Supply	Domestic
6700712	3/21/1966	39.6	Water Supply	Domestic
6703077	4/5/1968	32	Water Supply	Domestic
6703362	3/12/1969	32	Water Supply	Domestic
6703528	8/5/1969	54.9	Water Supply	Domestic
6703896	4/1/1971	50.3	Water Supply	Domestic
6703960	7/17/1971	38.1	Water Supply	Livestock
6704115	12/10/1971	30.5	Water Supply	Domestic
6705153	1/12/1974	50.3	Water Supply	Domestic
6705612	10/10/1974	41.1	Water Supply	Domestic
6706900	4/29/1978	60	Water Supply	Domestic
6708146	11/21/1984	44.8	Water Supply	Domestic
6708346	7/24/1985	35.4	Water Supply	Domestic
6708388	12/14/1985	41.1	Water Supply	Domestic
6708389	5/9/1985	41.1	Water Supply	Domestic
6708720	9/18/1986	42.7	Water Supply	Domestic
6709050	11/30/1987	57	Water Supply	Domestic
6709207	11/28/1987	59.4	Water Supply	Domestic
6709530	9/15/1988	30.5	Water Supply	Domestic
6709532	9/16/1988	23.5	Water Supply	Domestic
6709533	9/14/1988	22.9	Water Supply	Domestic
6709537	5/30/1988	39.6	Water Supply	Domestic
6709548	11/25/1988	39.3	Water Supply	Domestic
6710154	4/18/1989	32	Water Supply	Domestic
6710228	8/17/1989	27.4	Water Supply	Domestic
6710806	7/24/1991	25.6	Water Supply	Domestic
6711344	11/29/1993	45.1	Water Supply	Domestic
6712147	7/26/1996	35.1	Water Supply	Domestic
6713603	11/22/2000	29.6	Water Supply	Domestic
6714186	8/28/2002	29.6	Water Supply	Domestic
6714441	3/21/2003	38.7	Water Supply	Domestic
6714803	12/17/2003	43.3	Water Supply	Domestic
6714872	4/1/2004	48.7	Water Supply	Domestic
6714873	4/13/2004	24.4	Water Supply	Domestic
6715290	3/22/2005	27.4	Observation Wells	Not Used
6715291	3/23/2005	13.7	Observation Wells	Not Used
6715772	6/15/2006	30.5	Water Supply	Domestic
6715802	6/22/2006	0	Abandoned-Other	NULL
6715910	9/6/2006	30.5	Water Supply	Domestic
6716003	10/5/2006	48.5	Water Supply	Domestic

**TABLE B1
MECP WATER WELL RECORDS
WITHIN 1 km OF TW1-88**

Well ID	Date Completed	Depth (metres)	Well Status	Well Use
7043354	3/26/2007	13.7	Water Supply	Commerical
7105350	5/5/2008	0	Abandoned-Other	NULL
7111993	2/21/2008	36	Observation Wells	Not Used
7111994	1/20/2008	32	Observation Wells	Not Used
7118031	9/25/2008	44.8	Water Supply	Domestic
7125694	6/2/2009	25	Water Supply	Domestic
7142658	11/26/2009	15.2	NULL	Not Used
7142659	11/27/2009	14.3	Observation Wells	Not Used
7142660	11/30/2009	13.1	Observation Wells	Not Used
7142661	12/1/2001	11	Observation Wells	Not Used
7142662	12/4/2009	52.1	Observation Wells	Not Used
7156653	11/22/2010	39	Water Supply	Commerical
7170392	9/2/2011	37.2	Water Supply	Domestic
7179274	1/31/2012	0	NULL	NULL
7200165	3/25/2013	0	Abandoned-Quality	NULL
7221467	4/22/2014	6	Abandoned-Other	NULL
7221469	4/22/2014	0	Abandoned-Other	NULL
7221471	4/28/2014	38.5	Abandoned-Other	NULL

**TABLE B2
PRIVATE WELL SURVEY**

Well ID	Notes From First Visit On June 21, 2018	Completed Survey
6714873	Nestle Property, no survey	not applicable
7170392	Gated house - left letter in mailbox	no
6714803	Left letter in door	yes (mailed)
6716003	Gated house - left letter in mailbox	no
7125694	Owner does not want to participate	no

Note: A second visit was not completed since the houses were gated.



June 21, 2018

**RE: NOTICE OF PRIVATE WATER SUPPLY WELL SURVEY
ERIN**

Dear Homeowner,

Nestlé Waters Canada (Nestlé) has retained Golder Associates Ltd. (Golder) to conduct a hydrogeological assessment as part of the Permit To Take Water renewal process for the well located at 9313 Station Street, Erin, Ontario. Nestlé produces bottled water from two sources; one in Aberfoyle and one in Erin. The water takings are governed by Ministry of the Environment and Climate Change (MOECC) Permits to Take Water. As part of the renewal process, a technical study is required to be submitted with the application. The technical study requires a well survey to identify existing water users in the study area. A survey of private wells was completed during previous testing at the site and the objective of this reconnaissance survey is to update previous work by identifying newly constructed wells in the study area. Water levels in some of the private wells are currently monitored as part of Nestlé's monitoring program.

As part of the investigation, Golder Associates Ltd. (on behalf of Nestlé) is conducting a survey of private wells in the area to obtain information on well details and water quality. The attached questionnaire requests basic information about your water well including details of the well construction, observations of water quality and quantity, and any issues or concerns you may have regarding your water supply. Unfortunately we missed you at the time of our door-to-door visits and would still like to offer you the opportunity to contribute. Please find attached to this letter a copy of the questionnaire.

The following options are available to return the completed form to us:

- By Person: Please contact Kurt Stamm of Golder at (647) 280-9463 to arrange a face-to-face meeting;
- By Mail: Please use the self-addressed envelope to mail in the completed form;
- By Phone: Please contact Greg Padusenko of Golder at (519) 620-8182 x6509 or Kurt Stamm at (519) 620-8182 x6524 to complete the questionnaire;
- By E-mail: Please scan your completed form and e-mail it to gpadusenko@golder.com; or
- By Fax: Please fax your completed form to (519) 620-9878, attention Greg Padusenko.

We ask that you return the completed form by July 6, 2018.



If available, please include a copy of your water well record with the questionnaire.

The information will be used as part of an assessment of water well use in the area and will be shared with Nestlé and the MOECC. We thank you for your participation in this exercise. If you have any questions on the questionnaire please feel free to contact Greg Padusenko or Kurt Stamm at the number above.

Should you have any further questions, comments or concerns, please do not hesitate to contact me at your earliest convenience by telephone at (519) 767-6422, Ext. 6422, or via email at andreeanne.simard@waters.nestle.com.

Yours truly,

A handwritten signature in black ink, appearing to read "ASimard". The signature is written in a cursive, flowing style.

Andreeanne Simard, Ph.D.
Natural Resources Manager
Nestlé Waters Canada

Water Well Reconnaissance Survey

Owner of Well:

Name: _____ Telephone (Bus.): _____

Address: _____ Telephone (Home): _____

Person Interviewed: _____ Date: _____

Interviewed By: _____ Time: _____

Occupant of House Served by Well: (if other than owner)

Name: _____ Telephone (Bus.): _____

Address: _____ Telephone (Home): _____

Well Construction Details:

Date Constructed: _____ Use: _____

Contractor: _____ Type (drilled or dug): _____

Diameter: _____ Well Depth: _____

Is well accessible for direct sampling? Or buried? _____

Screen: Yes / No If yes, length: _____m Depth of top of screen: _____m

Well Water Levels: (indicate whether measured from ground level or from top of casing)

Original water level depth: _____m

Subsequent water level measurements (give depths in metres and dates): _____

Pumping Equipment:

Pump type: suction lift / positive submergence / other Age: _____

Depth of intake setting: _____m Pumping rate: _____L/s

Storage tank type: _____ Capacity: _____

Do you have a: Chlorinator: Yes / No Water Softener: Yes / No Water Filter: Yes / No

Water Use: Domestic: Yes / No Number of people using water from well: _____

Pool: Yes / No Lawn watering: Yes / No

Other uses: _____

Private Waste and Water Disposal Type (septic, etc.): _____

Distance to well: _____m

Well is: uphill / downhill / same grade

Previous Problems:

How long have you owned, operated or lived on this property? _____

Have you ever experienced any previous problems with your well? _____

If so, when? _____

What was the cause of the previous problem? Drought: _____ Pump Failure:

Increased Usage: _____ Interference: _____ Contamination:

If problem was contamination, what water quality changes were apparent? (note any differences in taste, odour, colour or clarity) _____

What action was taken to overcome the problem? _____

What were the effects of this problem? _____

Did you ever have your well:	deepened	yes / no
	or cleaned	yes / no
	or a new well constructed	yes / no

If so, why? _____

Outline briefly any previous repairs or changes in pumping equipment and dates:

Location Sketch:



Notes:

APPENDIX C

Transmissivity Analysis




Figure C1
 Summary of TW1-88 performance
 during 1988 and 2005 step and
 constant-rate pumping tests




Figure C2
Estimation of transmissivity at
TW1-88 from the Thiem solution




Figure C3
 Drawdown in the bedrock after 7 days of
 pumping at 270 l/gpm, November 3-10, 2005
 (reproduced from CRA, 2006, Figure 6.7)




Figure C4
 Cooper-Jacob analysis of the TW1-88
 drawdowns during the 1988
 constant-rate pumping test




Figure C5
 Cooper-Jacob distance-drawdown
 analysis at the end of the 2005 7-day
 constant-rate pumping test






Figure C6

Specific capacity inferred from the 1988 and 2005 testing superimposed on the average monthly TW1-88 performance data

APPENDIX D

Groundwater Hydrographs




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT **NESTLE WATERS CANADA**
Town of Erin, Ontario

TITLE **HYDROGRAPH FOR TW1-88**

PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	D1



- TW1-88 Daily Pumpage
- █ Precipitation
- MW12A-08
- D15





DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario

TITLE
**HYDROGRAPHS FOR BACKGROUND
 BEDROCK WELLS**

PROJECT NO. 13-1152-0250 (9000)	REV A	FIGURE D2
------------------------------------	----------	--------------




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario

TITLE
HYDROGRAPH FOR MW5A-05

PROJECT NO. 13-1152-0250 (9000)	REV A	FIGURE D3
------------------------------------	----------	--------------



- TW1-88 Daily Pumpage
- Precipitation
- MW6A-05 Daily Max
- MW6A-05 Daily Min




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT **NESTLE WATERS CANADA**
Town of Erin, Ontario

TITLE **HYDROGRAPH FOR MW6A-05**

PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	D4




- TW1-88 Daily Pumpage
- █ Precipitation
- D3 Daily Max
- D3 Daily Min



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario		
TITLE	HYDROGRAPH FOR D3		
PROJECT NO.	REV	FIGURE	
13-1152-0250 (9000)	A	D5	




— TW1-88 Daily Pumpage
 Precipitation
 — D2A Daily Max
 — D2A Daily Min

NOTE:
 The homeowner at D2A is no longer participating in the monitoring program.



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario		
TITLE	HYDROGRAPH FOR D2A		
PROJECT NO.	13-1152-0250 (9000)	REV	A
		FIGURE	D6



— TW1-88 Daily Pumpage
 ■ Precipitation
 — D36B




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT **NESTLE WATERS CANADA**
 Town of Erin, Ontario

TITLE **HYDROGRAPH FOR D36B**

PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	D7



- TW1-88 Daily Pumpage
- Precipitation
- D19
- D15 (background)

NOTE:
The homeowner at D19 is no longer participating in the monitoring program.




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT **NESTLE WATERS CANADA**
Town of Erin, Ontario

TITLE **HYDROGRAPHS FOR OTHER BEDROCK WELLS**

PROJECT NO. 13-1152-0250 (9000) REV A FIGURE D8



- TW1-88 Daily Pumpage
- █ Precipitation
- D15 (background)
- MW12A-08 (background)
- D8
- MW11A-08

NOTE:
A heat pump is installed in the domestic well at D8.




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT
NESTLE WATERS CANADA
Town of Erin, Ontario

TITLE
HYDROGRAPHS FOR OTHER BEDROCK WELLS

PROJECT NO. 13-1152-0250 (9000) **REV** A **FIGURE** D9



- TW1-88 Daily Pumpage
- █ Precipitation
- D15 (background)
- MW12A-08 (background)
- ▲ D24A
- ▲ D24B

NOTE:
D24B buried in snow from January to March of 2014




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT **NESTLE WATERS CANADA**
Town of Erin, Ontario

TITLE **HYDROGRAPHS FOR OTHER BEDROCK WELLS**

PROJECT NO. 13-1152-0250 (9000) REV A FIGURE D10



- TW1-88 Daily Pumpage
- Precipitation
- D15 (background)
- MW12A-08 (background)
- D26A
- D26B




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario

TITLE
**HYDROGRAPHS FOR OTHER
 BEDROCK WELLS**

PROJECT NO. 13-1152-0250 (9000)	REV A	FIGURE D11
------------------------------------	----------	---------------



— TW1-88 Daily Pumpage
 Precipitation
 D32




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT **NESTLE WATERS CANADA**
Town of Erin, Ontario

TITLE **HYDROGRAPHS FOR OTHER BEDROCK WELLS**

PROJECT NO. 13-1152-0250 (9000)	REV A	FIGURE D12
------------------------------------	----------	---------------




- TW1-88 Daily Pumpage
- █ Precipitation
- D2B
- MW3A-00
- MW3B-00
- MW05B-05
- MW06B-05

NOTE:
The homeowner at D2B is no longer participating in the monitoring program.



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario	
TITLE	HYDROGRAPHS FOR OVERBURDEN MONITORING LOCATIONS	
PROJECT NO.	13-1152-0250 (9000)	REV A
		FIGURE D13




- TW1-88 Daily Pumpage
- █ Precipitation
- MW2-00
- MW11B-08
- TW1-99



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario		
TITLE	HYDROGRAPHS FOR OVERBURDEN MONITORING LOCATIONS		
PROJECT NO.	13-1152-0250 (9000)	REV	A
			FIGURE D14



- TW1-88 Daily Pumpage
- █ Precipitation
- D7B
- MW12B-08
- D26C
- D36A




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario		
TITLE	HYDROGRAPHS FOR OVERBURDEN MONITORING LOCATIONS		
PROJECT NO.	13-1152-0250 (9000)	REV	A
		FIGURE	D15

APPENDIX E

**Groundwater Hydrographs
(Average)**




— Volume Pumped (L)
 ■ Precipitation (mm)
 — TW1-88



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario		
TITLE	AVERAGE MONTHLY WATER LEVEL ELEVATIONS TW1-88		
PROJECT NO.	13-1152-0250 (9000)	REV	A
FIGURE			E1



- Volume Pumped (L)
- Precipitation (mm)
- D2A
- D3
- MW5A-05
- MW6A-05




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario

TITLE AVERAGE MONTHLY WATER LEVEL ELEVATIONS
 UPPER BEDROCK
 WELLS WITHIN 500 m of TW1-88

PROJECT NO. 13-1152-0250 (9000)	REV A	FIGURE E2
---	-----------------	---------------------



— Volume Pumped (L)
 ■ Precipitation (mm)
 — D36B




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT **NESTLE WATERS CANADA**
 Town of Erin, Ontario

TITLE **AVERAGE MONTHLY WATER LEVEL ELEVATIONS**
UPPER BEDROCK
WELLS OUTSIDE 500 m of TW1-88

PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	E3



- Volume Pumped (L)
- Precipitation (mm)
- MW3A-00
- MW3B-00
- MW5B-05
- MW6B-05




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario

TITLE AVERAGE MONTHLY WATER LEVEL ELEVATIONS
 OVERBURDEN
 WELLS WITHIN 500 m of TW1-88

PROJECT NO. 13-1152-0250 (9000)	REV A	FIGURE E4
---	-----------------	---------------------



- Volume Pumped (L)
- Precipitation (mm)
- D26C
- D36A




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario	
TITLE	AVERAGE MONTHLY WATER LEVEL ELEVATIONS OVERBURDEN WELLS OUTSIDE 500 m of TW1-88	
PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	E5

APPENDIX F

**Vertical Gradients
(Overburden/Bedrock)**



— TW1-88 Daily Pumpage
 — Vertical Gradient OB/BR

PROJECT **NESTLE WATERS CANADA**
 Town of Erin, Ontario

TITLE **MW5-05 VERTICAL GRADIENT**




DATE DECEMBER 2018
 DESIGN KS
 REVIEW GP
 APPROVED GP

PROJECT NO. 13-1152-0250 (9000)

REV A

FIGURE F1



— TW1-88 Daily Pumpage
 — Vertical Gradient OB/BR

PROJECT

NESTLE WATERS CANADA
Town of Erin, Ontario

TITLE

MW6-05 VERTICAL GRADIENT

PROJECT NO.

13-1152-0250 (9000)

REV

A

FIGURE

F2




DATE DECEMBER 2018

DESIGN KS

REVIEW GP

APPROVED GP



— TW1-88 Daily Pumpage
 ● Vertical Gradient OB/BR

PROJECT **NESTLE WATERS CANADA**
 Town of Erin, Ontario

TITLE **MW11-08 VERTICAL GRADIENT**




DATE DECEMBER 2018
 DESIGN KS
 REVIEW GP
 APPROVED GP

PROJECT NO. 13-1152-0250 (9000)

REV A

FIGURE F3



— TW1-88 Daily Pumpage
 ● Vertical Gradient OB/BR

PROJECT

NESTLE WATERS CANADA
 Town of Erin, Ontario

TITLE

MW12-08 VERTICAL GRADIENT

PROJECT NO.

13-1152-0250 (9000)

REV

A

FIGURE

F4



DATE DECEMBER 2018


DESIGN KS

REVIEW GP

APPROVED GP

APPENDIX G

Mini-Piezometer Hydrographs




- TW1-88 Daily Pumpage
- Precipitation
- P03B-05 (Shallow)
- P03A-05 (Deep)
- Vertical Gradient OB/OB



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario		
TITLE	P03-05 NEST HYDROGRAPHS AND VERTICAL GRADIENTS		
PROJECT NO.	13-1152-0250 (9000)	REV	A
		FIGURE	G1





- TW1-88 Daily Pumpage
- Precipitation
- P06B-07 (Shallow)
- P06A-07 (Deep)
- Vertical Gradient OB/OB



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario		
TITLE	P06-07 NEST HYDROGRAPHS AND VERTICAL GRADIENTS		
PROJECT NO.	13-1152-0250 (9000)	REV	A
		FIGURE	G2




- TW1-88 Daily Pumping
- Precipitation
- P01B-07 (Shallow)
- P01A-07 (Deep)
- Vertical Gradient OB/OB



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario	
TITLE	P01-07 NEST HYDROGRAPHS AND VERTICAL GRADIENTS	
PROJECT NO.	13-1152-0250 (9000)	REV A
		FIGURE G3




- TW1-88 Daily Pumpage
- Precipitation
- P11B-05 (Shallow)
- P11A-05 (Deep)
- Vertical Gradient OB/OB



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario		
TITLE	P11-05 NEST HYDROGRAPHS AND VERTICAL GRADIENTS		
PROJECT NO.	13-1152-0250 (9000)	REV	A
		FIGURE	G4




- TW1-88 Daily Pumpage
- Precipitation
- P10B-05 (Shallow)
- P10A-05 (Deep)
- Vertical Gradient OB/OB



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario	
TITLE	P10-05 NEST HYDROGRAPHS AND VERTICAL GRADIENTS	
PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	G5




- TW1-88 Daily Pumpage
- Precipitation
- P12B-07 (Shallow)
- P12A-07 (Deep)
- Vertical Gradient OB/OB



DATE	DECEMBER 2018
DESIGN	JH
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario	
TITLE	P12-07 NEST HYDROGRAPHS AND VERTICAL GRADIENTS	
PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	G6



- TW1-88 Daily Pumpage
- Precipitation
- P13B-07 (Shallow)
- P13A-07 (Deep)
- Vertical Gradient OB/OB




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT	NESTLE WATERS CANADA Town of Erin, Ontario		
TITLE	P13-07 NEST HYDROGRAPHS AND VERTICAL GRADIENTS		
PROJECT NO.	13-1152-0250 (9000)	REV	A
		FIGURE	G7

APPENDIX H

Surface Water Hydrographs



- TW1-88 Daily Pumpage
- █ Precipitation
- SW1-08 (Creek d/s of on-Site Pond)
- SW3-08 (on-Site Pond)




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario

TITLE
**HYDROGRAPHS FOR SURFACE WATER LEVELS
 IN VICINITY OF ON-SITE POND**

PROJECT NO. 13-1152-0250 (9000) REV A FIGURE H1



PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario


TITLE
**HYDROGRAPHS FOR SURFACE WATER LEVELS
 IN ERIN BRANCH OF CREDIT RIVER**

- TW1-88 Daily Pumpage
- █ Precipitation
- SW7-08 (Erin Branch of the Credit River)



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	H2



— TW1-88 Daily Pumpage
 ■ Precipitation
 — SW7A-16




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT **NESTLE WATERS CANADA**
 Town of Erin, Ontario

TITLE **HYDROGRAPHS FOR SURFACE WATER LEVELS
 IN ERIN BRANCH OF CREDIT RIVER (2017 DATA)**

PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	H3



- TW1-88 Daily Pumpage
- █ Precipitation
- SW4-08 (Stream into Roman Lake)
- SW5-08 (Roman Lake)



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP



PROJECT **NESTLE WATERS CANADA**
Town of Erin, Ontario

TITLE **HYDROGRAPHS FOR SURFACE WATER LEVELS
IN VICINITY OF ROMAN LAKE**

PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	H4

APPENDIX I

Surface Water Flow




DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT
NESTLE WATERS CANADA
 Town of Erin, Ontario

TITLE
HYDROGRAPH FOR SW1-08 & SW1-99

PROJECT NO. 13-1152-0250 (9000)	REV A	FIGURE I1
------------------------------------	----------	--------------



— TW1-88 Daily Pumpage
 ■ Precipitation
 — SW3-00 (from on-Site Pond)





DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP

PROJECT **NESTLE WATERS CANADA**
 Town of Erin, Ontario

TITLE **HYDROGRAPH FOR SW3-00**

PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	I2



DATE	DECEMBER 2018
DESIGN	KS
REVIEW	GP
APPROVED	GP


PROJECT **NESTLE WATERS CANADA**
Town of Erin, Ontario

TITLE **HYDROGRAPH FOR SW7-08 & SW7A-16**

PROJECT NO.	REV	FIGURE
13-1152-0250 (9000)	A	13

APPENDIX J

Water Quality



PROJECT **HYDROGEOLOGICAL STUDY
NESTLE WATERS CANADA**

TITLE **PIPER PLOT**


PROJECT NO. 13-1152-0250 (9000)

REV A

FIGURE J1



DATE	2018-JUL-10
DESIGN	JLH
REVIEW	GRP
APPROVED	GRP



PROJECT **HYDROGEOLOGICAL STUDY
NESTLE WATERS CANADA**

TITLE **WATER QUALITY - TIME SERIES**



DATE	2019-JUN-17
DESIGN	JLH
REVIEW	GRP
APPROVED	GRP

PROJECT NO. 13-1152-0250 (9000)

REV A

FIGURE J2

APPENDIX K

Groundwater Modelling Report



**GROUNDWATER MODELLING REPORT
FOR RENEWAL OF THE PERMIT TO TAKE WATER FOR THE NESTLÉ WATERS
CANADA ABERFOYLE AND ERIN FACILITIES**

Report Prepared for:
CITY OF GUELPH AND NESTLÉ WATERS CANADA

Prepared by:
MATRIX SOLUTIONS INC.

Version 2.0
February 2019
Guelph, Ontario

Unit 7B, 650 Woodlawn Rd. W
Guelph, ON N1K 1B8
T 519.772.3777 F 226.314.1908
www.matrix-solutions.com

GROUNDWATER MODELLING REPORT
FOR RENEWAL OF THE PERMIT TO TAKE WATER FOR THE NESTLÉ WATERS CANADA
ABERFOYLE AND ERIN FACILITIES

Report prepared for City of Guelph and Nestlé Waters Canada, February 2019



Jeffrey Melchin, M.Sc., P.Ge.
Hydrogeologist *February 11, 2019*



reviewed by
David Van Vliet, M.A.Sc., P.Eng.
Senior Vice President, Eastern Canada

DISCLAIMER

Matrix Solutions Inc. certifies that this report is accurate and complete and accords with the information available during the project. Information obtained during the project or provided by third parties is believed to be accurate but is not guaranteed. Matrix Solutions Inc. has exercised reasonable skill, care, and diligence in assessing the information obtained during the preparation of this report.

Matrix Solutions Inc. was retained by the City of Guelph under contract to Nestlé Waters Canada. This report was prepared for the City of Guelph and Nestlé Waters Canada. The report may not be relied upon by any other person or entity without the written consent of Matrix Solutions Inc. and of the City of Guelph and Nestlé Waters Canada. Any uses of this report by a third party, or any reliance on decisions made based on it, are the responsibility of that party. Matrix Solutions Inc. is not responsible for damages or injuries incurred by any third party, as a result of decisions made or actions taken based on this report.

VERSION CONTROL

Version	Date	Issue Type	Filename	Description
V0.1	17-Sep-2018	Draft	26435-552 Groundwater Modelling R 2018-09-17 draft V0.1.docx	Issued for review
V0.2	17-Sep-2018	Draft Revised	26435-552 Groundwater Modelling R 2018-09-17 draft V0.2.docx	Issued for review with minor text revisions
V0.3	19-Dec-2018	Draft Revised 2	26435-552 Groundwater Modelling R 2018-09-17 draft V0.3.docx	Updates throughout; issued for review
V1.0	22-Jan-2019	Final	26435-552 Groundwater Modelling R 2019-01-22 final V1.0.docx	Updates throughout; issued as final
V2.0	11-Feb-2019	Final Revised	26435-552 Groundwater Modelling R 2019-02-11 final V2.0.docx	Updates throughout; issued as final revised

TABLE OF ABBREVIATIONS

CRA	Conestoga-Rovers and Associates
DEM	Digital Elevation Model
Earthfx	Earthfx Incorporated
FEFLOW	Groundwater Modelling Software
GAWSER	Guelph All-Weather Sequential Events Runoff
GCM	Global Climate Models
GRCA	Grand River Conservation Authority
GGET	City of Guelph and Township of Guelph/Eramosa
GRIN	Grand River Information Network
HSP-F	Hydrologic Simulation Program - Fortran
MECP	Ministry of Environment, Conservation, and Parks
MNR	Ministry of Natural Resources
MNRF	Ministry of Natural Resources and Forestry
MOE	Ministry of the Environment
MOECC	Ministry of Environment and Climate Change
NWC	Nestlé Waters Canada
PEST	Parameter ESTimation [Software]
PRMS	Precipitation-Runoff Modelling System
PTTW	Permit to Take Water
SSPA	S.S. Papadopoulos and Associates
WWIS	Water Well Information System

TABLE OF CONTENTS

1	INTRODUCTION.....	1
1.1	Tier Three Assessment.....	1
1.1.1	Tier Three Assessment Groundwater Flow Model.....	2
1.2	Nestlé Waters Canada Operations.....	4
1.2.1	Aberfoyle.....	4
1.2.2	Erin.....	5
2	GEOLOGIC AND HYDROGEOLOGIC SETTING.....	5
2.1	Aberfoyle.....	6
2.1.1	Overburden.....	6
2.1.2	Bedrock.....	6
2.1.3	Simulated Hydrostratigraphy and Groundwater Flow.....	7
2.2	Erin.....	8
2.2.1	Overburden.....	8
2.2.2	Bedrock.....	8
2.2.3	Simulated Stratigraphy and Groundwater Flow.....	9
3	TIER THREE MODEL UPDATES.....	10
3.1	Aberfoyle.....	10
3.1.1	Representation of Surface Water Features.....	11
3.2	Erin.....	12
3.2.1	Representation of Surface Water Features.....	13
4	MODEL CALIBRATION.....	13
4.1	Aberfoyle.....	13
4.1.1	Hydraulic Conductivity.....	13
4.1.2	Calibration to Pumping Conditions.....	15
4.1.3	Calibration to Long-term Average Conditions.....	17
4.1.4	Groundwater Discharge to Streams.....	22
4.1.5	Overall Calibration Summary.....	23
4.2	Erin.....	24
4.2.1	Hydraulic Conductivity.....	24
4.2.2	Calibration to Pumping Conditions.....	25
4.2.3	Calibration to Long-term Non-pumping Conditions.....	26
4.2.4	Groundwater Discharge to Streams.....	28
4.2.5	Overall Calibration Summary.....	28
5	MODEL SCENARIOS.....	29
5.1	Scenario Descriptions.....	29
5.1.1	Scenario 1 - Current Average NWC Pumping (Baseline Average Conditions, Steady-state).....	30
5.1.2	Scenario 2 - Maximum Permitted NWC Pumping (Steady-state).....	31

5.1.3	Scenario 3 - Current Average NWC Pumping (Baseline Conditions, Transient) ..	31
5.1.4	Scenario 4 - Maximum Permitted NWC Pumping (Transient)	32
5.1.5	Scenario 5 - Current Average NWC Pumping with Climate Change Projections (Transient).....	32
5.2	Scenario Results - Aberfoyle	34
5.2.1	Steady-state Scenario Results.....	34
5.2.2	Drought Scenario Results.....	35
5.2.3	Climate Change Scenario Results.....	36
5.3	Scenario Results - Erin.....	36
5.3.1	Steady-state Scenario Results.....	37
5.3.2	Drought Scenario Results.....	37
5.3.3	Climate Change Scenario Results.....	38
6	CLOSURE	39
7	REFERENCES.....	40

LIST OF CHARTS

Chart 1	Aberfoyle Scatter Plot of Average Hydraulic Head (2009 to 2013 and 2015) - All Targets	18
Chart 2	Aberfoyle Scatter Plot of Average Hydraulic Head (2009 to 2013 and 2015) - High Quality Targets.....	19
Chart 3	Aberfoyle Cumulative Probability Plot of Higher Quality Targets at Aberfoyle	20
Chart 4	Aberfoyle Cumulative Probability Plot of Lower Quality (WWIS) Targets at Aberfoyle	21
Chart 5	Erin Scatter Plot of Average Hydraulic Head (0 m ³ /day NWC Pumping)	27

LIST OF TABLES

TABLE 1	Aberfoyle - Conceptualization of Stratigraphic Framework	7
TABLE 2	Erin - Conceptualization of Stratigraphic Framework.....	9
TABLE 3	Aberfoyle - Summary of Hydraulic Conductivity Changes	14
TABLE 4	Aberfoyle - Hydraulic Head Calibration Statistics	21
TABLE 5	Aberfoyle - Summary of Estimated and Simulated Groundwater Discharge (m ³ /day).....	23
TABLE 6	Erin - Summary of Hydraulic Conductivity Changes.....	25
TABLE 7	Erin - Hydraulic Head Calibration Statistics.....	28
TABLE 8	Erin - Summary of Estimated and Simulated Groundwater Discharge (m ³ /d)	28
TABLE 9	Scenario Summary	30
TABLE 10	Aberfoyle Simulated Groundwater Discharge - Average NWC Pumping to Permitted NWC Pumping	35
TABLE 11	Aberfoyle Simulated Groundwater Discharge Ranked Duration Analysis - Average NWC Pumping to Permitted NWC Pumping	36

TABLE 12	Erin Simulated Groundwater Discharge - Average NWC Pumping to Permitted NWC Pumping.....	37
TABLE 13	Erin Simulated Groundwater Discharge Ranked Duration Analysis - Average NWC Pumping to Permitted NWC Pumping	38

FIGURES

FIGURE 1	City of Guelph and Township of Guelph/Eramosa Tier Three Assessment Model Area
FIGURE 2	Aberfoyle Site Map
FIGURE 3	Erin Site Map
FIGURE 4	Aberfoyle NW-SE Model Cross-section (AA')
FIGURE 5	Aberfoyle SW-NE Model Cross-section (BB')
FIGURE 6	Aberfoyle - Simulated Goat Island Fm. Potentiometric Surface (Layer 10)
FIGURE 7	Erin NW-SE Model Cross-section (AA')
FIGURE 8	Erin SW-NE Model Cross-section (BB')
FIGURE 9	Erin - Simulated Guelph Fm. Potentiometric Surface (Layer 7)
FIGURE 10	Aberfoyle - Simulated vs. Interpreted Drawdown in the Upper Bedrock (Layer 6 - Reformatory Quarry Mbr.) due to 2010 NWC Pumping Test
FIGURE 11	Aberfoyle - Simulated vs. Interpreted Drawdown in the Lower Bedrock (Layer 10 - Goat Island Fm.) due to 2010 NWC Pumping Test
FIGURE 12	Aberfoyle - Simulated vs. Interpreted Drawdown in the Lower Bedrock (Layer 12 - Middle Gasport Fm.) due 2010 NWC Pumping Test
FIGURE 13	Erin - Simulated Drawdown in the Guelph Fm. (Layer 7) due to NWC pumping (2016 to 2017)
FIGURE 14	Scatter Plot of Future Climate Models Selected for Hydrologic Modelling (2050s versus Current)
FIGURE 15	Estimated Mean Daily Recharge (2050s versus Baseline)
FIGURE 16	Aberfoyle - Simulated Additional Drawdown in Upper Bedrock (Layer 6 - Reformatory Quarry Mbr.) - Average Pumping to Permitted Pumping
FIGURE 17	Aberfoyle - Simulated Additional Drawdown in Lower Bedrock (Layer 10 - Goat Island Fm.) - Average Pumping to Permitted Pumping
FIGURE 18	Local Aberfoyle Extent - Simulated Additional Drawdown in Lower Bedrock (Layer 12 - Middle Gasport Fm.) - Average Pumping to Permitted Pumping
FIGURE 19	Regional Aberfoyle Extent - Simulated Additional Drawdown in Lower Bedrock (Layer 12 - Middle Gasport Fm.) - Average Pumping to Permitted Pumping
FIGURE 20	Aberfoyle - Simulated Water Level Variability at MW2A-07 - Drought Scenarios
FIGURE 21	Aberfoyle - Simulated Water Level Variability at Burke Well - Drought Scenarios
FIGURE 22	Aberfoyle - Simulated Groundwater Discharge at Mill Creek at Side Rd. 10 Gauge - Drought Scenarios Time Series
FIGURE 23	Aberfoyle - Simulated Groundwater Discharge at Mill Creek at Side Rd. 10 Gauge - Drought Scenarios Ranked Duration Curves

FIGURE 24	Aberfoyle – Mean Monthly Simulated Water Level Variability at MW2A-07 - Climate Change Scenarios
FIGURE 25	Aberfoyle - Mean Monthly Simulated Water Level Variability at Burke Well - Climate Change Scenarios
FIGURE 26	Aberfoyle - Mean Monthly Simulated Groundwater Discharge at Mill Creek at Side Rd. 10 Gauge - Climate Change Scenarios
FIGURE 27	Local Erin Extent - Simulated Additional Drawdown in the Guelph Fm. (Layer 7) - Average Pumping to Permitted Pumping
FIGURE 28	Regional Erin Extent - Simulated Additional Drawdown in the Guelph Fm. (Layer 7) - Average Pumping to Permitted Pumping
FIGURE 29	Erin - Simulated Water Level Variability at MW05A-05 - Drought Scenarios
FIGURE 30	Erin - Simulated Water Level Variability at Hillsburgh Well 2 - Drought Scenarios
FIGURE 31	Erin - Simulated Water Level Variability at Hillsburgh Well 3 - Drought Scenarios
FIGURE 32	Erin - Simulated Groundwater Discharge at SW1 - Drought Scenarios Time Series
FIGURE 33	Erin - Simulated Groundwater Discharge at SW1 - Drought Scenarios Ranked Duration Curves
FIGURE 34	Erin - Mean Monthly Simulated Water Level Variability at MW05A-05 - Climate Change Scenarios
FIGURE 35	Erin - Mean Monthly Simulated Water Level Variability at Hillsburgh Well 2 - Climate Change Scenarios
FIGURE 36	Erin - Mean Monthly Simulated Water Level Variability at Hillsburgh Well 3 - Climate Change Scenarios
FIGURE 37	Erin - Mean Monthly Simulated Groundwater Discharge at SW1 - Climate Change Scenarios

APPENDICES

APPENDIX A	Calibration Dataset and Results
APPENDIX B	Hydraulic Conductivity Updates

1 INTRODUCTION

The Ministry of Environment, Conservation and Parks (MECP) has provided new guidance outlining the requirements for the renewal of Permits to Take Water (PTTWs) for water bottling purposes (MOECC 2017). This guidance requires that an assessment of cumulative effects of renewed takings be completed using the highest tier water budget that has been completed under the *Clean Water Act*, 2006 (Government of Ontario 2018). In response to these requirements, Nestlé Waters Canada (NWC) arranged for the numerical groundwater flow model developed for the City of Guelph and Township of Guelph/Eramosa (GGET), *Tier Three Water Budget and Local Area Risk Assessment* (GGET Tier Three Assessment; Matrix 2017a) be updated in the areas of their Aberfoyle and Erin operations, and applied to assess cumulative effects as part of its PTTW renewal applications.

Matrix Solutions Inc. was retained by the City of Guelph, under contract with NWC, to refine the GGET Tier Three groundwater flow model (Tier Three model), to address the technical requirements of the *Interim Guidance Document* (MOECC 2017). The approach was based on the work plan agreed to by the City of Guelph and NWC (Matrix 2017b). This report outlines the work completed in support of meeting these requirements, including a cumulative effects water quantity risk assessment that considers current and drought conditions. The potential impacts of these conditions on local groundwater levels and municipal groundwater users, as well as the potential impacts on groundwater discharge to surface water features, were assessed using the refined Tier Three model. Finally, the model was applied to evaluate the potential change in groundwater levels and groundwater discharge under future climate conditions following the methodology described by Matrix (2018a).

Matrix worked with NWC and its consultants (S.S. Papadopoulos & Associates [SSPA], Golder Associates, and Blackport Hydrogeology Inc.) to complete this numerical modelling project, which included the sharing of data between parties and consultations during data analysis, model refinement, and calibration. The project leveraged the experience and local knowledge of these consultants gained through multiple years of data collection and analysis in the areas of Aberfoyle and Erin. Final model review and model calibration was completed in consultation with SSPA.

This report summarizes the geologic and hydrogeologic settings (Section 2), updates made to the numerical model (Section 3), model calibration data and results (Section 4), and results of the predictive steady-state (long-term average), transient (time-varying), and future climate scenarios for the Aberfoyle and Erin sites (Section 5).

1.1 Tier Three Assessment

A Tier Three Assessment was previously completed for municipal drinking water systems of GGET within the Province of Ontario, Canada (Matrix 2017a). As a requirement under the province's *Clean Water Act* (Bill 43; Government of Ontario 2018), the purpose of the Tier Three Assessment was to identify the Water Quantity Threats to municipal drinking water systems, where those systems are located within a

subwatershed classified as having a Moderate or Significant potential for water quantity stress during a Tier Two Water Quantity Stress Assessment (AquaResource 2009a; 2009b).

The scope of work completed for the GGET Tier Three Assessment and documented in Matrix (2017a) follows the Province of Ontario's *Technical Rules: Assessment Report, Clean Water Act, 2006* (Technical Rules; MOECC 2016), *Technical Bulletin: Part IX Local Area Risk Level* (Technical Bulletin; MOE and MNR 2010), and the *Memorandum: Assignment of Water Quantity Risk based on the Evaluation of Impacts to Other Water Users* (Technical Guidance Memorandum; MOE 2013). This work included the following tasks:

- Develop the conceptual understanding of the study area.
- Develop and calibrate a groundwater flow model with sufficient detail to simulate groundwater flow near municipal wells and surface water features.
- Develop and calibrate a streamflow-generation model to simulate variable streamflow in the area, and to estimate groundwater recharge rates in the study area.
- Apply the calibrated surface water and groundwater models to assess the water budget components in the Study Area and near municipal wells.
- Complete a Local Area Risk Assessment for the municipal wells located in the Study Area to determine if there is a risk that the municipal wells may not be able to meet current or future demands, while considering population growth, reduced groundwater recharge due to land development, and drought conditions.
- Identify Significant Water Quantity Threats, including consumptive water takings and areas of potential reduced groundwater recharge.

All stages of the GGET Tier Three Assessment, including development of the Tier Three model, were peer reviewed on behalf of the Lake Erie Source Protection Region by a Provincial Peer Review team consisting of hydrogeology and hydrology experts, to ensure that the technical aspects of the study complied with the *Technical Rules*. Municipalities local to the study area also provided technical review for consideration by the project team and Provincial Peer Review team.

1.1.1 Tier Three Assessment Groundwater Flow Model

To carry out the GGET Tier Three Assessment, a FEFLOW (version 6.2; Diersch 2014) groundwater flow model was developed based on the detailed conceptual model of the geologic, hydrologic, and hydrogeologic systems of the study area, with particular focus on the areas surrounding the City of Guelph and Rockwood and Hamilton Drive municipal well fields (Figure 1). The approach used to develop the Tier Three model built upon the approach followed to build the Guelph-Puslinch

groundwater flow model (Golder 2006). The key advancements made in developing this updated and refined groundwater flow model were as follows:

- The geographic coverage of the Tier Three model was extended to include the Grand River to the west, and the Niagara Escarpment to the east (Figure 1). Carrying the model westward to the Grand River provided a natural boundary condition for groundwater flow. The Niagara Escarpment represents the physical location where the Gasport Formation bedrock aquifer, the main aquifer supplying the municipal water supplies, pinches out.
- The conceptual model was updated based on detailed interpretation of geologic units at numerous high-quality boreholes located throughout the area, whereas the bedrock conceptual model used in the Guelph-Puslinch groundwater flow model was simplified, and represented by layers of constant thickness.
- Groundwater level data from high quality groundwater monitoring wells installed by the City of Guelph and screened in discrete hydrogeologic units provided an improved and enhanced understanding of the bedrock flow system.
- The Township of Guelph/Eramosa conducted additional studies for the municipal systems in Rockwood that improved understanding of the bedrock system in that area.
- The groundwater flow model was refined to include additional surface water features that were not previously represented in the Guelph-Puslinch groundwater flow model.

The approach adopted to calibrate the Tier Three model included a combination of iterative manual and software-assisted (Parameter ESTimation [PEST]; version 12; Doherty 2013) calibration. The model was calibrated to long-term steady-state conditions, and to transient conditions that included the simulation of a long-term pumping test (City of Guelph) and shorter-term pumping tests. Transient model verification was also undertaken to confirm the performance of the model under transient conditions. The steady-state Tier Three model was calibrated to hydraulic head measurements from MOECC domestic water wells records, GGET high-quality monitoring wells, and other high-quality wells that are part of other studies. The model was also calibrated to streamflow targets assumed to be representative of baseflow conditions. These targets were estimated from spot baseflow observations and streamflow gauge data collected by the Grand River Conservation Authority (GRCA), Water Survey of Canada, and others, at locations throughout the study area.

Calibration of the groundwater flow model relied on estimates of groundwater recharge across the landscape represented by the model. Groundwater recharge estimates used in the calibration of the model include the following:

- The Grand River Watershed Guelph All-Weather Sequential Events Runoff (GAWSER) streamflow generation model (version 6.5; Schroeter & Associates 2004, AquaResource 2009a, Matrix 2017a).
- The Credit River Watershed HSP-F model (AquaResource 2009c).
- Halton and Hamilton Region Conservation Authorities Precipitation-Runoff Modelling System (PRMS) model (Earthfx 2009).

Additional information on the development and calibration of the groundwater and streamflow-generation and hydrologic models is provided in Appendices B, D, and E of Matrix (2017a), and references therein.

The version of the Tier Three model used in the update and calibration effort described in the following sections is based on the model developed for GGET Tier Three Risk Assessment Scenario C (Matrix 2017a), which includes consideration of average climate conditions (i.e., average recharge), existing municipal pumping, and existing non-municipal pumping. Non-municipal permits and pumping rates were updated in the model to reflect more recent data within the local groundwater vulnerable area as part of a *Water Quantity Policy Development Study* (Matrix 2018b). Specifically, the PTTW database (September 2017 data release) and Water Taking Reporting System (WTRS; 2009 to 2016) were reviewed to assess if the non-municipal permitted takings represented in the model were still representative of existing conditions. Permits that had expired were removed from the model and the rates were updated using 2016 WTRS data. Consumptive use (i.e., the amount of water removed from a source without being returned to the same source) was estimated using the method used in the GGET Tier Three Assessment. Based on this work, the total consumptive pumping in the local groundwater vulnerable area decreased by 966 m³/day. These refined non-municipal pumping rates were carried forward for use in this project.

1.2 Nestlé Waters Canada Operations

1.2.1 Aberfoyle

The NWC Aberfoyle property is located within the Grand River Watershed, in the Township of Puslinch, approximately 3 km south of the City of Guelph, and 2 km north of Highway 401 along Wellington Road 46 (Figure 2). NWC is permitted to pump water from bedrock well TW3-80 for water bottling purposes, and bedrock well TW2-11 for miscellaneous purposes under PTTW 1381-95ATPY at a maximum total rate of 3,600 m³/day; however, well TW2-11 has not been used to date. Permitted taking of water has been ongoing at the site since NWC purchased the pre-existing Aberfoyle Springs bottling facility in 2000, and in 2017 annual taking totaled 767,883 m³.

NWC conducts annual environmental monitoring onsite that includes measurement of groundwater levels, mini-piezometer levels, surface water levels, flows, and temperatures. These monitoring

locations are shown on Figure 2. A full description of the monitoring program and historical monitoring data is provided in annual monitoring reports prepared on behalf of NWC (e.g., Golder 2018a).

Notable surface water features in the area include Mill Creek, which runs from northeast to southwest just north of the NWC property (Figure 2). A portion of Mill Creek flow is diverted into Aberfoyle Creek in the area of the Mini Lakes community (Figure 2). At this point, Aberfoyle Creek continues south, into Aberfoyle Mill Pond, and then through the NWC property. Aberfoyle Creek rejoins Mill Creek just west of the NWC property (Figure 2).

1.2.2 Erin

The NWC Erin bedrock well TW1-88 is located in the Grand River Watershed, close to the surface water divide between the Grand River Watershed and the Credit River Watershed. It is situated in the Town of Erin, approximately 500 m southwest of the Community of Hillsburgh (Figure 1). NWC is permitted to pump water from this well for water bottling purposes, under PTTW 3716-8UZMCU, at a maximum rate of 1,113 m³/day. Permitted water taking has been ongoing at the site since 2000 and in 2017 the annual taking was 66,075 m³.

Similar to the Aberfoyle site, NWC conducts annual environmental monitoring onsite that includes measurement of groundwater levels, mini-piezometer levels, surface water levels and flows. These monitoring locations are shown on Figure 3. A full description of the monitoring program and historical monitoring data is provided in annual monitoring reports prepared on behalf of NWC (e.g., Golder 2018b).

Notable surface water features in the area include tributaries of the Eramosa River and the Erin Branch of the Credit River, which briefly cross into the NWC property along the northwestern and northeastern property corners, respectively (Figure 3). Tributaries and on-line ponds contributing to the Eramosa River originate on and just north of the NWC property before continuing out of the area toward the southwest and south. Similarly, tributaries and ponds associated with the Erin Branch of the Credit River originate north and northeast of the NWC property before entering the Hillsburgh Pond, flowing out of the study area to the south and east. South of the NWC property, a creek originating from Roman Lake drains toward the southeast, where it enters the main branch of the West Credit River.

2 GEOLOGIC AND HYDROGEOLOGIC SETTING

Detailed descriptions of the regional geologic and hydrologic settings are provided in Matrix (2017a). Descriptions of the local geologic and hydrogeologic settings near NWC operations are provided in the 2017 annual monitoring reports for Aberfoyle (Golder 2018a) and Erin (Golder 2018b). Summaries of how these local settings are represented in the Tier Three model are presented in the following sections.

2.1 Aberfoyle

2.1.1 Overburden

The local overburden geology of the Aberfoyle site generally consists of coarse-grained outwash and ice-contact sand and gravel deposits overlying a finer-grained stony, silt Wentworth Till. This till also makes up the Paris and Galt moraines that are mapped toward the north and south of the site, where the till thickens to surface. Overburden thickness near the site ranges from 15 to 20 m and organic deposits are mapped along Aberfoyle Creek as it crosses the NWC property (Golder 2018a).

In the Tier Three model the shallow, coarser-grained deposits are represented as “Overburden A,” upper sand and gravel aquifer. Below this, the finer-grained till deposits are represented as “Overburden B,” a lower till aquitard (Table 1).

2.1.2 Bedrock

The bedrock geology of the Aberfoyle site has been historically described (Golder 2018a) using bedrock nomenclature and interpretations made prior to more recent updates made by the Ontario Geological Survey (e.g., Brunton 2009). Under that previous framework, bedrock hydrogeologic units at the Aberfoyle site were described (from shallow to deep) as the Guelph Formation Aquifer overlying the Eramosa Member Aquitard, the Amabel Formation Aquifer, and the Cabot Head Formation Aquitard. This interpretation is consistent with the more regional bedrock interpretation that existed prior to the development of the Tier Three model, as summarized in Table 1. The development of the Tier Three model; however, incorporated the revised nomenclature (after Brunton 2009; Table 1) which included refinement into new and additional bedrock formations and members. Based on this revised framework, modelled hydrostratigraphic units included:

- Guelph Formation Aquifer
- Reformatory Quarry Member Aquifer/Aquitard (Eramosa Formation)
- Vinemount Member Aquitard (Eramosa Formation)
- Goat Island Formation Aquifer/Aquitard
- Upper Gasport Aquifer, Middle Gasport High Permeability Aquifer, and Lower Gasport Aquifer units of the Gasport Formation
- Cabot Head Formation Aquitard

A comparison of these modelled hydrostratigraphic units and how they relate to the current and previous bedrock conceptualizations is presented in Table 1. Additional details on these hydrostratigraphic units are found in Matrix (2017a).

Monitoring well calibration targets are classified with respect to dominant hydrogeological units, including the Upper Bedrock Aquifer (bedrock targets above the Vinemount Aquitard) and Lower

Bedrock Aquifer (bedrock targets below the Vinemount Aquitard). This simplified conceptualization is also provided in Table 1.

TABLE 1 Aberfoyle - Conceptualization of Stratigraphic Framework

Bedrock Conceptualization Previous to GGET Tier Three Study ¹		Bedrock Conceptualization for GGET Tier Three Study ²		GGET Tier Three Model Representation of Hydrostratigraphic Units ³		Simplified Conceptualization at NWC Site for Calibration Targets
Formation	Member	Formation	Member	Hydrostratigraphic Unit	Model Layer	
Overburden		Overburden		Overburden A (Upper Sand/Gravel Aquifer)	1-2	Overburden Targets
				Overburden B (Lower Till Aquitard)	3	
				Contact Zone (fractured bedrock / basal unconsolidated deposits)	4	
Guelph Fm.		Guelph	Hanlon	Guelph Fm. (Aquifer)	5	Upper Bedrock Aquifer Targets
			Wellington			
Amabel	Eramosa	Eramosa	Stone Road	Reformatory Quarry Mbr. (Aquifer/Aquitard)	6	Middle Bedrock Aquitard
			Reformatory Quarry			
			Vinemount		Vinemount Mbr. (Aquitard)	
	Warton / Colpoy / Lions Head	Goat Island	Ancaster / Niagara Falls	Goat Island Fm. (Aquifer/Aquitard)	10	Lower Bedrock Aquifer Targets
			Gasport	Gothic Hill	Upper Gasport Unit (Aquifer)	
Middle Gasport Unit (High Permeability Aquifer)	12					
Rochester / Irondequoit / Rockway / Merritton Fms.		Lower Gasport Unit (Aquifer)	13			
Cabot Head/Reynales Fm.		Cabot Head Fm.	Cabot Head Fm. (Aquitard)	14	Cabot Head Fm. (Aquitard)	

¹ Golder (2006)

² After Brunton (2009)

³ Matrix (2017a)

2.1.3 Simulated Hydrostratigraphy and Groundwater Flow

Cross-sections were created to illustrate the GGET Tier Three hydrostratigraphy compared to the interpretation provided in Golder (2018a). Figure 2 shows the locations of Cross-section A-A' (Figure 4) extending from the northwest to the southeast, and Cross-section B-B' (Figure 5) extending from the southwest to the northeast. Each cross-section illustrates the horizontal conductivity distribution in the calibrated Tier Three model described in Section 4. The GGET Tier Three hydrostratigraphic layers (elevation and thickness) were assumed to be acceptable for this assessment, and model modifications were made by adjusting hydraulic conductivities locally.

Figures 4 and 5 illustrate the locations of the higher permeability hydrostratigraphic units, including the overburden (Overburden A), Contact Zone, Guelph Formation, Reformatory Quarry Member, and the Middle Gasport Formation aquifers. The other units in the Aberfoyle area are simulated with relatively lower hydraulic conductivity, except for small zones in the Goat Island Formation and overlying Vinemount Member. These localized zones of higher conductivity correspond to areas where there was a stronger water level response during pumping tests, suggesting a greater hydraulic connection to the pumping well. There may be differences in bedrock formations interpreted between the cross-sections provided in Golder (2018a), and the refined interpretations presented in Figures 4 and 5. For example, the Guelph Formation is conceptualized to exist in Cross-section A-A' of Golder (2018a); however, the Reformatory Quarry Member of the Eramosa Formation is conceptualized along the same portion of cross-section in the GGET Tier Three model (Figure 4).

NWC production well TW3-80 is completed within the high conductivity zone of the Goat Island Formation and within this unit groundwater is simulated to flow regionally from the north to the south, with a local low in the potentiometric surface from NWC pumping (Figure 6). The simulated potentiometric surface of Figure 6 is based on a simulated pumping rate of 2,113 m³/day, representing average NWC Aberfoyle pumping conditions from 2015 to 2017. The interpreted observed potentiometric surface of the production aquifer is provided in Figure 4.3 of Golder (2018a).

2.2 Erin

2.2.1 Overburden

The local overburden geology of the Erin site is similar to that of the Aberfoyle site, with a coarser-grained glaciofluvial outwash or ice-contact stratified drift overlying a deeper, finer-grained clay to sandy silt till, with more recent organic deposits found along watercourses. The shallower sand and gravel deposits generally thicken to the northwest, whereas the deeper finer-grained till is continuous across the site, and in some areas where it thickens it outcrops at surface. The outcrop area includes portions of the NWC property and areas toward the east and south where the till is associated with topographically high areas (Golder 2018b). At NWC production well TW1-88, the overburden is approximately 20 m thick.

In the Tier Three model the shallow, coarser-grained deposits are represented as “Overburden A,” an upper sand and gravel aquifer. Below this, the finer-grained till deposits are represented as “Overburden B,” a lower till aquitard (Table 2).

2.2.2 Bedrock

The bedrock geology of the Erin site has been previously described locally using a bedrock nomenclature that includes the Guelph Formation overlying the Amabel Formation (Golder 2018b). The focus of the GGET Tier Three bedrock conceptualization was the Guelph area, and as a result, there were fewer high

quality locations gathered and interpreted for the bedrock conceptualization in the Erin area. As a result, the elevations of the GGET Tier Three bedrock layers did not initially align with the bedrock layers currently conceptualized onsite. The modelled bedrock layer interpretations were refined in the Erin area based on local expertise provided by Blackport Hydrogeology Inc. and examination of local well logs. The revised model hydrostratigraphy for the Erin area is summarized in Table 2, along with the associated model layers and previous interpretation.

Based on the refined conceptualization, the updated modelled bedrock hydrostratigraphic units in the Erin area include a thicker Guelph Formation Aquifer overlying the Vinemount Aquitard, Gasport Formation Aquifer, and Cabot Head Formation Aquitard (Table 2). Similar to the Aberfoyle area, the hydraulic conductivity of simulated hydrostratigraphic units were refined locally, as opposed to introducing new layer elevations. For example, the hydraulic conductivity of model layers 5 to 10, that were previously conceptualized as four different bedrock units, were refined during the calibration process (Section 4) to the same values representing a thicker Guelph Formation.

TABLE 2 Erin - Conceptualization of Stratigraphic Framework

Tier Three Model Representation of Hydrostratigraphic Units ¹	Model Layer	Conceptualization Update for Erin Area
Overburden A (Upper Sand/Gravel Aquifer)	1-2	Overburden A (Upper Sand/Gravel Aquifer)
Overburden B (Lower Till Aquitard)	3	Overburden B (Lower Till Aquitard)
Contact Zone (fractured bedrock / basal unconsolidated deposits)	4	Contact Zone (fractured bedrock / basal unconsolidated deposits)
Guelph Fm. (Aquifer)	5	Guelph Fm. (Aquifer)
Reformatory Quarry Mbr. (Aquifer/Aquitard)	6	
Vinemount Mbr. (Aquitard)	7-9	
Goat Island Fm. (Aquifer/Aquitard)	10	
Upper Gasport Unit (Aquifer)	11	Vinemount Mbr. (Aquitard)
Middle Gasport Unit (High Permeability Aquifer)	12	Gasport Fm. (Aquifer)
Lower Gasport Unit (Aquifer)	13	
Cabot Head Fm. (Aquitard)	14	Cabot Head Fm. (Aquitard)

¹ Matrix (2017a)

2.2.3 Simulated Stratigraphy and Groundwater Flow

Cross-sections were created to illustrate the GGET Tier Three hydrostratigraphy compared to the interpretation provided in Golder (2018b). Figure 3 shows the locations of Cross-section A-A' (Figure 7) extending from the northwest to the southeast, and Cross-section B-B' (Figure 8) extending from the southwest to the northeast. Each of the cross-sections illustrate the final hydraulic conductivity distribution achieved following the calibration effort described in Section 4. Figures 7 and 8 illustrate the hydrostratigraphic units with relatively higher hydraulic conductivity, including the overburden (Overburden A), Contact Zone, Guelph Formation, and the Gasport Formation aquifers. The other units in the Erin area are simulated with relatively lower hydraulic conductivity.

NWC production well TW1-88 is completed within the Guelph Formation, and within this unit groundwater is simulated to flow regionally from northwest to southeast (Figure 9), with a local depression in the potentiometric surface in response to NWC pumping. The simulated hydraulic head contours also show a hydraulic gradient toward the Erin Branch of the Credit River as it flows toward the Town of Erin to the east. The simulated potentiometric surface of Figure 9 is based on a simulated pumping rate of 207 m³/day, representing average NWC Erin pumping conditions from 2015 to 2017. The interpreted observed potentiometric surface of the bedrock aquifer is provided in Figure 4.3 of Golder (2018b).

3 TIER THREE MODEL UPDATES

Local refinements to the Tier Three model were carried out in consultation with SSPA, Golder, and Blackport. This section describes the following updates made to the Tier Three model surrounding the NWC Aberfoyle and Erin sites:

- Revisions to the distribution and properties of hydrogeologic units.
- Mesh refinement around local surface watercourses, water bodies, and pumping wells.
- Addition of, and refinements to, boundary conditions representing surface watercourses and water bodies.
- Relocation and refinements to the magnitude of existing pumping well boundary conditions.
- Local model recalibration to account for the above refinements.

These model updates are discussed in the following sections for the Aberfoyle and Erin sites. Model calibration is discussed in Section 4.

3.1 Aberfoyle

The development and calibration of the GGET Tier Three model incorporated some local information, specifically in the Goat Island Formation, where NWC production well TW3-80 is completed (Matrix 2017a, Appendix E). Further updates and calibration in the Aberfoyle area as part of this current model refinement effort included a more fulsome examination of data from Lower Bedrock Aquifer units (below the Vinemount Aquitard), Upper Bedrock Aquifer units (above the Vinemount Aquitard), overburden sediments, and surface water features. Key data sources included:

- NWC 2017 Annual Monitoring Report (Golder 2018a).
- NWC 2010 Annual Monitoring Report (CRA 2011).

- Spatial data available from the online GRCA Grand River Information Network (GRIN) - Mapping used included 1 m ground surface topography contours, water bodies, and watercourses (GRCA 2018).

With the availability of long-term average water level data (Golder 2018a) and detailed water level response observations in various hydrostratigraphic units during a 40-day constant rate pumping test at TW3-80 (CRA 2011), refinements were made to the groundwater flow model to improve local, well-field scale response to NWC pumping, including:

- Refining the finite element mesh around TW3-80 and local surface water features.
- Adjusting the simulated horizontal location of TW3-80 following mesh refinement.
- Updating hydraulic conductivity values applied in different hydrostratigraphic units based on calibration to long-term average and pumping conditions (detailed in Section 4).
- Adding new and refining existing boundary conditions representing surface watercourses and water bodies (discussed in greater detail in the following section).

3.1.1 Representation of Surface Water Features

Groundwater flow models allow water to move between groundwater and surface water features through surface water boundary conditions. Surface water features are represented in the Tier Three model by assigning a specified head (water elevation) boundary condition to each model node along streams or rivers. The specified head, or water elevation, at each boundary condition was assumed to be the ground surface elevation at that location, as estimated from the 10 m Digital Elevation Model (DEM) of the ground surface available at the time of the GGET Tier Three Assessment. Observed water level elevation data were used for assigning specified head boundaries for larger water bodies in the model (e.g., lakes and reservoirs) where those data were available.

For this model update, the addition of new and refined boundary conditions was important to represent watercourses at a finer scale than was incorporated into the Tier Three model. In particular, Aberfoyle Creek, which runs through the NWC Aberfoyle property (Figure 2) was not previously represented in the Tier Three model due to its small size. NWC has collected water levels and flows along Aberfoyle Creek as part of the annual monitoring program (Golder 2018a). As the predicted change in groundwater discharge to Mill Creek is being assessed as part of this project, and since Aberfoyle Creek feeds into Mill Creek just west of the NWC property, Aberfoyle Creek was represented in the model.

Spatial watercourse mapping from the GRCA's online GRIN dataset (GRCA 2018) was used to approximate the location and path of the creek, and average observed water levels (Golder 2018a) were used to assign specified head boundary conditions at surface water monitoring stations SW01 and SW02 (Figure 2). Boundary conditions along Aberfoyle Creek between these stations were linearly interpolated

along the creek from the observed water levels. Other parts of Aberfoyle Creek, as well as other local water bodies (e.g., Aberfoyle Mill Pond and Mini Lakes) and streams were incorporated into the model with assigned specified head values estimated from current topographic mapping available through the GRCA GRIN dataset (GRCA 2018).

3.2 Erin

The Erin NWC site is located more than 15 km from the municipal supply wells of the City of Guelph, Town of Rockwood, and community of Hamilton Drive, where the physical characterization and model calibration was focussed. Additional local information was obtained for the site to improve characterization and calibration locally. Key data sources included:

- NWC Annual Monitoring Reports (Golder 2018b and CRA 2014a).
- *Well Construction and Testing Investigations* (CRA 1989).
- Insights from Blackport Hydrogeology Inc., who have considerable local hydrogeological experience.
- Spatial data available from the online GRCA GRIN dataset. Mapping used included 1 m ground surface topography contours, water bodies, and watercourses (GRCA 2018).

The following refinements were made to the Tier Three model using these data sources, and the long-term water level monitoring data contained therein, to support local, well-field scale calibration:

- Refining the finite element mesh around TW1-88 and local surface water features.
- Adjusting the simulated horizontal and vertical locations of TW1-88, Hillsburgh municipal Wells 2 and 3.
- Updating the pumping rates of Hillsburgh Wells 2 and 3 from the original estimates in the Tier Three model (i.e., 216 m³/day [H2] and 216 m³/day [H3]) to more recent (2011 to 2013) average pumping rates (i.e., 67 m³/day [H2] and 101 m³/day [H3] [Blackport Pers. Comm. 2018]). Total pumping from the Hillsburgh municipal wells has remained relatively constant (e.g., 163 to 179 m³/day from 2016 to 2017; Town of Erin 2017, 2018).
- Updating hydraulic conductivity values applied in different hydrostratigraphic units based on the local hydrostratigraphy and calibration to long-term average and pumping conditions (detailed in Section 4).
- Adding new and refining existing boundary conditions representing surface watercourses and water bodies (discussed in greater detail in the following section).

3.2.1 Representation of Surface Water Features

Boundary conditions representing interactions between groundwater and surface water were added in the NWC Erin area following the same approach used in Aberfoyle. The location and path of new stream and pond boundary conditions were guided by spatial data from the GRCA GRIN dataset for the Grand River Watershed and from the Ontario Ministry of Natural Resources and Forestry (MNR) for the Credit River Watershed.

Average observed water levels (Golder 2018b) were used to assign specified head boundary conditions at local surface water monitoring locations SW1-08, SW3-08, SW4-08, SW5-08, SW7-08, and SW7A-16 (Figure 3). Boundary conditions in other areas were assigned based on where 1 m ground surface topography contours cross surface water features. Linear interpolation was used to assign boundary conditions between locations assigned using observed water levels or topography contours, and to link them to surface water features already represented in the model. Blackport Hydrogeology Inc. provided water level data for the pond in Hillsburgh (Blackport Pers. Comm. 2018). Finally, boundary conditions were assigned using the elevation of the existing simulated ground surface in the Credit River Watershed where more detailed information was lacking.

4 MODEL CALIBRATION

Given the model updates described in Section 3, and the availability of long-term average and pumping water level monitoring data, local-scale model calibration was completed in the Tier Three model at the NWC Aberfoyle and Erin sites. The calibration effort was carried out in consultation with SSPA, Golder, and Blackport. Following calibration to observed water levels (Appendix A), simulated groundwater discharge to local streams was compared to baseflow and streamflow estimates to verify that the model adequately represents observed streamflow conditions. These calibrations are further discussed in Section 4.1 and 4.2 for the Aberfoyle and Erin sites, respectively.

4.1 Aberfoyle

Calibration in the Aberfoyle area involved making local refinements to zones of hydraulic conductivity in different hydrostratigraphic units in the Tier Three model to achieve a match between observed and simulated water levels. Both long-term average water level data, as well as measured recovery following a 40-day constant rate pumping test were used during the calibration process. The objective was to improve agreement with the model against both datasets.

4.1.1 Hydraulic Conductivity

Hydraulic conductivity values were adjusted during model calibration within the range of hydraulic conductivity and transmissivity estimates from other studies (e.g., Matrix 2017a, CRA 2014b, CRA 2011, and Golder 2018a) and references therein. Table 3 summarizes the final calibrated range of revised hydraulic conductivity values applied to the update areas in each hydrostratigraphic unit, along with the

ranges used prior to the update and values estimated from field data. In general, the refined hydraulic conductivity values were within, or very close to, the estimated ranges derived from field data (Table 3). Figures B1 to B7 (Appendix B) present the final conductivity values applied for the zones that were updated in each hydrostratigraphic unit of the model. No updates were made to the hydraulic conductivity values for the contact zone (Layer 4) or Cabot Head Formation (Layer 14). Changes included the following:

- Addition of multiple, small, high conductivity zones extending from ground surface to the top of the fine-grained till unit (Layers 1 and 2), representing the excavated space and ponds created by sand and gravel aggregate operations (Figure B1).
- The creation of a low conductivity zone in the fine-grained overburden unit (Layer 3; Figure B2).
- The creation of a narrow zone in the Guelph Formation and Reformatory Quarry Member of the Eramosa Formation where the vertical conductivity was increased (Layer 5 and 6; Figure B3). The horizontal conductivity remained the same.
- The creation of a narrow zone in the Vinemount Member of the Eramosa Formation where the conductivity was increased (Layer 7-9; Figure B4).
- The creation of a relatively high conductivity zone within a larger, relatively low conductivity zone in the Goat Island Formation (Layer 10; Figure B5).
- The creation of a conductivity zone in the Upper, Middle, and Lower Gasport Formation, where conductivity was decreased relative to the surrounding regional area (Layer 11, 12, and 13; Figures B6, B7, and B8). This zone was required to match the drawdown cone interpreted from point observations of drawdown.

TABLE 3 Aberfoyle - Summary of Hydraulic Conductivity Changes

Model Layer(s) ¹	Unit	Previous Calibrated Hydraulic Conductivity of Update Areas (m/s)		Revised Calibrated Hydraulic Conductivity of Update Areas (m/s)		Estimates of Horizontal Hydraulic Conductivity from Field Data (m/s) ²	
		Min	Max	Min	Max	Min	Max
1-2	Overburden A (Coarser-grained)	$K_x = 1 \times 10^{-4}$ $K_z = 5 \times 10^{-5}$	$K_x = 2 \times 10^{-4}$ $K_z = 2 \times 10^{-4}$	$K_x = 1 \times 10^{-1}$ $K_z = 1 \times 10^{-1}$	$K_x = 1 \times 10^{-1}$ $K_z = 1 \times 10^{-1}$	$K_x = 4 \times 10^{-6}$	$K_x = 2 \times 10^{-2}$
3	Overburden B (Finer-grained)	$K_x = 1 \times 10^{-6}$ $K_z = 5 \times 10^{-7}$		$K_x = 2 \times 10^{-7}$ $K_z = 1 \times 10^{-7}$		$K_x = 2 \times 10^{-9}$	$K_x = 9 \times 10^{-5}$
5-6	Guelph Fm. and Eramosa Fm., Reformatory Quarry Mbr.	$K_x = 3 \times 10^{-6}$ $K_z = 3 \times 10^{-8}$		$K_x = 3 \times 10^{-6}$ $K_z = 3 \times 10^{-7}$		$K_x = 2 \times 10^{-7}$	$K_x = 6 \times 10^{-4}$
7-9	Eramosa Fm., Vinemount Mbr.	$K_x = 1 \times 10^{-7}$ $K_z = 1 \times 10^{-9}$		$K_x = 3 \times 10^{-6}$ $K_z = 3 \times 10^{-7}$		$K_x = 5 \times 10^{-7}$	$K_x = 3 \times 10^{-5}$
10	Goat Island Fm.	$K_x = 5 \times 10^{-6}$ $K_z = 8 \times 10^{-8}$	$K_x = 2 \times 10^{-4}$ $K_z = 3 \times 10^{-6}$	$K_x = 8 \times 10^{-8}$ $K_z = 1 \times 10^{-9}$	$K_x = 1 \times 10^{-3}$ $K_z = 1 \times 10^{-4}$	$K_x = 9 \times 10^{-8}$	$K_x = 4 \times 10^{-4}$

Model Layer(s) ¹	Unit	Previous Calibrated Hydraulic Conductivity of Update Areas (m/s)		Revised Calibrated Hydraulic Conductivity of Update Areas (m/s)		Estimates of Horizontal Hydraulic Conductivity from Field Data (m/s) ²	
		Min	Max	Min	Max	Min	Max
11 and 13	Upper and Lower hydrostratigraphic units of the Gasport Fm.	$K_x = 2 \times 10^{-6}$ $K_z = 2 \times 10^{-8}$	$K_x = 2 \times 10^{-6}$ $K_z = 2 \times 10^{-7}$	$K_x = 1 \times 10^{-7}$ $K_z = 1 \times 10^{-8}$		$K_x = 2 \times 10^{-8}$	$K_x = 5 \times 10^{-4}$
12	Middle hydrostratigraphic unit of the Gasport Fm.	$K_x = 8 \times 10^{-5}$ $K_z = 4 \times 10^{-5}$		$K_x = 4 \times 10^{-6}$ $K_z = 2 \times 10^{-6}$		$K_x = 2 \times 10^{-6}$	$K_x = 1 \times 10^{-2}$

¹ No hydraulic conductivity changes made to model layer 4 (Contact Zone) and 14 (Cabot Head Fm.)

² From (Matrix 2017a), (CRA 2014b), (CRA 2011), and (Golder 2018a)

Kx - Horizontal Hydraulic Conductivity

Kz - Vertical Hydraulic Conductivity

4.1.2 Calibration to Pumping Conditions

4.1.2.1 Approach

The calibration to pumping conditions was completed using water level monitoring data collected as part of a long-term constant rate test at NWC well TW3-80 (CRA 2011). The test occurred from August to October 2010, at a rate of 3,542 m³/day, for approximately 40 days, and water levels were measured at monitoring wells completed within the overburden and Upper and Lower Bedrock aquifers. Conestoga-Rovers and Associates (CRA; CRA 2011) reported the maximum measured water level recovery following 3.4 days after pumping ceased. CRA also estimated recoveries at each well that would occur due to pumping at the permitted rate of 3,600 m³/day, assuming “*linear proportionality between an increase in rate and an increase in drawdown*” (CRA 2011). S.S. Papadopoulos and Associates (SSPA) assembled these estimated recovery values for use as calibration targets to permitted pumping conditions.

To supplement the calibration data provided by the 40-day pumping test, SSPA estimated additional drawdown values using water level monitoring data collected from five bedrock wells installed after the 2010 pumping test. Calibration targets for these wells were developed using observed drawdown measurements collected during the 2010 Christmas season when NWC pumping operations were shut down. These targets were estimated by scaling the observed drawdown during this time by the ratio of the pre-shutdown pumping rate and 3,600 m³/day (Neville 2018, Pers. Comm.).

In total, 56 drawdown targets were used for monitoring wells completed in the overburden (18), Upper Bedrock Aquifer (18), and Lower Bedrock Aquifer (20). A list of the drawdown targets is provided in Appendix A (Table A1), and the locations are shown on Figures 10, 11, and 12.

The calibration approach consisted of estimating simulated drawdown by subtracting water levels between two steady-state conditions: pumping TW3-80 at 3,600 m³/day and no pumping at TW3-80. The simulated drawdown was then compared to the observed drawdown targets, and the difference between the two were minimized during the calibration process. This is an approximate analysis

approach as observed water levels at some well locations may not have fully recovered after 3.4 days. However, the approach is considered appropriate for this application, especially at key monitoring well nests where the water levels were approaching stable levels. Visual inspection of the observed hydrographs of these wells during the 2010 testing (CRA 2011) suggests that the difference in water elevation arising from assuming fully recovered conditions after 3.4 days is a small fraction of the total interpreted drawdown.

Note that while some calibration to the same 40-day test was completed as part of the GGET Tier Three Assessment (Matrix 2017a), that effort focussed on calibration to drawdown in the Lower Bedrock Aquifer. The present effort included calibration to drawdown in the Lower Bedrock, Upper Bedrock, and overburden units.

4.1.2.2 Results

The approach to assessing the goodness-of-fit between modelled and simulated pumping conditions (drawdown) was to evaluate the calibration results using maps comparing simulated drawdown contours with those interpreted from point drawdown observations. The primary objective of the calibration to pumping conditions was to approximate the general shape and extent of the drawdown contours in the Upper and Lower Aquifer units. Figures 10, 11, and 12 illustrate simulated and interpreted drawdown contours for the Reformatory Quarry Member of the Eramosa Formation (Upper Bedrock) and the Goat Island and Middle Gasport formations (Lower Bedrock), respectively. The observed drawdown contours were interpreted by CRA (2011) and were made using a variety of assumptions based on the hydrogeological formation represented by each monitoring well.

Figure 10 illustrates interpreted and simulated drawdown contours for the Upper Bedrock Aquifer (Simulated Reformatory Quarry Member). In general, the simulated drawdown contours match the trend of the interpreted drawdown contours, with a narrow, elongated shape extending from pumping well TW3-80 to monitoring well MW7B-08.

Figures 11 and 12 illustrate interpreted drawdown for wells completed in the Lower Bedrock Aquifer versus simulated drawdown from the Goat Island Formation and Middle Gasport Formation, respectively. As the Lower Bedrock Aquifer includes all calibration targets below the Vinemount Aquitard, two figures are provided to show the difference between the simulated drawdown of two Lower Bedrock Aquifer units. The figures show simulated contours approximating the circular shape of the interpreted contours. The calibrated model results in an under-prediction of the extent of the 1 m drawdown contour in the Goat Island Formation (Figure 11) and a slight over-prediction in the Middle Gasport Formation (Figure 12).

4.1.3 Calibration to Long-term Average Conditions

4.1.3.1 Approach

Steady-state calibration to long-term average conditions was completed using groundwater level monitoring data collected as part of the annual monitoring program at the Aberfoyle site (Golder 2018a). SSPA used these data to estimate average water levels for the period of 2009 to 2015 (except 2014) for use as steady-state calibration targets. In total, 79 water level targets were estimated for monitoring wells completed in the overburden (21), Upper Bedrock Aquifer (31), and Lower Bedrock Aquifer (27). Well completion elevation details were used to assign water level targets to hydrostratigraphic units under the revised bedrock nomenclature in the model where the unit was not already identified by SSPA. Table 1 was also used to guide translation of bedrock names between the previous and revised bedrock nomenclature where necessary.

Water level calibration targets used in the GGET Tier Three Assessment and derived from the Water Well Information System (WWIS) were used as additional calibration targets for the Aberfoyle area to broaden the coverage of the assessment. In total, 555 targets (i.e., 415 in bedrock and 140 in overburden) from the GGET Tier Three Assessment were used, covering a 3 km radius surrounding the Aberfoyle property. These WWIS static water level observations offer the benefit of having a high number of calibration targets that cover a wide area; however, there can be uncertainty associated with individual observations. These uncertainties may include errors in the reported locations and depths of wells, coarse water level measurement techniques, and water levels that may have been collected in different years or seasons, or under different stages of pumping/non-pumping conditions. Based on professional experience, individual groundwater elevation estimates as calculated from the WWIS dataset may have an average error, or uncertainty, of 5 to 10 metres as compared to actual conditions. Because of these uncertainties, the water level targets derived from WWIS data are considered lower quality than those from annual NWC monitoring activities and higher priority is given to calibrating the higher quality calibration targets.

Details of the calibration targets used in the Aberfoyle area are provided in Appendix A (Table A1).

An average pumping rate of 1,690 m³/day over the calibration period was estimated for TW3-80 using annual water taking data provided in Golder (2018a). This rate was used for the calibration to long-term average conditions, and represents an average for the same 2009 to 2015 (except 2014) period as determined for the water level targets.

4.1.3.2 Results

The steady-state calibration to long-term average conditions involved comparing simulated hydraulic heads against those measured in high-quality monitoring wells and lower quality WWIS wells completed within overburden and bedrock units. The scatter plot for long-term average conditions at the Aberfoyle site is presented on Chart 1, and a table of the observed and simulated values are provided in Appendix A (Table A1).

The scatter plot (Chart 1) illustrates the goodness-of-fit for hydraulic head targets with model-simulated heads plotted on the vertical axis, and observed hydraulic heads plotted on the horizontal axis. The 1:1 line corresponds to simulated head being equal to observed head, and the objective of the calibration effort is to have the points as close as possible to this line. Deviations of ± 5 m are shown on the plot as parallel lines offset from the 1:1 line. Points falling outside of the ± 5 m lines represent observation locations where the simulated hydraulic head differs from the observed value by more than 5 m. This difference may be due to model error, assumptions in the conceptual model, or may also be due to errors associated with the field-observed data.

The scatter plot shows that the simulated hydraulic heads are within the ± 5 m bounds for almost all of the higher quality targets. Overall, the calibration error is generally distributed both above and below the 1:1 line. Simulated hydraulic head is somewhat over-simulated in the Lower Bedrock; however, the highest simulated heads from this unit are from private wells (Chart 1), which may indicate gaps in the model-conceptualization of these wells, or an indication that these wells may be lower quality data points. Many of the bedrock domestic wells are completed as open bedrock boreholes and as a result there is uncertainty as to the specific bedrock formation associated with the measured water level.




Chart 1 Aberfoyle Scatter Plot of Average Hydraulic Head (2009 to 2013 and 2015) - All Targets

Chart 2 illustrates the same data as Chart 1, except for just the higher quality calibration targets. Lines representing ± 2.4 m were added to the chart to illustrate the range of the root mean squared error of these targets. The chart illustrates that the majority of predicted higher quality water levels would fall

within 2.4 m of the observed value, which is a smaller range than observed with the WWIS targets (i.e., 4.9 m). Additional information is provided about this calibration statistic later in this section.




Chart 2 Aberfoyle Scatter Plot of Average Hydraulic Head (2009 to 2013 and 2015) - High Quality Targets

Chart 3 illustrates a cumulative probability plot of the difference between the simulated and observed hydraulic head (i.e., the residual) for the higher quality calibration targets. Following the guidance of Spitz and Moreno (1996, p. 244-245) and Hill (1998), the residuals from a calibration should be normally distributed, confirming that there is no systematic bias in the model results. Where residuals do not follow a normal distribution there may be structural uncertainties in the model, which introduce a limitation to the degree of calibration that is possible. The majority of the residuals in Chart 3 approximate a straight line, following a normal distribution. Two outliers (NWC production well TW3-80 and overburden monitor MW01C-04) fall outside the normal distribution, suggesting that these observed water levels may represent small-scale geological heterogeneities. Achieving a better fit to these points may not be possible given the current model conceptualization.




Chart 3 Aberfoyle Cumulative Probability Plot of Higher Quality Targets at Aberfoyle

Chart 4 illustrates the cumulative probability distribution for the calibration targets derived from the WWIS records. Similar to the match to the higher quality targets, the majority of these residuals approximated a straight line when plotted on a normal probability axis. Some targets were identified as potential outliers (Chart 4) and, as discussed previously, these may highlight lower quality targets where there may be errors in the reported well locations and depths, errors in how the water levels were measured, and spatial differences caused by water levels that may have been collected in different years or seasons, or under different stages of pumping/non-pumping conditions.




Chart 4 Aberfoyle Cumulative Probability Plot of Lower Quality (WWIS) Targets at Aberfoyle

Table 4 summarizes the calibration statistics computed as measures of the goodness-of-fit between model-simulated and observed hydraulic heads for all calibration targets, high quality Upper and Lower Bedrock targets, overburden targets, and targets from the WWIS.

TABLE 4 Aberfoyle - Hydraulic Head Calibration Statistics

Calibration Statistic	All Targets	High Quality Upper Bedrock Targets	High Quality Lower Bedrock Targets	High Quality Overburden Targets	All High Quality Targets	WWIS Targets
Number of Calibration Targets	634	31	27	21	79	555
Mean Error (m)	2.1	0.2	1.5	-0.7	0.4	2.3
Mean Absolute Error (m)	3.2	1.7	2.4	1.0	1.8	3.4
Root Mean Squared Error (m)	4.6	2.1	3.0	1.8	2.4	4.9

The calibration statistics and results, as listed in the above table, are described as follows:

- **Mean Error.** The mean error is a measure of whether, on average, simulated water levels are higher or lower than those observed. Ideally, the mean error should be as close as possible to zero. This statistic indicates that on average, all the simulated water levels are higher than the observed values by 2.1 m. The mean error is 0.4 m for the high quality calibration targets.

- **Mean Absolute Error.** The mean absolute error is a measure of the average deviation between simulated and observed water levels. During model calibration, this statistic should be minimized as much as possible. The mean absolute error for the 634 calibration targets is 3.2 m and is equal to 1.8 m for the high quality targets.
- **Root Mean Squared Error.** The root mean squared error is similar to standard deviation in providing a measure of the degree of scatter about the 1:1 line. This statistic is calculated by averaging the squares of each residual error, and then taking the square root of that average. In squaring the residual errors, the root mean squared error gives higher weighting to larger residuals. The root mean squared error for the full calibration dataset is 4.6 m, meaning that the majority of predicted water levels would fall within 4.6 m of the observed value. The value for the high quality targets is 2.4 m.

4.1.4 Groundwater Discharge to Streams

In addition to simulated aquifer water levels and drawdown, the groundwater flow model also estimates the contribution of groundwater discharge to streams toward streamflow. Baseflow is a term given to the portion of streamflow that remains in the absence of direct overland runoff. Baseflow may be a result of groundwater discharge in addition to other contributions, such as sewage treatment plant discharges, water diversion, and the release of water from lakes, reservoirs, or wetlands. In this assessment, a key calibration assumption is that estimated stream baseflow is mostly due to groundwater discharge, and not any other factors. As discussed below, this assumption should be generally valid for Mill Creek; however, measured streamflow in Aberfoyle Creek is likely impacted by the release of water from Aberfoyle Pond.

The refined GGET Tier Three model was assessed on how well simulated groundwater discharge matched estimated baseflows. Surface water flow data from two GRCA flow gauges on Mill Creek (2GAC19 and 3AQ131; Figure 1) and two NWC surface water monitoring stations on Aberfoyle Creek (SW01 and SW02; Figure 2) were assessed for the Aberfoyle area. Baseflow estimates were derived by others using streamflow data, and provide a benchmark range against which simulated groundwater discharge can be compared. Baseflow estimates include those derived for Mill Creek during the GGET Tier Three Assessment (Matrix 2017a) and those derived by SSPA for Mill Creek and Aberfoyle Creek (SSPA 2016, Golder and SSPA 2018). Table 5 summarizes available baseflow estimates, model calibration targets, and the simulated groundwater discharge for each of the four monitoring locations. The model calibration targets for the Mill Creek gauges were selected as the range in the median baseflow values estimated from Matrix (2017a) and SSPA (2016). The model calibration targets for Aberfoyle Creek were selected as the low end of the Golder and SSPA (2018) baseflow estimate range as this range reflects streamflow measurements that include the impacts of Aberfoyle Pond and other upstream factors. The simulated groundwater discharge is based on the long-term average conditions described in Section 4.1.3.1.

TABLE 5 Aberfoyle - Summary of Estimated and Simulated Groundwater Discharge (m³/day)

Locations	Estimated Baseflow		Model Calibration Target	Simulated Groundwater Discharge
	SSPA	Matrix ¹		
Mill Creek Near Aberfoyle (GRCA Gauge 3AQ131)	17,300 ²	18,900	17,300 to 18,900	17,900
Mill Creek @ Side Rd. 10 (GRCA Gauge 2GAC19)	45,500 ²	55,500	45,500 to 55,500	40,000
Increase from 3AQ131 to 2GAC19	n/a	n/a	26,600 to 38,200	22,100
Aberfoyle Creek - SW01	5,616 to 14,861 ³	n/a	5,616	3,790 ⁴
Aberfoyle Creek - SW02	6,739 to 15,811 ³	n/a	6,739	4,593 ⁴
Increase from SW01 to SW02	n/a	n/a	1,123	803

n/a - not available

¹ Matrix (2017a).

² SSPA (2016)

³ Golder and SSPA (2018)

⁴ Discharge does not include impacts from Aberfoyle Pond and upstream confluence with Mill Creek

4.1.4.1 Results

Table 5 shows that simulated groundwater discharge was predicted to be within the estimated baseflow range provided by SSPA for gauge 2GAC19 (Mill Creek at Side Rd. 10), and less than the range from Matrix (2017a). The simulated groundwater discharge was within all estimated baseflow ranges for gauge 3AQ131 (Mill Creek near Aberfoyle).

Simulated groundwater discharge for monitoring stations along Aberfoyle Creek (SW01 and SW02) was found to be slightly under-simulated compared to the estimated baseflow counterparts. Baseflow in Aberfoyle Creek is likely an over-estimate of groundwater discharge due to the effects of Aberfoyle Pond, which contributes to baseflow by the release of surface water from storage.

4.1.5 Overall Calibration Summary

Local updates to the calibrated model in the Aberfoyle area largely included refinements of surface water boundary conditions and adjustments to hydraulic conductivity. The calibration results illustrated that:

- **Pumping conditions** - The refined model adequately approximated the trends of the interpreted drawdown contours in the Upper and Lower Bedrock aquifers as delineated using water level recovery data from a long-term pumping test at TW3-80.
- **Long-term average conditions** – The model refinements resulted in improved calibration to local conditions as compared to the GGET Tier Three Assessment. The calibration error for the high quality NWC monitoring targets is improved as compared to the WWIS calibration targets used for the GGET Tier Three Assessment. The results indicate that the model is reflective of groundwater flow conditions in the local Aberfoyle area as well as in the regional area.

- **Streamflow/groundwater discharge** - Simulated groundwater discharge was slightly less than estimated baseflow targets for Aberfoyle Creek but acceptable given that baseflow estimates are not exact representations of groundwater discharge. The results suggest that the overall water balance within the assessment area as reflected by groundwater recharge and discharge is reasonable.

The results suggest that the updated model appropriately represents the hydrogeologic conditions in the area of NWC TW3-80, and is suitable for the assessment of future pumping scenarios.

4.2 Erin

Calibration in the Erin area consisted of local and regional refinements to zones of hydraulic conductivity in different hydrostratigraphic units during calibration to average non-pumping and pumping conditions at NWC well TW1-88.

4.2.1 Hydraulic Conductivity

Similar to the updates made in the Aberfoyle area, hydraulic conductivity values in the Erin area were refined during model calibration, and the final values assigned were guided by the range of hydraulic conductivity and transmissivity estimates from other studies (e.g., Matrix 2017a, Terraqua 1991, CRA 1989; and Blackport [Pers. Comm. 2018]) and references therein. In some cases, refinements to hydraulic conductivity were made as surrogate to making refinements to modelled hydrostratigraphic unit surface elevations and thicknesses. The final calibrated range of revised hydraulic conductivity values applied to the update areas in each hydrostratigraphic unit is presented in Table 6, along with the ranges used prior to the update and values estimated from field data. The refined hydraulic conductivity values applied in the model for the Guelph Formation were very close to the estimated ranges derived from local and regional estimates (Table 6). Conductivity values applied in the overburden and contact zone units were generally higher than the estimates available from field data; however, field estimates were based on a limited number of data points. The final values applied are still considered reasonable when compared to typical ranges of conductivity for similar materials cited in literature (Freeze and Cherry 1979). Figures B8 to B11 (Appendix B) present the final conductivity values applied for zones that were updated in each hydrostratigraphic unit of the model. No updates were made to the hydraulic conductivity values for the model layers representing the Vinemount Member (Layer 11), or Gasport (Layer 12 and 13) and Cabot Head (Layer 14) formations. Changes included the following:

- The creation of a relatively low conductivity zone within the coarse-grained overburden unit north of the NWC site, and a conductivity zone to the south where vertical conductivity was decreased. The conductivity of zones representing finer-grained tills outcropping in the coarser deposits were refined to be consistent values both north and south of the site (Layer 1 and 2; Figure B8).

- The creation of a relatively lower conductivity northern zone and relatively higher conductivity southern zones in the till overburden (Layer 3; Figure B9).
- The creation of three conductivity zones within the contact zone aquifer unit where conductivity was decreased to the north and increased to the south. The conductivity of a smaller local zone was increased just south of the Erin site (Layer 4; Figure B10).
- The creation of four conductivity zones within the Guelph Formation where conductivity was increased to varying amounts (Layer 5 to 10; Figure B11).

TABLE 6 Erin - Summary of Hydraulic Conductivity Changes

Model Layer(s) ¹	Unit	Previous Calibrated Hydraulic Conductivity of Update Areas (m/s)		Revised Calibrated Hydraulic Conductivity of Update Areas (m/s)		Estimates of Horizontal Hydraulic Conductivity from Field Data (m/s) ²	
		Min	Max	Min	Max	Min	Max
1-2	Overburden A (Coarser-grained)	Kx = 1×10^{-4} Kz = 1×10^{-4}	Kx = 5×10^{-4} Kz = 5×10^{-4}	Kx = 1×10^{-4} Kz = 1×10^{-5}	Kx = 5×10^{-4} Kz = 5×10^{-5}	Kx = 2×10^{-6}	Kx = 6×10^{-6}
3	Overburden B (Finer-grained)	Kx = 1×10^{-6} Kz = 3×10^{-8}	Kx = 3×10^{-5} Kz = 3×10^{-6}	Kx = 6×10^{-8} Kz = 6×10^{-9}	Kx = 1×10^{-5} Kz = 5×10^{-6}	Kx = 7×10^{-8}	Kx = 5×10^{-7}
4	Contact Zone	Kx = 3×10^{-5} Kz = 3×10^{-6}		Kx = 1×10^{-5} Kz = 1×10^{-6}	Kx = 5×10^{-4} Kz = 5×10^{-5}	Kx = 2×10^{-6}	
5-10	Guelph Fm.	Kx = 2×10^{-7} Kz = 2×10^{-9}	Kx = 5×10^{-6} Kz = 2×10^{-7}	Kx = 6×10^{-6} Kz = 6×10^{-7}	Kx = 8×10^{-4} Kz = 8×10^{-5}	Kx = 4×10^{-7}	Kx = 6×10^{-4}

¹ No hydraulic conductivity changes made to model layer 11 (Vinemount Member), 12 and 13 (Gasport Fm.), and 14 (Cabot Head Fm.)

² From Matrix (2017a), Terraqua (1991), CRA (1989) and (Blackport 2018, Pers. Comm.)

Kx - Horizontal Hydraulic Conductivity

Kz - Vertical Hydraulic Conductivity

4.2.2 Calibration to Pumping Conditions

4.2.2.1 Approach

Calibration to pumping conditions at the Erin site was completed using the 2016 to 2017 average pumping and non-pumping water level data available from the annual monitoring program. SSPA used these data to estimate drawdown at monitoring wells where there was a clear pumping and non-pumping trend. SSPA estimated drawdown for the remainder of the monitoring wells using drawdown data from a constant rate test conducted in 2005 (CRA 2006, Neville 2018, Pers. Comm.). This was completed by linearly scaling the observed drawdown based on the difference between the pumping rate during the constant rate test and the average daily pumping rate estimated during 2016 to 2017. In total, 18 drawdown calibration targets for the overburden (8) and bedrock (10) monitoring wells were provided. A list of these targets is provided in Appendix A (Table A2).

The calibration approach consisted of estimating simulated drawdown by subtracting water levels between two steady-state conditions: no pumping of TW1-88, and pumping at 890 m³/day. This pumping rate was developed by SSPA, using an average (2016 to 2017) daily pumping rate of

195 m³/day, and estimating that this average represents pumping TW1-88 for 5.3 hours at a rate of 890 m³/day, followed by recovery (Neville 2018, Pers. Comm.). The simulated drawdown was then compared to the observed drawdown targets, and the difference between the two was minimized during the calibration process.

4.2.2.2 Results

The observed and simulated drawdown values for each of the monitoring points are provided in Table A2 (Appendix A). The simulated drawdown at pumping well TW1-88 was 7.49 m, which is 1.09 m larger than the observed drawdown of 6.40 m. The simulated drawdowns at the remaining monitoring wells were within ± 0.5 m of those observed for the bedrock and overburden targets. These results suggest a good fit between observed and simulated values.

An aerial map showing the interpolated simulated drawdown contours for the Guelph Formation Aquifer is provided on Figure 13 to view the simulation results spatially. The figure shows drawdown extending radially away from the pumping well, in a slightly northwesterly direction that is consistent with a simulated regional gradient from the northwest to south and south east (Figure 9).

4.2.3 Calibration to Long-term Non-pumping Conditions

4.2.3.1 Approach

Steady-state calibration to long-term average conditions was completed using groundwater level monitoring data collected as part of the annual monitoring program at the Erin site (Golder 2018b). SSPA used these data to estimate average water levels for the period of 2016 to 2017 when well TW1-88 was not pumping and when it was pumping. Inferred non-pumping data were used as steady-state calibration targets in the Tier Three model where they were available. In total, 25 water level targets were provided for monitoring wells completed in the overburden (11) and bedrock (14). Of these water levels, three non-pumping average water levels were inferred from the available data. A single average water level was reported for the remainder of the wells where it was not possible to infer separate non-pumping versus pumping conditions due to NWC pumping. While it is uncertain whether these water levels explicitly represent pumping or non-pumping conditions, they were used for calibrating to non-pumping conditions in the absence of other high quality data onsite. Well completion elevation details were used to assign water level targets to hydrostratigraphic units under the revised conceptualization in the model where the unit was not already identified by SSPA. Table 2 was also used to guide calibration target assignment where necessary in the model.

Water level calibration targets used in the GGET Tier Three Assessment and derived from the WWIS were used as additional calibration targets for the Erin area to increase the coverage of the calibration area. In total, 289 targets (i.e., 278 in bedrock and 11 in overburden) from the GGET Tier Three Assessment were used, covering a 3 km radius surrounding the Erin site, with additional targets located further upgradient, toward the northwest. Similar to what was described for the WWIS targets near

Aberfoyle (Section 4.1.3.1), the uncertainty of individual groundwater elevation estimates as calculated from the WWIS dataset may have an average error, or uncertainty, of 5 to 10 m as compared to actual conditions. Because of these uncertainties, the water level targets derived from WWIS data are considered lower quality than those from annual NWC monitoring activities.

A list of the calibration targets used in the Erin area is provided in Appendix A (Table A2).

4.2.3.2 Results

The steady-state calibration to long-term average, non-pumping conditions at NWC TW1-88 involved comparing simulated hydraulic heads against those measured in both higher-quality and lower-quality wells completed within overburden and bedrock units. The scatter plot used to visualize the goodness-of-fit for these hydraulic head targets is presented on Chart 5, and a table of the observed and simulated values are provided in Appendix A (Table A2).

The scatter plot shows that the majority of the simulated hydraulic heads are within the ± 5 m bounds. Further, the calibration error is generally distributed both above and below the 1:1 line.




Chart 5 Erin Scatter Plot of Average Hydraulic Head ($0 \text{ m}^3/\text{day}$ NWC Pumping)

Table 7 lists the calibration statistics that are computed as measures of the goodness-of-fit between model-simulated and observed hydraulic heads for all calibration targets, higher quality bedrock and overburden targets, and targets from the WWIS. Definitions for each calibration statistic can be found in Section 4.1.3.2. The calibration statistics are typical of a regional groundwater flow model and the calibration to higher quality bedrock and overburden monitoring wells onsite is slightly improved over the calibration to water levels from WWIS wells (Table 7).

TABLE 7 Erin - Hydraulic Head Calibration Statistics

Calibration Statistic	All Targets	High Quality Bedrock Targets	High Quality Overburden Targets	WWIS Targets
Number of Calibration Targets	314	14	11	289
Mean Error (m)	0.1	-0.2	-0.7	0.2
Mean Absolute Error (m)	4.5	2.9	2.8	4.6
Root Mean Squared Error (m)	5.8	4.0	4.3	5.9

4.2.4 Groundwater Discharge to Streams

Surface water spotflow data from two NWC surface water monitoring stations along a tributary to the Eramosa River (SW1 and SW3; Figure 3) were used to qualitatively assess simulated groundwater discharge in the Erin area. While baseflow estimates have not been derived for these locations, the estimated average spotflows as calculated using 2017 monthly manual flow measurements (Golder 2018b) provide rough estimates for relative magnitude of what the baseflow/groundwater discharge could look like. Table 8 summarizes the average spotflow measurements at NWC stations SW1 and SW3, and the simulated groundwater discharge for each of these monitoring locations. The simulated groundwater discharge is within the range of spotflow measurements at SW1 and SW3 and similar in magnitude to the average values. The simulated groundwater discharge is based on long-term climate conditions, while the spotflow measurements reflect single points in time during 2017.

TABLE 8 Erin - Summary of Estimated and Simulated Groundwater Discharge (m³/d)

Locations	Range of 2017 Spotflow Measurements	Average 2017 Spotflow Measurement ¹	Simulated Groundwater Discharge
SW1	1,218 to 4,260	2,271	1,900
SW3	354 to 2,160	1,113	1,724

¹ Estimated using 2017 monthly manual spotflow measurements (Golder 2018b)

4.2.5 Overall Calibration Summary

Local updates to the calibrated model in the Erin area largely included refinements of surface water boundary conditions and adjustments to hydraulic conductivity. The calibration results illustrated that:

- **Pumping conditions** - Simulated drawdown at non-pumping monitoring wells were within ± 0.5 m of the observed drawdown targets measured in bedrock and overburden wells.
- **Long-term average, non-pumping conditions** - The model refinements resulted in improved calibration to local conditions as compared to the GGET Tier Three Assessment. The calibration error for the high quality NWC monitoring targets is slightly improved as compared to the WWIS calibration targets used for the GGET Tier Three Assessment. The results indicate that the model is reflective of groundwater flow conditions in the local area as well as in the regional area.

- **Streamflow/groundwater discharge** - Simulated groundwater discharge was similar to the estimated 2017 average spotflow measurements at two surface water monitoring stations, suggesting that the overall water balance within the assessment area as reflected by groundwater recharge and discharge is reasonable.

The results suggest that the updated model appropriately represents the hydrogeologic conditions in the area of NWC TW1-88, and is suitable for the assessment future pumping scenarios.

5 MODEL SCENARIOS

The Tier Three model was updated and calibrated locally in the Aberfoyle and Erin areas to better reflect the high-quality data collected from long-term annual monitoring and from a long-term pumping test. The model reflects local groundwater flow under long-term average pumping conditions (Aberfoyle) or non-pumping conditions (Erin), as well as higher rate pumping conditions (Aberfoyle and Erin). As a result, the model is an appropriate tool to estimate the general effects of changes in pumping. The following sections describe the application of the refined model to assess potential changes in groundwater levels and groundwater discharge due to future pumping at the NWC Aberfoyle and Erin sites, as well as potential effects considering drought and climate change. Section 5.1 provides a description of the predictive scenarios, and Sections 5.2 and 5.3 summarize the results for the Aberfoyle and Erin sites, respectively.

5.1 Scenario Descriptions

Nine predictive scenarios were developed to compare and assess the potential impacts and cumulative effects associated with NWC pumping. These scenarios assess long-term average conditions, historical climate and drought conditions, and climate change. They are summarized in Table 9, and additional details are presented in the following subsections.

TABLE 9 Scenario Summary

Scenario	Assessment	NWC Pumping Rate	Climate Time Period	Climate Change Scenario	Model Simulation
1 (Baseline Average)	Long-term Average	Average TW3-80 = 2,113 m ³ /day TW1-88 = 207 m ³ /day	Long-term Average	n/a	Steady-state
2	Long-term Average	Maximum Permitted TW3-80 = 3,600 m ³ /day TW1-88 = 1,113 m ³ /day	Long-term Average	n/a	Steady-state
3 (Baseline Transient)	Historical Climate Variability and Drought	Average TW3-80 = 2,113 m ³ /day TW1-88 = 207 m ³ /day	1960 to 2005	n/a	Transient
4	Historical Climate Variability and Drought	Maximum Permitted TW3-80 = 3,600 m ³ /day TW1-88 = 1,113 m ³ /day	1960 to 2005	n/a	Transient
5a	Climate Change	Average TW3-80 = 2,113 m ³ /day TW1-88 = 207 m ³ /day	1960 to 2005	1	Transient
5b				2	
5c				3	
5d				4	

n/a - not applicable

5.1.1 Scenario 1 - Current Average NWC Pumping (Baseline Average Conditions, Steady-state)

Scenario 1 is the baseline steady-state scenario designed to reflect current, long-term average conditions. The assumptions in this scenario included the following:

- Average (2015-2017) NWC pumping rate at TW3-80 (2,113 m³/day).
- Average (2015-2017) NWC pumping rate at TW1-88 (207 m³/day).
- Average municipal pumping rates, consistent with the existing rates used in the GGET Tier Three Assessment scenarios (Matrix 2017a).
- Non-municipal pumping rates, consistent with those used in the GGET Tier Three Assessment (Matrix 2017a) and updated as part of the *Guelph-Guelph/Eramosa Water Quantity Policy Development Study* (Matrix 2018b).
- Average groundwater recharge rates in the Grand River Watershed estimated from a 45-year surface water modelling scenario (1961 to 2005; Matrix 2017a). Average groundwater recharge rates in the Credit River Watershed were provided by AquaResource (2009c) and recharge within the Halton and Hamilton Region Conservation Authorities was reported in Earthfx (2009).

5.1.2 Scenario 2 - Maximum Permitted NWC Pumping (Steady-state)

Scenario 2 was designed to show long-term average conditions considering the same steady-state model setup described for Scenario 1, except for the following assumptions:

- Maximum permitted NWC pumping rate at TW3-80 (3,600 m³/day).
- Maximum permitted NWC pumping rate at TW1-88 (1,113 m³/day).

5.1.3 Scenario 3 - Current Average NWC Pumping (Baseline Conditions, Transient)

Scenario 3 is the transient baseline scenario designed to test the response of the system with current average NWC pumping rates, under typical climate variability, and a severe drought represented by the driest period observed in the local contemporary climate record. This drought period was observed locally in the 1960s. The variability of groundwater recharge rates over the simulation period reflects actual historic conditions and is therefore a suitable surrogate for future climate variability. The results of the scenario are hypothetical, as NWC has only been pumping since 2000 (Erin) and 2001 (Aberfoyle).

The setup of this scenario included the following:

- Average (2015-2017) NWC pumping rate at TW3-80 (2,113 m³/day).
- Average (2015-2017) NWC pumping rate at TW1-88 (207 m³/day).
- Average municipal pumping rates, consistent with the existing rates used in the GGET Tier Three Assessment scenarios (Matrix 2017a).
- Non-municipal pumping rates, consistent with those used in the GGET Tier Three Assessment (Matrix 2017a) and updated as part of the *Guelph-Guelph/Eramosa Water Quantity Policy Development Study* (Water Quantity Policy Study; Matrix 2018b).
- Transient historical climate variability and drought conditions represented by estimated monthly recharge (1960 to 2005). This model input was generated using Guelph All-Weather Sequential-Events Runoff (GAWSER) as part of the climate change component of the Water Quantity Policy Study as documented in Matrix (2018a).
- Transient monthly municipal pumping from the Eramosa River and into the Arkell Artificial Recharge System (1960 to 2005). This model input was generated using GAWSER as part of the climate change component of the Water Quantity Policy Study as documented in Matrix (2018a).

5.1.4 Scenario 4 - Maximum Permitted NWC Pumping (Transient)

Scenario 4 was designed to show historical climate variability and drought conditions, considering the same transient setup described for Scenario 3a, except for the following:

- Maximum permitted NWC pumping rate at TW3-80 (3,600 m³/day).
- Maximum permitted NWC pumping rate at TW1-88 (1,113 m³/day).

5.1.5 Scenario 5 - Current Average NWC Pumping with Climate Change Projections (Transient)

Scenario 5 represents a set of four climate change scenarios (i.e., 5a, 5b, 5c, and 5d) that use the methodology developed for the climate change assessment completed for the GGET municipal water supply systems (Matrix 2018a).

The primary tools used to estimate future climate are Global Climate Models (GCMs). GCMs are complex, physically-based, three-dimensional models that represent the earth's atmosphere, oceans, and land surfaces and simulate, over several decades, the interactions of processes that determine the climate for an area. These tools have evolved since the 1970s to their present level of sophistication. Modelling centres around the world have developed numerous GCMs used for long-term simulations to characterize the evolution of temperature, precipitation, solar radiation, winds, and other parameters well into the future.

There are many uncertainties in future climate predictions relating to unknown future emissions of greenhouse gases and aerosols, the conversion of emissions to atmospheric gases, modelling the response of the climate system, and methods for downscaling GCMs to be representative of local climates. As a result, uncertainties will remain inherent in predicting the hydrologic and hydrogeologic response to future climate change.

Figure 14 illustrates a scatter plot of simulated annual mean change in temperature and precipitation for the 2041-2070 period (2050s), as compared to the 1981-2010 period (current) for the results of 57 GCM scenarios in the Guelph area. This figure displays the level of uncertainty among GCM models as mean annual temperatures range from +1.7 to +4.6 °C, while annual precipitation changes range from -4 to +20%.

EBNFLO and AquaResource (2010) recommends that practitioners evaluate potential climate change impacts using a large number of future climate scenarios to reflect the uncertainty that exists in individual model results; however, it is not generally feasible to evaluate all of the GCMs available. EBNFLO and AquaResource (2010) describe the 'Percentiles' method used to select a subset of individual GCM results, followed by the application of the 'Change Field' method to estimate climate change impacts using traditional hydrologic methods. Figure 14 illustrates a set of ten individual scenarios

(orange squares) selected for the assessment completed for GGET (Matrix 2018a), and a smaller set of four scenarios (circled squares) selected for the groundwater modelling assessment.

The change field method is a methodology for estimating future local climate datasets from larger scale GCM results. This method uses the GCM simulations to estimate monthly changes for each climate variable for a future time period relative to a baseline climate period. These relative changes, termed 'change fields', are used to adjust observed climate station data time series to reflect future conditions. This approach results in an altered input climate time series that reflects the average relative change in each parameter and, through the use of local observations, the local climate. Matrix (2018a) describes the application of the Grand River hydrology model, GAWSER, to estimate the hydrologic response to the future climate datasets developed using the 'change field' method and the selected GCM results.

Figure 15 illustrates average daily groundwater recharge rates for each month for a silty sand soil in the Guelph area for the four selected future climate scenarios. Each future climate scenario was developed by adjusting the 1950-2005 existing climate dataset by the 2050's change fields for that scenario. The average daily recharge rate for a given month represents the GAWSER-predicted daily recharge averaged over all days of that month for the entire GAWSER model simulation. As shown on this figure, the average daily rate predicted for the future climate scenarios is higher than baseline conditions during the months of December through March; this is a result of having less frozen soil and increased precipitation. Groundwater recharge during the summer months is generally less than baseline conditions and similar to baseline during spring and fall.

The climate change assessment was completed with the following steps:

1. Select GCMs encompassing the range in projected changes in climate for the 2050s period. There is a great deal of uncertainty in making projections of future climates, and it is common practice to assess impacts of climate change using multiple future climate datasets to reflect the range of variability in potential future conditions.
2. Create a 45-year dataset of hourly temperature and precipitation projections (2050s) for each of the GCMs using the 'change field' methodology further described in Matrix 2018a.
3. Create a 45-year time series of groundwater recharge projections (2050s) for each of the GCMs using the temperature and precipitation datasets, and the GAWSER hydrology model.
4. Run the GGET Tier Three groundwater flow model to simulate groundwater levels and groundwater discharge for each of the 2050s groundwater recharge scenarios.

Scenarios 5a, 5b, 5c, and 5d are four 45-year scenarios, each representing a future (2050s) climate projection from a different GCM. These scenarios include the following assumptions:

- Average (2015 to 2017) NWC pumping rate at TW3-80 (2,113 m³/day).

- Average (2015 to 2017) NWC pumping rate at TW1-88 (207 m³/day).
- Average municipal pumping rates, consistent with the existing rates used in the GGET Tier Three Assessment scenarios (Matrix 2017a).
- Non-municipal pumping rates, consistent with those used in the GGET Tier Three Assessment (Matrix 2017a) and updated as part of the Water Quantity Policy Study (Matrix 2018b).
- A 45-year transient monthly recharge time series representing a prediction of future climate made by a GCM for the 2050s period.
- Transient monthly municipal pumping from the Eramosa River and into the Arkell Artificial Recharge System (1960 to 2005), adjusted to incorporate the effects of climate change.

5.2 Scenario Results - Aberfoyle

All predictive scenarios were assessed based on simulated changes in water levels and groundwater discharge with respect to current average NWC pumping conditions (i.e., 2015 to 2017). In the Aberfoyle area, simulated impacts to water levels were assessed locally on the NWC property at monitoring well MW2A-07, at the nearest City of Guelph municipal bedrock well (the Burke Well), and also assessed more regionally within the Upper and Lower Bedrock aquifers. Simulated impacts to groundwater discharge were assessed at GRCA gauge 2GAC19 (Mill Creek at Side Rd. 10). Selection of this gauge to evaluate changes in surface water was agreed upon between Ministry of the Environment, Conservation and Parks and NWC.

5.2.1 Steady-state Scenario Results

The steady-state scenario results include the simulated average additional drawdown and groundwater discharge associated with the increase in pumping from the current average NWC pumping rate (Scenario 1) to the maximum permitted NWC pumping rate (Scenario 2).

Figures 16, 17, and 18 show the predicted additional drawdown within the simulated Upper and Lower Bedrock Aquifer layers due to increased pumping. The drawdown contours extend in a north to south direction, from MW07-08 to just south of the NWC property for all three figures. The shape of the drawdown contours change with depth, from an elongated shape in the Reformatory Quarry Member (Figure 16) to a slightly wider, oval shape in the Middle Gasport Formation (Figure 18). The maximum extent of the largest 1 m drawdown contour for all three figures is from approximately 1.2 km to the northwest, and approximately 500 m to the southeast.

Locally, the simulated drawdown associated with increasing pumping from average NWC rates to permitted NWC rates was predicted to be 3.7 m in the Lower Bedrock Aquifer at the closest

non-pumping monitoring well on the NWC Aberfoyle property (MW2A-07). Drawdown at the closest City of Guelph municipal well, the Burke Well (Figure 19), was estimated to be less than 2 cm.

Groundwater discharge at GRCA gauge 2GAC19 (Mill Creek at Side Rd. 10; Figure 19) in Scenario 1 to 2 is predicted to decrease by 3%, from 39,544 m³/day to 38,271 m³/day due to the increase in pumping (Table 10).

TABLE 10 Aberfoyle Simulated Groundwater Discharge - Average NWC Pumping to Permitted NWC Pumping

Location	Simulated Groundwater Discharge (m ³ /day)		Change in Groundwater Discharge (m ³ /day)	Change in Groundwater Discharge (%)
	Average NWC Pumping (Scenario 1)	Permitted NWC Pumping (Scenario 2)		
Mill Creek at Side Rd. 10 - 2GAC19	39,544	38,273	-1,271	-3%

5.2.2 Drought Scenario Results

The drought scenario results include the simulated transient impacts to water levels and groundwater discharge associated with the increase in pumping from average NWC rates (Scenario 3) to permitted NWC rates (Scenario 4), while considering a 45-year climate record (1960 to 2005) that includes drought periods (e.g., the 1960s).

Figures 20 and 21 show the predicted water level variability on NWC property at MW2A-07 and at the Burke municipal well, respectively over the 45-year record. At MW2A-07, water levels are predicted to vary within approximately 0.75 m over the course of the 45-year record. The results indicate that bedrock water levels at or near the NWC property are not significantly impacted by climate variability. Further, additional water level decline associated with increased pumping is predicted to be approximately 3.75 m (Figure 20), which is considerably greater than the impact of climate variability.

In comparison to the NWC property, water levels at the Burke Well (Figure 21) are predicted to be more sensitive to climate variability. Water levels at the Burke Well are predicted to decline by approximately 3 m during the drought period, which is much greater than any potential impact from increased pumping by NWC.

Simulated groundwater discharge variability at Mill Creek at the Side Rd. 10 gauge (2GAC19) is shown on Figure 22 as a time series, and Figure 23 as ranked duration curves for average (Scenario 3) and permitted (Scenario 4) NWC pumping rates. Figure 22 shows simulated groundwater discharge ranging from approximately 7,000 m³/day (during the 1960s drought) to 87,000 m³/day, and a minimal difference between the simulated groundwater discharge between average NWC pumping and permitted NWC pumping. When that same data are graphed as ranked duration curves (Figure 23), the differences between the simulated groundwater discharge of Scenarios 3 and 4 are easier to visualize.

These differences are summarized in Table 11, where the results are grouped into three classifications where groundwater discharge is exceeded 20%, 50%, and 80% of the time. Table 11 summarizes that groundwater discharge is predicted to be decreased by 3% at the 20% and 50% levels, and by 6% at the 80% level.

TABLE 11 Aberfoyle Simulated Groundwater Discharge Ranked Duration Analysis - Average NWC Pumping to Permitted NWC Pumping

Location	% Time where Groundwater Discharge was Equalled or Exceeded	Simulated Groundwater Discharge (m ³ /day)		Change in Groundwater Discharge (m ³ /day)	Change in Groundwater Discharge (%)
		Average NWC Pumping (Scenario 3)	Permitted NWC Pumping (Scenario 4)		
Mill Creek at Side Rd. 10 - 2GAC19	20	53,696	52,206	-1,490	-3%
	50	38,423	37,082	-1,341	-3%
	80	24,992	23,532	-1,460	-6%

5.2.3 Climate Change Scenario Results

The future climate change scenarios reflect an increase in groundwater recharge rates as compared to historical climate conditions (Figure 15). Figure 24 illustrates an increased range of groundwater elevations predicated at MW2A-07 under the future climate scenarios as compared to the historical climate. The average increase in groundwater elevation is on the order of 0.10 m, which is relatively small when compared to the decrease in groundwater levels associated with increased NWC pumping to the maximum permitted rate (Scenario 4).

The future climate change simulations predict that groundwater levels at the City of Guelph Burke Well will increase by 0.5 m to 1.5 m as compared to historical climate (Figure 25). This increase in groundwater levels is higher than at MW2A-07, as the Burke Well water levels reflect shallower groundwater, and a greater connection to shallow overburden and changes in groundwater recharge.

Figure 26 illustrates that groundwater discharge into Mill Creek, as simulated at the Sideroad 10 gauge (2GAC19), may increase considerably in the future climate. This increase in groundwater discharge is much greater than the anticipated decrease in groundwater discharge in response to an increase in NWC pumping to the maximum permitted rate. The increased discharge is more prominent during the January-June period, and as discussed previously, this is due to greater amounts of precipitation in the winter, less frozen ground, and greater groundwater recharge rates.

5.3 Scenario Results - Erin

In the Erin area, simulated impacts to water levels were assessed locally on the NWC property at monitoring well MW05A-05, at the nearest municipal wells (Hillsburgh Well 2 and 3), and also assessed more regionally within the bedrock aquifer. Simulated impacts to groundwater discharge were assessed at NWC surface water monitoring station SW1.

5.3.1 Steady-state Scenario Results

Figure 27 shows the predicted additional drawdown in the Guelph Formation due to the increase in pumping from average NWC pumping (Scenario 1) to permitted NWC pumping (Scenario 2). The contours extend away from pumping well TW1-88 in a radial fashion, with a slight preferred orientation toward the northwest.

Locally, the simulated additional drawdown associated with increasing pumping from average NWC rates to permitted NWC rates was predicted to be 4.1 m at the closest non-pumping monitoring well on the NWC Erin property (MW05A-05). The additional simulated drawdown was predicted to be 0.3 m at both Hillsburgh municipal wells (Figure 28).

Groundwater discharge at NWC surface water monitoring station SW1 (Figure 27) in Scenarios 1 and 2 was simulated to decrease by 3%, from 1,880 m³/day to 1,822 m³/day due to the increase in pumping (Table 12).

TABLE 12 Erin Simulated Groundwater Discharge - Average NWC Pumping to Permitted NWC Pumping

Location	2017 Observed Flow ¹ (m ³ /day)	Simulated Groundwater Discharge (m ³ /day)		Change in Groundwater Discharge (m ³ /day)	Change in Groundwater Discharge (%)
		Average NWC Pumping (Scenario 1)	Permitted NWC Pumping (Scenario 2)		
Downstream of Onsite Pond - SW1	1,218 to 4,260	1,880	1,822	-58	-3%

¹ Range from Golder (2018b)

5.3.2 Drought Scenario Results

Figures 29, 30, and 31 show the predicted water level variability at NWC monitoring well MW05A-05, and Hillsburgh Well 2 and 3, respectively, over the 45-year record for average NWC pumping (Scenario 3) and permitted NWC pumping (Scenario 4). At MW05A-05, water levels are predicted to vary by up to 3 m over the 45-year record, with the lowest level predicted during the drought of the 1960s (Figure 29). Water levels decline during this time by a magnitude of approximately 1.25 m. The additional water level decline associated with increased pumping from average to permitted NWC rates is predicted to be approximately 4 m (Figure 29).

Water levels at the Hillsburgh Well 2 and 3 (Figures 30 and 31) are predicted to vary by more than 4 m in response to normal climate variability over the 45-year record. If drought conditions similar to those observed in the 1960s were to reoccur, water levels are predicted to decline by approximately 2.3 m. Finally, the additional water level decline at the Hillsburgh Well 2 and 3 associated with increased NWC pumping is predicted to be 0.3 m to 0.4 m on average over the 45-year time frame.

Simulated groundwater discharge variability at the surface water monitoring station SW1 is shown on Figure 32 as a time series, and Figure 33 as ranked duration curves for average (Scenario 3) and permitted (Scenario 4) NWC pumping rates. Figure 32 shows simulated groundwater discharge ranging from less than 1,200 m³/day during the 1960s drought, to a maximum of almost 2,900 m³/day. A minimal difference exists between the simulated groundwater discharge between average NWC pumping and permitted NWC pumping. These differences are examined closer using the ranked duration curves of Figure 33 and the analysis shown in Table 13. Here groundwater discharge is predicted to decrease by 3% at the 20% and 50% levels, and decrease by 4% at the 80% level.

TABLE 13 Erin Simulated Groundwater Discharge Ranked Duration Analysis - Average NWC Pumping to Permitted NWC Pumping

Location	% Time where Groundwater Discharge was Equalled or Exceeded	Simulated Groundwater Discharge (m ³ /day)		Change in Groundwater Discharge (m ³ /day)	Change in Groundwater Discharge (%)
		Average NWC Pumping (Scenario 3)	Permitted NWC Pumping (Scenario 4)		
Downstream of Onsite Pond - SW1	20	2,195	2,130	-65	-3%
	50	1,871	1,814	-58	-3%
	80	1,600	1,542	-57	-4%

5.3.3 Climate Change Scenario Results

Similar to the Aberfoyle site, the future climate change scenarios for the Erin site reflect an increase in groundwater recharge rates as compared to historical climate conditions. Figure 34 illustrates an increased range of groundwater elevations predicated at MW5A-05 under the future climate scenarios as compared to the historical climate. The average increase in groundwater elevation is on the order of 0.50 m, which is relatively small when compared to the decrease in groundwater levels associated with increased NWC pumping to the maximum permitted rate (Scenario 4).

The future climate change simulations predict that groundwater levels at Hillsburgh Well 2 and 3 will increase between approximately 0.2 m to 1.8 m as compared to historical climate (Figure 35 and 36).

Figure 37 illustrates that groundwater discharge into an unnamed headwater tributary to the Eramosa River, as simulated at SW1, may increase in the future climate. This increase in groundwater discharge is greater than the anticipated decrease in groundwater discharge in response to increased NWC pumping at the maximum permitted rate. The increased discharge is more prominent during the January-June period, and as discussed previously, this is due to greater amounts of precipitation in the winter, less frozen ground, and greater groundwater recharge rates.

6 CLOSURE

The groundwater flow model developed for the GGET Tier Three Assessment was refined and applied in the areas of NWC's Aberfoyle and Erin water bottling operations to assess potential cumulative effects associated with NWC's permitted takings. The work was completed in response to the Interim Procedural and Technical Guidance Document for Bottle Water Renewals (MOECC 2017) that requires an assessment of cumulative effects of renewed water bottling takings using the highest tier water budget completed under the *Clean Water Act*.

The Tier Three model was refined in the areas of the Aberfoyle and Erin NWC properties, calibrated to water levels under long-term average and pumping conditions, and was shown to adequately represent the hydrogeologic conditions in these areas. The model was applied to predict the potential impacts of NWC takings on local groundwater levels, on groundwater levels at municipal wells, and on groundwater discharge to surface water features. These impacts were assessed under steady-state (long-term average) and transient (time-varying) conditions, while considering current climate, drought periods, and the potential impacts due to climate change.

The results of the model scenarios completed in this assessment indicate the following:

- Increasing the pumping rates at the NWC Aberfoyle and Erin facilities from current rates to permitted rates will not affect groundwater levels at the closest City of Guelph municipal well (Burke Well) and will have minimal impact to groundwater levels at the Hillsburgh municipal wells.
- Increasing the pumping rate at NWC Aberfoyle and Erin facilities from current rates to permitted rates will result in a 3% reduction in groundwater discharge to the identified surface water features.
- The future climate change scenarios result in greater amounts of groundwater recharge and increased groundwater elevations and groundwater discharge to surface water features.

The modelling results presented in this report are based on the modelling approach employed for the GGET Tier Three Assessment (Matrix 2017a) and Assessment of Climate Change in Support of the Guelph-Guelph/Eramosa Water Quantity Policy Study (Matrix 2018a), and represents the state of the practice at the time of this assessment. This report describes modifications made to the Tier Three model based on data provided by NWC and is assumed correct. The results of the model scenarios reflect the current scientific understanding, but are uncertain due to limitations of data and scientific characterization reflected in the model. It is recommended that the numerical model employed to complete this assessment be updated in the future to reflect new data or if observed conditions change as compared to those represented in this assessment.

7 REFERENCES


- AquaResource Inc. (AquaResource). 2009a. *Integrated Water Budget Report, Grand River Watershed*. Prepared for Grand River Conservation Authority. June 2009.
- AquaResource Inc. (AquaResource). 2009b. *Tier 2 Water Quantity Stress Assessment Report, Grand River Watershed*. Prepared for the Grand River Conservation Authority. December 2009.
- AquaResource Inc. (AquaResource). 2009c. *Integrated Water Budget Report - Tier 2, Credit Valley Source Protection Area*. Prepared for Credit Valley Conservation Authority. April 2009.
<https://ctcswp.ca/technical-docs/#1496857206673-baff4eda-f5c3>
- Blackport R (2018). Personal Communication. Meeting. May 14, 2018.
- Brunton F.R. 2009. "Update of Revisions to the Early Silurian Stratigraphy of the Niagara Escarpment: Integration of Sequence Stratigraphy, Sedimentology and Hydrogeology to Delineate Hydrogeologic Units." In: *Summary of Field Work and Other Activities 2009*. Ontario Geological Survey. Open File Report 6240. 25-1 to 25-20.
- Conestoga-Rovers and Associates (CRA). 2014a. *2013 Annual Monitoring Report Nestlé Erin Site, Town of Erin, Ontario*. Prepared for Nestlé Waters Canada. Guelph, Ontario.
- Conestoga-Rovers and Associates (CRA). 2014b. *2013 Annual Monitoring Report, Nestlé Waters Canada*. Guelph, Ontario.
- Conestoga-Rovers and Associates (CRA). 2011. *2010 Annual Monitoring Report*. Prepared for Nestlé Waters Canada. Guelph, Ontario. January 2011.
- Conestoga-Rovers and Associates (CRA). 2006. *Test Pumping Investigation Supply Well TW1-88*. Prepared for Nestlé Waters Canada. Town of Erin, Ontario. February 2006.
- Conestoga-Rovers and Associates (CRA). 1989. *Well Construction and Testing Investigation*. Township of Erin. January 1989.
- Diersch H-J. G. 2014. *FEFLOW Finite Element Modeling of Flow, Mass and Heat Transport in Porous and Fractured Media*. Springer, Verlag Berlin Heidelberg.
- Doherty J. 2013. *Addendum to the PEST Manual*. Watermark Numerical Computing. May 2013.
www.pesthomepage.org/getfiles.php?file=addendum.pdf
- Earthfx Incorporated (Earthfx). 2009. *Final Report, Simulation of Groundwater Flow in the Vicinity of the Cedarvale Wellfield, Georgetown, Ontario: Model Development and Calibration Report*. Prepared for Regional Municipality of Halton.

- EBNFLO Environmental and AquaResource Inc. (EBNFLO and AquaResource). 2010. *Guide for Assessment of Hydrologic Effects of Climate Change in Ontario*. Prepared for the Ontario Ministry of Natural Resources and Ministry of the Environment in partnership with Credit Valley Conservation. June 2010.
- Freeze R.A. and J.A. Cherry. 1979. *Groundwater*. Prentice Hall. New Jersey. 604 pp.
- Golder Associates Ltd. (Golder) and S.S. Papadopoulos and Associates, Inc. (SSPA). 2018. Preliminary Estimation of Baseflows at SW1 and SW2. Personal Communication. June 27, 2018.
- Golder Associates Ltd. (Golder). 2018a. *2017 Annual Monitoring Report, Nestle Waters Canada Aberfoyle Site*. Final draft report prepared for Nestle Waters Canada. Puslinch, Ontario. February 2018.
- Golder Associates Ltd. (Golder). 2018b. *2017 Annual Monitoring Report, Nestle Waters Canada Erin Spring Site*. Final draft report prepared for Nestle Waters Canada. Puslinch, Ontario. February 2018.
- Golder Associates Ltd. (Golder). 2006. *Guelph-Puslinch Groundwater Protection Study*. Prepared for the Grand River Conservation Authority. Cambridge, Ontario. May 2006.
- Government of Ontario. 2018. *Clean Water Act, 2006*. Ontario Regulation 287/07. Last Amendment: 206/18. Consolidation Period from July 1, 2018, to September 11, 2018.
<http://www.ontario.ca/laws/regulation/070287>
- Grand River Conservation Authority (GRCA). 2018. *Geospatial Data, GIS Data Catalogue*. Grand River Information Network (GRIN). <https://data.grandriver.ca/downloads-geospatial.html>
- Hill, M.C. 1998. *Methods and Guidelines for Effective Model Calibration*, U.S. Geological Survey, Water-Resources Investigation Report 98-4005.
- Matrix Solutions Inc. (Matrix) 2018a. *Assessment of Climate Change and Assessment of Water Quantity Threats in the IPZ-Q in Support of the Guelph-Guelph/Eramosa Water Quantity Policy Study*. Prepared for the Lake Erie Source Protection Region. Guelph, Ontario. November 2018.
- Matrix Solutions Inc. (Matrix). 2018b. *Guelph-Guelph/Eramosa Water Quantity Policy Development Study: Threats Management Strategy*. Version 1.0. Prepared for the Lake Erie Source Protection Region. Guelph, Ontario. June 2018.
- Matrix Solutions Inc. (Matrix). 2017a. *City of Guelph and Township Of Guelph/Eramosa Tier Three Water Budget and Local Area Risk Assessment*. Prepared for the Lake Erie Source Protection Region. Breslau, Ontario. March 2017. <https://www.sourcewater.ca/en/source-protection-areas/guelph-and-guelph-eramosa-tier-3.aspx>


- Matrix Solutions Inc. (Matrix). 2017b. *Cost Estimate for 'Proposed Scope of Groundwater Modeling for Renewal of the Permit To Take Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities*. December 2017.
- Neville C. (2018). Hydrogeologist, Associate. S.S. Papadopoulos & Associates, Inc. Personal communication. Email. May 25, 2018.
- Ontario Ministry of the Environment and Climate Change (MOECC). 2017. *Interim Procedural and Technical Guidance Document for Bottle Water Renewals: Permit to Take Water Applications and Hydrogeological Study Requirements*. Operations Division. April 2017.
http://www.downloads.ene.gov.on.ca/envision/env_reg/er/documents/2017/012-9151_d.pdf
- Ontario Ministry of the Environment and Climate Change. (MOECC). 2016. *Technical Rules: Assessment Report, Clean Water Act, 2006*. November 20, 2008. Amended on December 12, 2008 (administrative amendments), November 16, 2009 (EBR Posting Number EBRO10-7573), and December 2, 2013 (Technical Bulletin). Updated on May 19, 2016.
<https://www.ontario.ca/page/technical-rules-assessment-report>
- Ontario Ministry of the Environment. (MOE). 2013. *Memorandum: Assignment of Water Quantity Risk based on the Evaluation of Impacts to Other Water Users*. Memorandum prepared for Source Protection Regions. Toronto, Ontario. December 2, 2013.
- Ontario Ministry of the Environment (MOE) and Ontario Ministry of Natural Resources (MNR). 2010. *Technical Bulletin: Part IX Local Area Risk Level*. April 2010. 15 pp.
<https://ia601209.us.archive.org/22/items/std01079874.ome/std01079874.pdf>
- Schroeter & Associates. 2004. *GAWSER: Guelph All-Weather Sequential-Events Runoff Model, Version 6.5, Training Guide and Reference Manual*. Prepared for the Ontario Ministry of Natural Resources and the Grand River Conservation Authority.
- Spitz, K., and J. Moreno, 1996: *A Practical Guide to Groundwater and Solute Transport Modeling*, John Wiley & Sons, Inc., New York, New York.
- S.S. Papadopoulos & Associates, Inc. (SSPA). 2016. *Estimates of Baseflow for Mill Creek*. Memorandum to Charles B. Andrews. February 26, 2016.
- Terraqua Investigations Ltd. (Terraqua). 1991. *Hydrogeologic Investigation of a Proposed Residential Development*. Hillsburgh, Ontario. May 1991.
- Town of Erin. 2018. *Summary Report*. Town of Erin. Hillsburgh Well Supply. Drinking-Water System No. 220007285. February 2018.

Town of Erin. 2017. *Summary Report*. Town of Erin. Hillsburgh Well Supply. Drinking-Water System No. 220007285. January 2017.

United States Department of Agriculture (USDA). 1994. BFLOW program, available from <http://swat.tamu.edu/software/baseflow-filterprogram/>.



- Nestlé Waters Canada Property Boundary
- Tier Three Model Boundary
- Grand River Watershed Boundary
- Community
- Wetland
- Water Body
- Watercourse
- Major Road
- Niagara Escarpment
- GRCA Flow Gauge



City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take
 Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities

**City of Guelph and Township of Guelph/Eramosa
 Tier Three Assessment Model Area**

Date: September, 2018	Project: 26435	Submitter: J. Melchin	Reviewer: D. Van Vliet
-----------------------	----------------	-----------------------	------------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\CityOfGuelph\2018\FiguresandTables\09\2018\Report\Figure-1-City_of_Guelph_and_Township_of_Guelph_Eramosa_Tier_Three_Assessment_Model_Area.mxd - Letter_P - 13-Sep-18, 01:41 PM - county - T1001

Reference: Contains information licensed under the Open Government Licence - Ontario and information made available under the copyright © of Grand River Conservation Authority Open Data Licence v3.0.



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- Highway
- Road
- Cross-section
- Monitoring Well (Bedrock)
- Monitoring Well (Overburden)
- ▲ Piezometer
- Private Well (Bedrock)
- ⊕ Production Well
- Surface Water Station
- Surface Water Temperature Station

Reference: Contains information licensed under the Open Government Licence – Ontario and information made available under the copyright of Grand River Conservation Authority Open Data Licence v3.0. Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community

1:13,500 metres
 140 0 140 280
 NAD 1983 UTM Zone 17N



City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestle Waters Canada Aberfoyle and Erin Facilities

Aberfoyle Site Map

Date: December 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\FiguresandTables\CHG\2018\Report\Figure-2-Aberfoyle_Site_Map.mxd - Tabool, L. 18-Dec-18, 07:08 AM - csmey - TID005



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- Highway
- Road
- Cross-section
- Monitoring Well (Bedrock)
- Monitoring Well (Overburden)
- ▲ Piezometer
- Private Well
- Private Well (Bedrock)
- ⊕ Production Well
- Surface Water Station



References: Contains information licensed under the Open Government Licence - Ontario. Data obtained from: Grand River Conservation Authority used under license. Service Layer Credits: Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community





City of Guelph
Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestle Waters Canada Aberfoyle and Erin Facilities

Erin Site Map

Date: September 2018	Project: 26435	Submitter: J. Melchin	Reviewer: D. Van Vliet
----------------------	----------------	-----------------------	------------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\FiguresandTables\OGC\2018\Report\Figure_3\Erin_Site_Map.mxd - Tabbed_L_13-Sep-18, 01:42 PM - copy_1_TID005




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

Aberfoyle NW-SE Model Cross-Section (AA')

Date:	Project:	Technical:	Reviewer:	Drawn:
09 Jan 2019	26435	J. Melchin	D. Van Vliet	J. Melchin

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



Conductivity: K_{xx}

- Patches -
[m/s]

- 1.0E-02
- 1.0E-03
- 1.0E-04
- 1.0E-05
- 1.0E-06
- 1.0E-07
- 1.0E-08
- 1.0E-09
- 1.0E-10




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

Aberfoyle SW-NE Model Cross-Section (BB')

Date:	Project:	Technical:	Reviewer:	Drawn:
09 Jan 2019	26435	J. Melchin	D. Van Vliet	J. Melchin

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- Hydraulic Head Contour | 5m (masl)
- Highway
- Road
- Monitoring Well (Bedrock)
- Monitoring Well (Overburden)
- ▲ Piezometer
- Private Well (Bedrock)
- ⊕ Production Well
- Surface Water Station
- Surface Water Temperature Station



Reference: Contains information licensed under the Open Government Licence – Ontario. Data obtained from Grand River Conservation Authority used under license.




City of Guelph
Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities

Aberfoyle - Simulated Goat Island Fm. Potentiometric Surface (Layer 10)

Date: December 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Chp\EA\figs\26435\Figures\Tables\04632018\Report\Figure 6-Aberfoyle_Simulated_Goat_Island_Fm_Potentiometric_Surface_Layer_10.mxd - Tab04_L_07.Dec.18, 12:12 PM - c.cury - TID005



- Conductivity: K_{xx}
- Patches -
[m/s]
- 1.0E-02
 - 1.0E-03
 - 1.0E-04
 - 1.0E-05
 - 1.0E-06
 - 1.0E-07
 - 1.0E-08
 - 1.0E-09
 - 1.0E-10




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

Erin NW-SE Model Cross-Section (AA')

Date:	Project:	Technical:	Reviewer:	Drawn:
09 Jan 2019	26435	J. Melchin	D. Van Vliet	J. Melchin

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Conductivity: K_{xx}
- Patches -
[m/s]
- 1.0E-02
 - 1.0E-03
 - 1.0E-04
 - 1.0E-05
 - 1.0E-06
 - 1.0E-07
 - 1.0E-08
 - 1.0E-09
 - 1.0E-10




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities


Erin SW-NE Model Cross-Section (BB')

Date:	Project:	Technical:	Reviewer:	Drawn:
09 Jan 2019	26435	J. Melchin	D. Van Vliet	J. Melchin

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- Hydraulic Head Contour | 5m (masl)
- Highway
- Road
- Monitoring Well (Bedrock)
- Monitoring Well (Overburden)
- ▲ Piezometer
- Private Well
- Private Well (Bedrock)
- ⊕ Production Well
- Surface Water Station



Reference: Contains information licensed under the Open Government Licence - Ontario. Data obtained from Grand River Conservation Authority used under license.



City of Guelph
Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestle Waters Canada Aberfoyle and Erin Facilities


Erin - Simulated Guelph Fm. Potentiometric Surface (Layer 7)

Date: September 18 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet


Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\Figures\Tables\CH03\2018\Report\Figure-9-Erin_Simulated_Guelph_Fm_Potentiometric_Surface_Layer_7.mxd - Tabled_L - 14-Sep-18, 10:09 AM - curry - TD005

I:\City\Guelph\26435\Figures\Tables\0462018\Presentation\Figure_10_Aberfoyle_Simulated_vs_Interpreted_Drawdown_in_the_Upper_Bedrock_Layer6_Reformatory_Quarry_Mbr_due_to_2010_NWC_Pumping_Test.mxd - Tabbed_L_13-Dec-18 07:33 PM - ccurry - TD0005



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- Interpreted Drawdown Contour | 1m
- - - Simulated Drawdown Contour | 1m
- Highway
- Road
- Upper Bedrock Monitoring Well
- O: x.x Observed Drawdown Value




Reference: Contains information licensed under the Open Government Licence - Ontario. Data obtained from Grand River Conservation Authority used under license.



City of Guelph
Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestle Waters Canada Aberfoyle and Erin Facilities
Aberfoyle - Simulated vs. Interpreted Drawdown in the Upper Bedrock (Layer 6 - Reformatory Quarry Mbr.) due to 2010 NWC Pumping Test

Date: December 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- Interpreted Drawdown Contour | 1m
- - - Simulated Drawdown Contour | 1m
- Highway
- Road
- Lower Bedrock Monitoring Well
- O: x.x Observed Drawdown Value



Reference: Contains information licensed under the Open Government Licence – Ontario. Data obtained from Grand River Conservation Authority used under license.




City of Guelph
Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestle Waters Canada Aberfoyle and Erin Facilities

Aberfoyle - Simulated vs. Interpreted Drawdown in the Lower Bedrock (Layer 10 – Goat Island Fm.) due to 2010 NWC Pumping Test


Date: December 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\City\Guelph\0435\Figures\Tables\0435\018\Presentation\Figure_13_Erin_Simulated_Drawdown_in_the_Guelph_Fm_Layer_7.dwg to NWC_pumping_2016 to 2017.mxd - Table1_L - 13 Dec 18, 07:38 PM - cummy - TID005



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- - - Simulated Drawdown | 1m
- Highway
- Road
- Bedrock Monitoring Well
- O: x.x Estimated Observed Drawdown Value



Reference: Contains information licensed under the Open Government Licence – Ontario. Data obtained from Grand River Conservation Authority used under license.




City of Guelph
Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestle Waters Canada Aberfoyle and Erin Facilities

Erin – Simulated Drawdown in the Guelph Fm. (Layer 7) due to NWC Pumping (2016 to 2017)

Date: December 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- ◆ Climate Change Scenarios
- Representative Climate Change Scenarios




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
 Canada Aberfoyle and Erin Facilities

**Scatter Plot of Future Climate Models Selected
 for Hydrologic Modelling
 (2050s versus Current)**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Baseline
- Climate Change 1 (FIO-ESM[Run 1])
- Climate Change 2 (CSIRO-Mk3-6-0[Run 10])
- Climate Change 3 (MIROC-ESM[Run 1])
- Climate Change 4 (CMCC-CESM[Run 1])




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
 Canada Aberfoyle and Erin Facilities


**Estimated Mean Daily Recharge
 (2050s versus Baseline)**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- - - Simulated Drawdown | 1m
- Highway
- Road
- Monitoring Well (Bedrock)
- Monitoring Well (Overburden)
- ▲ Piezometer
- Private Well (Bedrock)
- ⊕ Production Well
- Surface Water Station
- Surface Water Temperature Station




Reference: Contains information licensed under the Open Government Licence - Ontario. Data obtained from Grand River Conservation Authority used under license.

City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestle Waters Canada Aberfoyle and Erin Facilities
Aberfoyle - Simulated Additional Drawdown in Upper Bedrock (Layer 6 – Reformatory Quarry Mbr.) – Average Pumping to Permitted Pumping


Date: January 2019 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\CityOfGuelph\126435\Figures and Tables\046\2018\Report\Figure 16-Aberfoyle_Simulated_Additional_Drawdown_in_Upper_Bedrock_Layer_6_Reformatory_Quarry_Mbr_Average_Pumping_to_Permitted_Pumping.mxd-Table1_L_18-Jan-19_04:18-PM-ehallinger-T10005



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- - - Simulated Drawdown | 2m
- Highway
- Road
- Monitoring Well (Bedrock)
- ▲ Monitoring Well (Overburden)
- ▲ Piezometer
- Private Well (Bedrock)
- ⊕ Production Well
- Surface Water Station
- Surface Water Temperature Station




Reference: Contains information licensed under the Open Government Licence - Ontario. Data obtained from Grand River Conservation Authority used under license.

City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities
Aberfoyle - Simulated Additional Drawdown in Lower Bedrock (Layer 10 – Goat Island Fm.) – Average Pumping to Permitted Pumping

Date: January 2019 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\CityOfGuelph\126435\Figures and Tables\04\03\018\Report\Figure 17_Aberfoyle_Simulated_Additional_Drawdown_in_Lower_Bedrock_Layer_10_Goat_Island_Fm_Average_Pumping_to_Permitted_Pumping.mxd - Table 1 - 21-Jan-19 08:14 AM - ehalligan - TD005



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- - - Simulated Drawdown | 1m
- Highway
- Road
- ⊕ Monitoring Well (Bedrock)
- ⊕ Monitoring Well (Overburden)
- ▲ Piezometer
- ⊕ Private Well (Bedrock)
- ⊕ Production Well
- Surface Water Station
- Surface Water Temperature Station

1:8,250 metres

80 0 80 160
NAD 1983 UTM Zone 17N

Reference: Contains information licensed under the Open Government Licence – Ontario. Data obtained from Grand River Conservation Authority used under license.

City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities


Local Aberfoyle Extent - Simulated Additional Drawdown in Lower Bedrock (Layer 12 – Middle Gasport Fm.) – Average Pumping to Permitted Pumping

Date: January 2019	Project: 26435	Submitter: J. Melchin	Reviewer: D. Van Vliet
--------------------	----------------	-----------------------	------------------------

Figure 18

I:\CityOfGuelph\1026435\FiguresandTables\04\03\018\Report\Figure_18_Local_Aberfoyle_Extent_Simulated_Additional_Drawdown_in_Lower_Bedrock_Layer_12_Middle_Gasport_Fm_Average_Pumping_to_Permitted_Pumping.mxd - Table1_L - 21-Jan-19 09:05:AM - ehallinger - T2005

I:\Client\Guelph\26435\Figures and Tables\CHG\2018\Report\Figures\19-Regional_Aberfoyle_Extent_Simulated_Drawdown_in_Lower_Bedrock_Layer_12_Middle_Gasport_Fm_Average_Pumping_to_Permitted_Pumping.mxd - Tabbed_L - 18-Dec-18, 09:05 AM - county_TID005



- Nestlé Waters Canada Property Boundary
- Community
- Water Body
- Watercourse
- Simulated Drawdown | 1m
- Highway
- Road
- Production Well
- Municipal Well
- ◆ GRCA Flow Gauge



Reference: Contains information licensed under the Open Government Licence - Ontario. Data obtained from Grand River Conservation Authority used under license.




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestle Waters Canada Aberfoyle and Erin Facilities

Regional Aberfoyle Extent - Simulated Additional Drawdown in Lower Bedrock (Layer 12 - Middle Gasport Fm.) - Average Pumping to Permitted Pumping

Date: December 2018	Project: 26435	Submitter: J. Melchin	Reviewer: D. Van Vliet
---------------------	----------------	-----------------------	------------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- MW2A-07 - Average NWC Pumping (2,113 m³/day; Scenario 3)
- MW2A-07 - Permitted NWC Pumping (3,600 m³/day; Scenario 4)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

**Aberfoyle – Simulated Water Level Variability at
MW2A-07 – Drought Scenarios**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Burke Well - Average NWC Pumping (2,113 m³/day; Scenario 3)
- Burke Well - Permitted NWC Pumping (3,600 m³/day; Scenario 4)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

**Aberfoyle – Simulated Water Level Variability at
Burke Well – Drought Scenarios**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Mill Ck. At Side Rd. 10 - Average NWC Pumping (2,113 m³/day; Scenario 3)
- Mill Ck. At Side Rd. 10 - Permitted NWC Pumping (3,600 m³/day; Scenario 4)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

**Aberfoyle – Simulated Groundwater Discharge
at Mill Creek at Side Rd. 10 Gauge –
Drought Scenarios Time Series**

Date:	11 Dec 2018	Project:	26435	Technical:	J. Melchin	Reviewer:	D. Van Vliet	Drawn:	J. Melchin
-------	-------------	----------	-------	------------	------------	-----------	--------------	--------	------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Mill Ck. At Side Rd. 10 - Average NWC Pumping (2,113 m³/day; Scenario 3)
- Mill Ck. At Side Rd. 10 - Permitted NWC Pumping (3,600 m³/day; Scenario 4)




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
 Canada Aberfoyle and Erin Facilities

**Aberfoyle – Simulated Groundwater Discharge
 at Mill Creek at Side Rd. 10 Gauge –
 Drought Scenarios Ranked Duration Curves**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Range of Future Climates
- MW2A-07 - Historical Climate Variability (NWC Pumping = 2,113 m³/day; Scenario 3)
- MW2A-07 - Climate Change 1 (NWC Pumping = 2,113 m³/day; Scenario 5a)
- MW2A-07 - Climate Change 2 (NWC Pumping = 2,113 m³/day; Scenario 5b)
- MW2A-07 - Climate Change 3 (NWC Pumping = 2,113 m³/day; Scenario 5c)
- MW2A-07 - Climate Change 4 (NWC Pumping = 2,113 m³/day; Scenario 5d)
- MW2A-07 - Historical Climate Variability (NWC Pumping = 3,600 m³/day; Scenario 4)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

**Aberfoyle – Mean Monthly Simulated Water
Level Variability at MW2A-07 –
Climate Change Scenarios**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Range of Future Climates
- Burke Well - Historical Climate Variability (NWC Pumping = 2,113 m³/day; Scenario 3)
- Burke Well - Historical Climate Variability (NWC Pumping = 3,600 m³/day; Scenario 4)
- Burke Well - Climate Change 1 (NWC Pumping = 2,113 m³/day; Scenario 5a)
- Burke Well - Climate Change 2 (NWC Pumping = 2,113 m³/day; Scenario 5b)
- Burke Well - Climate Change 3 (NWC Pumping = 2,113 m³/day; Scenario 5c)
- Burke Well - Climate Change 4 (NWC Pumping = 2,113 m³/day; Scenario 5d)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

Aberfoyle – Mean Monthly Simulated Water Level Variability at Burke Well – Climate Change Scenarios

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Range of Future Climates
- Mill Creek - Historical Climate Variability (NWC Pumping = 2,113 m³/day; Scenario 3)
- Mill Creek - Historical Climate Variability (NWC Pumping = 3,600 m³/day; Scenario 4)
- Mill Creek - Climate Change 1 (NWC Pumping = 2,113 m³/day; Scenario 5a)
- Mill Creek - Climate Change 2 (NWC Pumping = 2,113 m³/day; Scenario 5b)
- Mill Creek - Climate Change 3 (NWC Pumping = 2,113 m³/day; Scenario 5c)
- Mill Creek - Climate Change 4 (NWC Pumping = 2,113 m³/day; Scenario 5d)




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
 Canada Aberfoyle and Erin Facilities


**Aberfoyle – Mean Monthly Simulated
 Groundwater Discharge at Mill Creek at Side
 Rd. 10 Gauge – Climate Change Scenarios**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Nestlé Waters Canada Property Boundary
- Water Body
- Watercourse
- - - Simulated Drawdown | 2m
- Highway
- Road
- Monitoring Well (Bedrock)
- Monitoring Well (Overburden)
- ▲ Piezometer
- Private Well
- Private Well (Bedrock)
- ⊕ Production Well
- Surface Water Station



Reference: Contains information licensed under the Open Government Licence - Ontario. Data obtained from Grand River Conservation Authority used under license.



City of Guelph
Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities

Local Erin Extent - Simulated Additional Drawdown in the Guelph Fm. (Layer 7) – Average Pumping to Permitted Pumping

Date: January 2019	Project: 26435	Submitter: J. Melchin	Reviewer: D. Van Vliet
--------------------	----------------	-----------------------	------------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\CityofGuelph\126435\FiguresandTables\04\G2018\Report\Figure 27-Local_Erin_Extent_Simulated_Additional_Drawdowns_in_the_Guelph_Fm_Layer_7_Average_Pumping_to_Permitted_Pumping.mxd - Table 1 - 21-Jan-19, 10:48 AM - eholinger - TD005

Easting (m)


570000

4850000

Northing (m)



4850000



-  Nestlé Waters Canada Property Boundary
-  Water Body
-  Watercourse
-  Simulated Drawdown | 1m
-  Highway
-  Road
-  Production Well
-  Municipal Well



Reference: Contains information licensed under the Open Government Licence – Ontario. Data obtained from Grand River Conservation Authority used under license.




City of Guelph
Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestle Waters Canada Aberfoyle and Erin Facilities

Regional Erin Extent - Simulated Additional Drawdown in the Guelph Fm. (Layer 7) - Average Pumping to Permitted Pumping

Date: December 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\Figures and Tables\2018\Report\Figure 28-Regional_Erin_Extent_Simulated_Average_Pumping_to_Permitted_Pumping.mxd - Table 1 - 18-Dec-18 01:37 PM - copy - T10005



- MW05A-05 - Average NWC Pumping (207 m³/day; Scenario 3)
- MW05A-05 - Permitted NWC Pumping (1,113 m³/day; Scenario 4)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

**Erin – Simulated Water Level Variability at
MW05A-05 – Drought Scenarios**

Date:	11 Dec 2018	Project:	26435	Technical:	J. Melchin	Reviewer:	D. Van Vliet	Drawn:	J. Melchin
-------	-------------	----------	-------	------------	------------	-----------	--------------	--------	------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Hillsburgh Well 2 -Average NWC Pumping (207 m³/day; Scenario 3)
- Hillsburgh Well 2 - Permitted NWC Pumping (1,113 m³/day; Scenario 4)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

Erin – Simulated Water Level Variability at Hillsburgh Well 2 – Drought Scenarios

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Hillsburgh Well 3 - Average NWC Pumping (207 m³/day; Scenario 3)
- Hillsburgh Well 3 - Permitted NWC Pumping (1,113 m³/day; Scenario 4)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

Erin – Simulated Water Level Variability at Hillsburgh Well 3 – Drought Scenarios

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- SW1 - Average NWC Pumping (207 m³/day; Scenario 3)
- SW1 - Permitted NWC Pumping (1,113 m³/day; Scenario 4)




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
 Canada Aberfoyle and Erin Facilities

**Erin – Simulated Groundwater Discharge at
 SW1 – Drought Scenarios Time Series**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- SW1 - Average NWC Pumping (207 m³/day; Scenario 3)
- SW1 - Permitted NWC Pumping (1,113 m³/day; Scenario 4)




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
 Canada Aberfoyle and Erin Facilities

**Erin – Simulated Groundwater Discharge at
 SW1 – Drought Scenarios Ranked Duration
 Curves**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- Range of Future Climates
- MW05A-05 - Historical Climate Variability (NWC Pumping = 207 m³/day; Scenario 3)
- MW05A-05 - Historical Climate Variability (NWC Pumping = 1,113 m³/day; Scenario 4)
- MW05A-05 - Climate Change 1 (NWC Pumping = 207 m³/day; Scenario 5a)
- MW05A-05 - Climate Change 2 (NWC Pumping = 207 m³/day; Scenario 5b)
- MW05A-05 - Climate Change 3 (NWC Pumping = 207 m³/day; Scenario 5c)
- MW05A-05 - Climate Change 4 (NWC Pumping = 207 m³/day; Scenario 5d)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

Erin – Mean Monthly Simulated Water Level Variability at MW05A-05 – Climate Change Scenarios

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- ▒ Range of Future Climates
- Hillsburgh Well 2 - Historical Climate Variability (NWC Pumping = 207 m³/day; Scenario 3)
- Hillsburgh Well 2 - Historical Climate Variability (NWC Pumping = 1,113 m³/day; Scenario 4)
- Hillsburgh Well 2 - Climate Change 1 (NWC Pumping = 207 m³/day; Scenario 5a)
- Hillsburgh Well 2 - Climate Change 2 (NWC Pumping = 207 m³/day; Scenario 5b)
- Hillsburgh Well 2 - Climate Change 3 (NWC Pumping = 207 m³/day; Scenario 5c)
- Hillsburgh Well 2 - Climate Change 4 (NWC Pumping = 207 m³/day; Scenario 5d)




City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

**Erin – Mean Monthly Simulated Water Level
Variability at Hillsburgh Well 2 –
Climate Change Scenarios**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.



- ▒ Range of Future Climates
- Hillsburgh Well 3 - Historical Climate Variability (NWC Pumping = 207 m³/day; Scenario 3)
- Hillsburgh Well 3 - Historical Climate Variability (NWC Pumping = 1,113 m³/day; Scenario 4)
- Hillsburgh Well 3 - Climate Change 1 (NWC Pumping = 207 m³/day; Scenario 5a)
- Hillsburgh Well 3 - Climate Change 2 (NWC Pumping = 207 m³/day; Scenario 5b)
- Hillsburgh Well 3 - Climate Change 3 (NWC Pumping = 207 m³/day; Scenario 5c)
- Hillsburgh Well 3 - Climate Change 4 (NWC Pumping = 207 m³/day; Scenario 5d)




Matrix Solutions Inc.
ENVIRONMENT & ENGINEERING

City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

**Erin – Mean Monthly Simulated Water Level
Variability at Hillsburgh Well 3 –
Climate Change Scenarios**

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet
Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.			Drawn: J. Melchin

Figure 36



- Range of Future Climates
- SW1 - Historical Climate Variability (NWC Pumping = 207 m³/day; Scenario 3)
- SW1 - Historical Climate Variability (NWC Pumping = 1,113 m³/day; Scenario 4)
- SW1 - Climate Change 1 (NWC Pumping = 207 m³/day; Scenario 5a)
- SW1 - Climate Change 2 (NWC Pumping = 207 m³/day; Scenario 5b)
- SW1 - Climate Change 3 (NWC Pumping = 207 m³/day; Scenario 5c)
- SW1 - Climate Change 4 (NWC Pumping = 207 m³/day; Scenario 5d)



City of Guelph
Groundwater Modelling Report for Renewal of the Permit To Take Water for the Nestlé Waters
Canada Aberfoyle and Erin Facilities

Erin – Mean Monthly Simulated Groundwater Discharge at SW1 – Climate Change Scenarios

Date: 11 Dec 2018	Project: 26435	Technical: J. Melchin	Reviewer: D. Van Vliet	Drawn: J. Melchin
-------------------	----------------	-----------------------	------------------------	-------------------

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

APPENDIX A

Calibration Dataset and Results

APPENDIX A - CALIBRATION DATASET AND RESULTS

Table A1 Calibration Dataset and Results - Aberfoyle

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
125_Brock_S_Y_Well	569339	4812724	297	296	311.59	313.89	0.26	1.80	Upper Bedrock	N
#2 Brock N.	568379	4813795	n/a	n/a	315.84	314.56	0.11	0.04	Upper Bedrock	N
27_Old_Brock	569089	4813534	299	282	309.41	313.41	5.38	3.36	Lower Bedrock	N
#46 Gilmour	569848	4813550	n/a	n/a	319.56	316.75	n/a	n/a	Upper Bedrock	N
50_Brock_S_I_Well	568947	4813482	299	291	309.68	309.51	n/a	n/a	Lower Bedrock	N
58 Brock S.	569022	4813428	n/a	n/a	311.67	311.52	1.21	4.47	Upper Bedrock	N
7404_Rd_34	568132	4813524	300	298	315.62	314.83	n/a	n/a	Upper Bedrock	N
7425_Rd_34_B_Well	568371	4813669	305	283	310.23	314.91	3.63	0.89	Lower Bedrock	N
8_MapleLeaf_Lane	568715	4813413	303	302	311.74	311.89	n/a	n/a	Upper Bedrock	N
80_Brock_S_W2_Well	569254	4813252	297	260	307.94	312.30	n/a	n/a	Lower Bedrock	N
98_Brock_S_M1_Well	569443	4813056	303	281	309.66	313.86	5.37	2.34	Lower Bedrock	N
67-04699	569118	4813379	300	284	310.60	312.61	n/a	n/a	Upper Bedrock	N
67-08234	568172	4813388	298	285	310.22	313.67	n/a	n/a	Upper Bedrock	N
67-09385	568152	4813754	304	266	315.30	317.55	n/a	n/a	Lower Bedrock	N
Capital_Paving_Asp halt_Pl	567511	4811895	302	281	307.59	309.02	n/a	n/a	Upper Bedrock	N
Fireflow	568454	4812433	299	261	309.86	311.19	1.97	0.74	Lower Bedrock	N
H Well at end of Maple Leaf Ln --	568291	4812752	n/a	n/a	312.94	310.59	n/a	n/a	Upper Bedrock	N
Lane Restaurant	568841	4813123	n/a	n/a	311.71	311.22	n/a	n/a	Upper Bedrock	N
MP8D	568464	4812470	310	309	310.48	310.47	n/a	n/a	Overburden	N

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
MP8S	568464	4812470	310	309	310.51	310.47	n/a	n/a	Overburden	N
MP11D	569736	4813798	317	316	317.91	317.26	n/a	n/a	Overburden	N
MP11S	569736	4813798	318	317	317.79	317.26	n/a	n/a	Overburden	N
MP12D	568954	4812893	310	309	311.60	311.39	0.19	0.12	Overburden	N
MP12S	568954	4812893	311	310	311.55	311.39	0.15	0.12	Overburden	N
MP14D	568750	4812760	309	309	311.51	311.06	n/a	n/a	Overburden	N
MP14S	568750	4812760	311	310	311.50	311.06	n/a	n/a	Overburden	N
MP16D	569148	4813251	310	310	312.16	312.19	n/a	n/a	Overburden	N
MP16S	569148	4813251	312	311	312.25	312.19	n/a	n/a	Overburden	N
MW01A-04	569636	4813476	306	303	317.51	316.39	n/a	n/a	Upper Bedrock	N
MW01B-04	569636	4813476	311	308	317.53	316.40	n/a	n/a	Overburden	N
MW01C-04	569636	4813476	320	317	322.94	316.40	n/a	n/a	Overburden	N
MW02A-07	568946	4812909	283	280	309.41	308.28	7.00	8.86	Lower Bedrock	N
MW02B-07	568946	4812909	292	290	309.79	308.28	n/a	n/a	Lower Bedrock	N
MW02C-07	568946	4812909	300	298	310.81	309.87	2.61	4.59	Upper Bedrock	N
MW02D-07	568940	4812910	304	303	311.49	311.35	0.66	0.11	Overburden	N
MW02E-07	568940	4812910	309	308	311.45	311.35	0.34	0.11	Overburden	N
MW03A-07	568783	4812949	280	277	310.51	311.21	2.64	2.85	Lower Bedrock	N
MW03B-07	568783	4812949	286	284	311.38	311.21	n/a	n/a	Lower Bedrock	N
MW03C-07	568783	4812949	295	293	311.51	311.12	1.88	0.62	Upper Bedrock	N
MW04A-07	569252	4813069	283	280	309.48	309.78	6.11	8.45	Lower Bedrock	N
MW04B-07	569252	4813069	300	298	311.83	313.21	0.35	1.51	Upper Bedrock	N
MW04C-07	569252	4813069	308	306	311.78	313.44	0.01	0.99	Overburden	N
MW06A-08	569344	4814036	283	280	316.18	318.11	1.41	0.71	Lower Bedrock	N
MW06B-08	569344	4814036	299	298	318.44	317.66	0.00	0.02	Upper Bedrock	N
MW07A-08	568805	4813813	288	285	309.90	311.04	5.39	6.26	Lower Bedrock	N

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
MW07B-08	568805	4813813	302	300	311.15	313.36	3.11	2.68	Upper Bedrock	N
MW08A-08	568677	4814244	284	281	317.46	318.61	0.67	0.57	Lower Bedrock	N
MW08B-08	568677	4814244	299	298	317.26	317.41	0.06	0.01	Upper Bedrock	N
MW10A-09	569940	4813642	319	316	319.57	317.31	0.00	0.00	Overburden	N
MW10B-09	569947	4813655	305	302	319.61	317.48	0.02	0.01	Upper Bedrock	N
MW10C-09	569947	4813655	263	260	317.66	318.25	n/a	n/a	Lower Bedrock	N
MW10D-09	569947	4813655	248	245	317.49	318.25	0.61	0.98	Lower Bedrock	N
MW13-10	569080	4812749	287	284	305.02	301.79	14.38	n/a	Lower Bedrock	N
MW14A-11	568360	4813081	283	279	310.26	313.47	3.54	2.19	Lower Bedrock	N
MW14B-11	568360	4813081	297	294	313.66	311.35	0.22	0.04	Upper Bedrock	N
MW14C-11	568360	4813081	303	301	314.26	311.34	0.12	0.03	Upper Bedrock	N
MW15A-12	567775	4812475	282	250	310.43	311.69	0.50	0.18	Lower Bedrock	N
MW15B-12	567770	4812469	301	300	308.26	310.75	n/a	n/a	Upper Bedrock	N
MW16A-12	568750	4811186	262	257	307.03	310.25	0.20	0.10	Lower Bedrock	N
MW16B-12	568747	4811185	290	288	307.44	311.52	n/a	n/a	Upper Bedrock	N
MW17A-12	569495	4811887	275	271	308.08	312.35	2.06	0.79	Lower Bedrock	N
MW17B-12	569493	4811885	301	300	309.47	314.15	n/a	n/a	Upper Bedrock	N
MW18A-12	568760	4812109	261	256	307.82	311.55	3.34	1.37	Lower Bedrock	N
MW18B-12	568758	4812106	297	295	308.05	311.31	n/a	n/a	Upper Bedrock	N
MW-D	568562	4812714	301	294	310.72	310.63	1.13	0.05	Upper Bedrock	N
MW-I	568562	4812714	307	305	310.91	310.63	1.23	0.05	Upper Bedrock	N
MW-S	568562	4812714	297	295	311.10	310.60	0.00	0.03	Overburden	N
Nestle_Farmhouse	569259	4812831	304	292	312.38	312.93	n/a	n/a	Upper Bedrock	N
PCC-D	568445	4813464	303	301	314.20	311.94	0.13	0.10	Upper Bedrock	N
PCC-I	568445	4813464	308	306	313.99	311.50	0.04	0.03	Overburden	N
PCC-S	568445	4813464	312	311	314.16	311.50	0.00	0.03	Overburden	N

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
PW5_Meadows_of_Aberfoyle	569576	4813205	302	266	310.02	315.04	4.72	1.59	Lower Bedrock	N
S Well	569309	4811461	n/a	n/a	308.33	311.55	n/a	n/a	Lower Bedrock	N
TW1-93	568672	4812578	302	302	309.87	311.09	0.36	0.06	Overburden	N
TW1-99	569018	4812829	301	301	311.59	311.90	0.32	1.51	Overburden	N
TW3-80	569056.3	4812800.2	288	285	306.03	299.38	14.52	n/a	Lower Bedrock	N
W Well	569233	4813059	n/a	n/a	311.85	312.98	n/a	n/a	Upper Bedrock	N
TW2-11	568638	4812238	281	255	309.46	311.40	n/a	n/a	Lower Bedrock	N
Lane_House	569018	4813363	298	277	310.05	308.36	5.54	10.79	Upper Bedrock	N
MP4S-04	568999	4812999	311.42	310.81	n/a	n/a	0.19	0.19	Overburden	N
MP4D-04	568999	4812999	310.19	309.75	n/a	n/a	0.19	0.19	Overburden	N
MP6S-04	569030	4813051	310.94	310.33	n/a	n/a	0.08	0.03	Overburden	N
MP6D-04	569030	4813051	309.72	309.11	n/a	n/a	0.11	0.03	Overburden	N
FW1D-09	569777	4813966	244.00	241.00	n/a	n/a	0.42	0.89	Lower Bedrock	N
MW11C-09	570028	4813727	272.10	268.00	n/a	n/a	0.38	0.76	Lower Bedrock	N
MW12C-09	569896	4813760	258.00	253.00	n/a	n/a	0.48	0.96	Lower Bedrock	N
MW9B-09	569779	4813965	297.48	296.11	n/a	n/a	0.02	0.01	Upper Bedrock	N
MW11B-09	570028	4813724	302.63	301.94	n/a	n/a	0.02	0.01	Upper Bedrock	N
MW9A-09	569779	4813963	318.41	315.36	n/a	n/a	0.00	0.01	Overburden	N
MW11A-09	570025	4813725	315.37	313.85	n/a	n/a	0.00	0.01	Overburden	N
MW12A-11	569899	4813760	n/a	n/a	n/a	n/a	0.00	0.01	Overburden	N
n/a	566585	4810364	308.82	303.82	305.13	305.41	n/a	n/a	Overburden	Y
n/a	566436	4810390	309.93	304.93	305.21	305.112	n/a	n/a	Overburden	Y
n/a	566720	4810470	309.82	304.82	305.61	305.901	n/a	n/a	Overburden	Y
n/a	566850	4810320	309.95	304.95	305.84	306.096	n/a	n/a	Overburden	Y
n/a	566991	4811145	310.03	305.03	306.45	306.844	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
n/a	566984	4811178	310.28	305.28	306.5	306.972	n/a	n/a	Overburden	Y
n/a	566987	4811162	310.31	305.31	306.52	306.816	n/a	n/a	Overburden	Y
n/a	566987	4811162	309.33	304.33	306.57	306.816	n/a	n/a	Overburden	Y
n/a	567128	4811064	311.75	306.75	306.64	307.424	n/a	n/a	Overburden	Y
n/a	567314	4811221	310.79	305.79	306.75	307.286	n/a	n/a	Overburden	Y
n/a	567318	4811201	310.52	305.52	306.76	307.381	n/a	n/a	Overburden	Y
n/a	567262	4811312	308.28	303.28	306.83	307.667	n/a	n/a	Overburden	Y
n/a	567308	4811244	310.26	305.26	306.99	307.37	n/a	n/a	Overburden	Y
n/a	567497	4811427	308.94	303.94	307	307.726	n/a	n/a	Overburden	Y
n/a	566987	4811162	309.16	304.16	307.07	306.816	n/a	n/a	Overburden	Y
n/a	567314	4811221	309.89	304.89	307.12	307.286	n/a	n/a	Overburden	Y
n/a	567680	4811443	311.47	306.47	307.15	308.129	n/a	n/a	Overburden	Y
n/a	567605	4811440	309.74	304.74	307.21	307.806	n/a	n/a	Overburden	Y
n/a	567710	4811492	310.78	305.78	307.34	308.392	n/a	n/a	Overburden	Y
n/a	567726	4811623	312.11	307.11	307.66	308.345	n/a	n/a	Overburden	Y
n/a	567726	4811623	311.88	306.88	307.67	308.345	n/a	n/a	Overburden	Y
n/a	566640	4811326	307.65	302.65	308.72	307.698	n/a	n/a	Overburden	Y
n/a	566720	4811756	311.28	306.28	311.69	308.556	n/a	n/a	Overburden	Y
n/a	566553	4810406	309.03	304.03	305.28	305.385	n/a	n/a	Overburden	Y
n/a	566744	4810530	308.94	303.94	305.85	305.991	n/a	n/a	Overburden	Y
n/a	566640	4810110	312.71	307.71	305.85	305.165	n/a	n/a	Overburden	Y
n/a	566804	4810572	310.14	305.14	305.94	306.219	n/a	n/a	Overburden	Y
n/a	566879	4810152	307.4	302.4	305.96	306.101	n/a	n/a	Overburden	Y
n/a	566750	4810142	305.8	300.8	305.99	306.091	n/a	n/a	Overburden	Y
n/a	566823	4810603	310.15	305.15	306.24	306.307	n/a	n/a	Overburden	Y
n/a	567017	4811031	308.53	303.53	306.31	307.051	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
n/a	567311	4811129	310.94	305.94	306.49	307.699	n/a	n/a	Overburden	Y
n/a	566940	4810390	310.51	305.51	306.7	306.139	n/a	n/a	Overburden	Y
n/a	567158	4810745	306.6	301.6	307	308.249	n/a	n/a	Overburden	Y
n/a	567775	4811181	310.99	305.99	307.14	308.99	n/a	n/a	Overburden	Y
n/a	566733	4811440	312.32	307.32	307.18	307.75	n/a	n/a	Overburden	Y
n/a	567429	4810589	305.6	300.6	307.41	308.259	n/a	n/a	Overburden	Y
n/a	567314	4811221	309.64	304.64	307.42	307.289	n/a	n/a	Overburden	Y
n/a	566912	4811652	309.19	304.19	307.81	307.725	n/a	n/a	Overburden	Y
n/a	566690	4811747	312.22	307.22	308.12	308.589	n/a	n/a	Overburden	Y
n/a	566716	4811603	310.88	305.88	308.26	307.767	n/a	n/a	Overburden	Y
n/a	566667	4811757	312.32	307.32	308.47	308.711	n/a	n/a	Overburden	Y
n/a	566693	4811583	310.73	305.73	308.5	307.862	n/a	n/a	Overburden	Y
n/a	566571	4811515	310.18	305.18	308.82	308.054	n/a	n/a	Overburden	Y
n/a	566745	4811450	308.52	303.52	308.85	307.753	n/a	n/a	Overburden	Y
6702537	571380	4810889	308.59	303.59	310.39	315.796	n/a	n/a	Overburden	Y
n/a	566957	4812381	311.43	306.43	310.39	310.112	n/a	n/a	Overburden	Y
6703373	568374	4811563	312.57	307.57	313.07	311.228	n/a	n/a	Overburden	Y
n/a	568416	4814373	321.67	316.67	318.21	320.265	n/a	n/a	Overburden	Y
n/a	568332	4814434	322.57	317.57	319.39	321.447	n/a	n/a	Overburden	Y
n/a	568416	4814494	324.07	319.07	319.42	321.622	n/a	n/a	Overburden	Y
n/a	568738	4814705	332.93	327.93	331.33	321.9	n/a	n/a	Overburden	Y
6702674	571500	4810968	299.14	294.14	304.32	315.754	n/a	n/a	Overburden	Y
6702525	568110	4811385	302.38	297.38	305.57	310.963	n/a	n/a	Overburden	Y
6711403	566954	4811184	298.99	293.99	305.87	307.284	n/a	n/a	Overburden	Y
n/a	566994	4811020	298.84	293.84	306.07	306.941	n/a	n/a	Overburden	Y
n/a	567160	4811324	300.8	295.8	306.23	307.655	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
n/a	566703	4811002	306.41	301.41	306.23	306.884	n/a	n/a	Overburden	Y
6702538	571349	4810824	302.42	297.42	306.29	315.651	n/a	n/a	Overburden	Y
n/a	567435	4811260	301.39	296.39	306.33	307.364	n/a	n/a	Overburden	Y
n/a	566723	4811100	305.45	300.45	306.35	307.457	n/a	n/a	Overburden	Y
n/a	566856	4810865	301.44	296.44	306.56	306.261	n/a	n/a	Overburden	Y
n/a	566945	4811112	300.27	295.27	306.64	306.755	n/a	n/a	Overburden	Y
6703614	570804	4810123	304.75	299.75	306.87	314.21	n/a	n/a	Overburden	Y
n/a	567058	4809760	311.53	306.53	306.97	307.635	n/a	n/a	Overburden	Y
n/a	566985	4811023	300.88	295.88	306.98	306.882	n/a	n/a	Overburden	Y
n/a	566788	4811094	305.15	300.15	307.03	307.569	n/a	n/a	Overburden	Y
n/a	566742	4811279	304.4	299.4	307.06	307.697	n/a	n/a	Overburden	Y
6702326	568032	4810227	305.1	300.1	307.08	309.565	n/a	n/a	Overburden	Y
n/a	567068	4810315	306.83	301.83	307.13	306.263	n/a	n/a	Overburden	Y
n/a	568340	4809542	305.06	300.06	307.14	310.83	n/a	n/a	Overburden	Y
n/a	566765	4811309	305.8	300.8	307.26	307.698	n/a	n/a	Overburden	Y
n/a	568212	4809843	306.89	301.89	307.26	310.621	n/a	n/a	Overburden	Y
n/a	567260	4810328	303.33	298.33	307.27	307.999	n/a	n/a	Overburden	Y
n/a	567102	4811878	311.13	306.13	307.33	309.003	n/a	n/a	Overburden	Y
n/a	567817	4809323	303.82	298.82	307.39	308.994	n/a	n/a	Overburden	Y
n/a	567379	4810979	300.75	295.75	307.43	308.401	n/a	n/a	Overburden	Y
n/a	567639	4810138	307.81	302.81	307.46	308.906	n/a	n/a	Overburden	Y
n/a	568222	4810233	308.06	303.06	307.57	310.17	n/a	n/a	Overburden	Y
n/a	567599	4811606	303.98	298.98	307.76	307.931	n/a	n/a	Overburden	Y
n/a	567612	4811354	301.42	296.42	307.77	307.774	n/a	n/a	Overburden	Y
n/a	566866	4811330	302.75	297.75	307.91	307.701	n/a	n/a	Overburden	Y
n/a	567510	4811567	299.08	294.08	307.94	307.743	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6709858	571476	4810883	301.4	296.4	308.54	315.519	n/a	n/a	Overburden	Y
n/a	566408	4811545	309.66	304.66	308.65	308.048	n/a	n/a	Overburden	Y
6711419	566472	4811544	308.28	303.28	308.72	308.161	n/a	n/a	Overburden	Y
n/a	566410	4811537	308	303	308.8	308.024	n/a	n/a	Overburden	Y
n/a	566556	4811410	303.91	298.91	308.85	307.783	n/a	n/a	Overburden	Y
n/a	566483	4811776	307.48	302.48	308.93	309.176	n/a	n/a	Overburden	Y
n/a	566910	4811750	305.5	300.5	309.05	308.283	n/a	n/a	Overburden	Y
6704817	571344	4810924	296.99	291.99	309.1	315.999	n/a	n/a	Overburden	Y
6708127	566934	4812403	310.96	306.69	309.91	310.326	n/a	n/a	Overburden	Y
6710043	571313	4811285	302.68	297.68	310.16	317.112	n/a	n/a	Overburden	Y
6706444	568514	4810943	311.41	306.41	310.56	310.457	n/a	n/a	Overburden	Y
6710596	571092	4810988	294.14	289.14	310.57	316.642	n/a	n/a	Overburden	Y
6709780	571147	4810936	291.15	286.15	310.7	316.423	n/a	n/a	Overburden	Y
6711667	571550	4811051	301.08	296.08	310.71	315.92	n/a	n/a	Overburden	Y
6711904	571161	4810840	301.31	296.31	310.75	316.119	n/a	n/a	Overburden	Y
n/a	566756	4811894	311.59	306.59	310.87	309.334	n/a	n/a	Overburden	Y
6702539	571435	4810956	298.44	293.44	311.24	315.891	n/a	n/a	Overburden	Y
6712476	568925	4812654	307.85	302.85	311.24	312.818	n/a	n/a	Overburden	Y
6709672	569076	4813331	312.41	307.41	311.71	312.511	n/a	n/a	Overburden	Y
6712277	570894	4810888	301.92	296.92	311.82	316.587	n/a	n/a	Overburden	Y
6710040	571606	4811618	306.62	301.62	311.9	317.655	n/a	n/a	Overburden	Y
6705095	571306	4811126	299.94	294.94	312.9	316.694	n/a	n/a	Overburden	Y
6704136	571494	4811053	301.96	296.96	313.08	316.079	n/a	n/a	Overburden	Y
6710042	571272	4811260	308.29	303.29	313.36	317.108	n/a	n/a	Overburden	Y
6712255	571732	4811523	304.08	299.08	313.77	317.169	n/a	n/a	Overburden	Y
6702532	571179	4810887	297.79	292.79	314.05	316.224	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6710443	570891	4810871	298.85	293.85	314.47	316.545	n/a	n/a	Overburden	Y
6712163	571677	4811143	303.62	298.62	314.79	315.905	n/a	n/a	Overburden	Y
6710720	571116	4811018	297.09	292.09	314.98	316.686	n/a	n/a	Overburden	Y
6710494	571727	4811661	312.44	307.44	317.28	317.61	n/a	n/a	Overburden	Y
6702672	571516	4811036	302.25	297.25	318.02	315.962	n/a	n/a	Overburden	Y
6711290	571996	4811693	305.07	300.07	318.59	317.206	n/a	n/a	Overburden	Y
6711984	571962	4811637	303.58	298.58	318.9	317.092	n/a	n/a	Overburden	Y
6702656	570223	4813802	313.89	308.89	319	319.901	n/a	n/a	Overburden	Y
6712487	571865	4811680	305.76	300.76	319.6	317.427	n/a	n/a	Overburden	Y
6710657	567375	4814086	312.44	307.44	319.75	323.751	n/a	n/a	Overburden	Y
n/a	568607	4814561	325.07	320.07	321.1	321.141	n/a	n/a	Overburden	Y
6702535	570569	4809764	312.39	307.39	321.38	313.095	n/a	n/a	Overburden	Y
6702542	570564	4810063	311.52	306.52	321.76	314.159	n/a	n/a	Overburden	Y
6710785	570269	4814216	321.17	316.17	323.36	322.153	n/a	n/a	Overburden	Y
n/a	568617	4814742	329.91	324.91	323.4	322.9	n/a	n/a	Overburden	Y
6702654	570257	4813957	314.66	309.66	323.79	320.91	n/a	n/a	Overburden	Y
n/a	569996	4815301	318.15	313.15	323.84	326.073	n/a	n/a	Overburden	Y
6705984	569665	4815661	324.09	319.09	323.93	324.974	n/a	n/a	Overburden	Y
n/a	570334	4815022	326.02	321.02	324.5	325.927	n/a	n/a	Overburden	Y
n/a	570622	4815502	320.29	315.29	324.64	326.35	n/a	n/a	Overburden	Y
6704730	570693	4814511	320.69	315.69	324.75	324.785	n/a	n/a	Overburden	Y
n/a	570162	4815309	314.85	309.85	325.11	326.125	n/a	n/a	Overburden	Y
n/a	570205	4814901	322.32	317.32	325.56	324.941	n/a	n/a	Overburden	Y
6707382	570654	4814363	324.92	319.92	325.71	323.994	n/a	n/a	Overburden	Y
6703501	570694	4814383	325.58	320.58	325.94	324.168	n/a	n/a	Overburden	Y
n/a	570825	4815022	328.34	323.34	326.06	326.918	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
n/a	570387	4815749	318.69	313.69	326.21	326.125	n/a	n/a	Overburden	Y
6707995	566454	4814523	320.28	315.28	326.68	328.765	n/a	n/a	Overburden	Y
n/a	570524	4814845	327.82	322.82	327.71	325.931	n/a	n/a	Overburden	Y
6711712	570389	4815590	321.79	316.79	329.06	326.232	n/a	n/a	Overburden	Y
6710354	570568	4814580	324.72	319.72	332.78	324.879	n/a	n/a	Overburden	Y
6704042	569774	4809483	301.51	296.51	303.12	312.338	n/a	n/a	Overburden	Y
6702534	570611	4810062	296.02	291.02	305.45	314.127	n/a	n/a	Overburden	Y
6704693	568214	4809488	294.41	289.41	305.57	310.514	n/a	n/a	Overburden	Y
6706874	569474	4809943	304.25	299.25	306.06	313.43	n/a	n/a	Overburden	Y
6705870	567138	4812055	299.51	294.51	306.75	309.51	n/a	n/a	Overburden	Y
6703852	567734	4811693	303.25	298.25	306.77	308.59	n/a	n/a	Overburden	Y
n/a	567000	4810090	296.97	291.97	307	306.191	n/a	n/a	Overburden	Y
n/a	568803	4809727	306.01	301.01	307.11	311.693	n/a	n/a	Overburden	Y
n/a	568610	4809499	296.16	291.16	307.14	310.859	n/a	n/a	Overburden	Y
6709991	571435	4810814	294.68	289.68	307.25	315.384	n/a	n/a	Overburden	Y
6704038	569614	4809823	306.65	301.65	307.36	313.272	n/a	n/a	Overburden	Y
n/a	568817	4809877	305.21	300.21	307.42	312.016	n/a	n/a	Overburden	Y
n/a	568769	4809970	297.15	292.15	307.46	311.963	n/a	n/a	Overburden	Y
n/a	567200	4810080	303.74	298.74	307.54	306.735	n/a	n/a	Overburden	Y
n/a	567000	4811024	295.54	290.54	307.54	306.984	n/a	n/a	Overburden	Y
n/a	567460	4811180	301.03	296.03	307.68	307.906	n/a	n/a	Overburden	Y
6702526	568622	4810945	297.69	292.69	307.79	311.016	n/a	n/a	Overburden	Y
6707523	568974	4813383	301.73	296.73	307.9	310.633	n/a	n/a	Overburden	Y
6705877	569575	4809782	304.16	299.16	307.95	313.144	n/a	n/a	Overburden	Y
6708315	568693	4813453	303.78	298.78	308.09	312.036	n/a	n/a	Overburden	Y
6711420	566825	4811417	300.5	295.5	308.32	307.718	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6711905	568960	4810383	299.89	294.89	308.38	312.749	n/a	n/a	Overburden	Y
6704389	569634	4809783	305.72	300.72	308.42	313.198	n/a	n/a	Overburden	Y
6710719	570928	4810921	298.39	293.39	308.47	316.639	n/a	n/a	Overburden	Y
6711008	571323	4811321	301.89	296.89	308.59	317.19	n/a	n/a	Overburden	Y
6707985	569054	4813403	308.06	303.06	308.63	311.902	n/a	n/a	Overburden	Y
6711283	568747	4812709	305.53	300.53	308.77	311.296	n/a	n/a	Overburden	Y
6702533	570683	4810240	297.73	292.73	308.88	314.7	n/a	n/a	Overburden	Y
6709927	571853	4811541	299.73	294.73	309.06	316.977	n/a	n/a	Overburden	Y
6709646	571359	4810949	293.65	288.65	309.15	316.044	n/a	n/a	Overburden	Y
6711908	569586	4809871	305.65	300.65	309.17	313.358	n/a	n/a	Overburden	Y
6702653	569452	4813059	311.76	306.76	309.92	315.002	n/a	n/a	Overburden	Y
6710440	571892	4811504	295.99	290.99	310.31	316.754	n/a	n/a	Overburden	Y
6704325	567154	4812093	300.66	295.66	310.4	309.517	n/a	n/a	Overburden	Y
6702673	571564	4811086	299.81	294.81	310.9	316.008	n/a	n/a	Overburden	Y
6712162	571452	4811385	304.45	299.45	310.99	317.181	n/a	n/a	Overburden	Y
6704046	570604	4810053	299.03	294.03	311.07	314.1	n/a	n/a	Overburden	Y
6702652	569231	4813261	308.9	303.9	311.2	313.284	n/a	n/a	Overburden	Y
6711822	570969	4810622	301.25	296.25	311.22	315.749	n/a	n/a	Overburden	Y
6711985	571656	4811554	303.04	298.04	311.28	317.398	n/a	n/a	Overburden	Y
6702519	568958	4813406	304.41	299.41	311.41	310.701	n/a	n/a	Overburden	Y
6710770	570979	4810976	296.64	291.64	311.57	316.735	n/a	n/a	Overburden	Y
n/a	571139	4811499	299.53	294.53	311.59	317.755	n/a	n/a	Overburden	Y
6703873	569044	4813343	303	298	311.68	311.143	n/a	n/a	Overburden	Y
6707586	569534	4813063	310.86	305.86	312.07	315.568	n/a	n/a	Overburden	Y
6702520	568800	4813486	304.04	299.04	312.31	311.891	n/a	n/a	Overburden	Y
6704957	569227	4813097	306.83	301.83	312.37	312.954	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6707091	570294	4812123	306.56	301.56	312.48	318.589	n/a	n/a	Overburden	Y
6710415	571754	4811551	304.06	299.06	312.53	317.222	n/a	n/a	Overburden	Y
6709476	569413	4811511	300.87	295.87	312.61	314.188	n/a	n/a	Overburden	Y
6711692	568922	4813430	308.5	303.5	312.9	310.92	n/a	n/a	Overburden	Y
6703850	571494	4811143	300.91	295.91	312.94	316.375	n/a	n/a	Overburden	Y
6711150	568904	4813340	305.74	300.74	313.1	310.802	n/a	n/a	Overburden	Y
6711440	571456	4811452	300.09	295.09	313.13	317.367	n/a	n/a	Overburden	Y
6712223	569431	4811760	306.86	301.86	313.16	313.787	n/a	n/a	Overburden	Y
6702663	571851	4811430	299.09	294.09	313.31	316.572	n/a	n/a	Overburden	Y
6707595	571674	4811183	298.85	293.85	313.38	316.067	n/a	n/a	Overburden	Y
6707588	571574	4811123	300.35	295.35	313.41	316.118	n/a	n/a	Overburden	Y
6702527	569797	4812195	309.4	304.4	313.41	316.891	n/a	n/a	Overburden	Y
6708057	571514	4811043	299.18	294.18	313.44	315.991	n/a	n/a	Overburden	Y
6709100	571545	4811115	301.77	296.77	313.55	316.169	n/a	n/a	Overburden	Y
6704330	569014	4813423	301.61	296.61	313.79	311.397	n/a	n/a	Overburden	Y
6702507	566824	4812988	302.69	297.69	313.91	315.861	n/a	n/a	Overburden	Y
6704401	569454	4812703	298.04	293.04	314.12	314.74	n/a	n/a	Overburden	Y
6704673	567673	4813039	309.65	304.65	314.26	313.465	n/a	n/a	Overburden	Y
n/a	568445	4813462	303.43	298.43	314.28	311.921	n/a	n/a	Overburden	Y
6704397	568954	4813403	305.89	300.89	314.7	310.674	n/a	n/a	Overburden	Y
6702511	568160	4814041	307.85	302.85	314.97	318.679	n/a	n/a	Overburden	Y
6702518	567626	4812895	305.59	300.59	315.07	312.785	n/a	n/a	Overburden	Y
6711149	571502	4811438	300.67	295.67	315.27	317.263	n/a	n/a	Overburden	Y
6704843	566121	4813361	305.07	300.07	315.94	324.668	n/a	n/a	Overburden	Y
6711569	571135	4811051	294.87	289.87	316.08	316.744	n/a	n/a	Overburden	Y
6702645	568170	4814121	309.4	304.4	316.49	319.37	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6703857	572134	4811763	311.51	306.51	316.53	317.077	n/a	n/a	Overburden	Y
6707509	569114	4814363	305.42	300.42	318.46	318.044	n/a	n/a	Overburden	Y
6702506	567307	4814740	308.77	303.77	318.8	328.474	n/a	n/a	Overburden	Y
6710735	571109	4814142	310	305	319.73	323.401	n/a	n/a	Overburden	Y
6707576	570434	4811983	305.77	300.77	319.75	318.631	n/a	n/a	Overburden	Y
6704395	572184	4813023	304.74	299.74	320.03	320.559	n/a	n/a	Overburden	Y
6707510	569094	4814363	305.37	300.37	320.38	317.99	n/a	n/a	Overburden	Y
6712248	567476	4814168	303.69	298.69	320.64	323.788	n/a	n/a	Overburden	Y
6702659	571610	4813418	308.13	303.13	320.74	321.477	n/a	n/a	Overburden	Y
6705092	570730	4814573	315.42	310.42	320.88	325.164	n/a	n/a	Overburden	Y
6704295	567674	4814563	309.24	304.24	321.48	325.774	n/a	n/a	Overburden	Y
6709773	567562	4814194	302.61	297.61	321.52	323.603	n/a	n/a	Overburden	Y
6703155	571734	4813473	308.12	303.12	322.01	321.759	n/a	n/a	Overburden	Y
6710734	571141	4814193	307.3	302.3	322.16	323.598	n/a	n/a	Overburden	Y
6710250	569383	4811731	309.27	304.27	322.21	313.508	n/a	n/a	Overburden	Y
n/a	569561	4814976	312.03	307.03	322.26	321.792	n/a	n/a	Overburden	Y
6707623	570862	4814453	313.17	308.17	323.1	324.762	n/a	n/a	Overburden	Y
n/a	570434	4815297	316.13	311.13	323.32	326.318	n/a	n/a	Overburden	Y
6705510	570975	4810584	304.74	299.74	324.19	315.622	n/a	n/a	Overburden	Y
6707664	570814	4814483	315.56	310.56	324.33	324.839	n/a	n/a	Overburden	Y
6712161	569796	4815360	310.32	305.32	324.79	324.726	n/a	n/a	Overburden	Y
6704580	571307	4814015	304.91	299.91	324.92	322.763	n/a	n/a	Overburden	Y
n/a	570861	4815176	322.17	317.17	325.49	327.497	n/a	n/a	Overburden	Y
6710980	567254	4814007	310.5	305.5	325.64	323.649	n/a	n/a	Overburden	Y
6703935	570154	4815713	314.56	309.56	326.03	325.953	n/a	n/a	Overburden	Y
n/a	570825	4815656	314.35	309.35	326.15	327.044	n/a	n/a	Overburden	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6703934	570084	4815693	313.98	308.98	326.71	325.865	n/a	n/a	Overburden	Y
6710357	570099	4815643	311.84	306.84	326.76	325.911	n/a	n/a	Overburden	Y
6704466	566674	4814703	309.53	304.53	327.54	329.498	n/a	n/a	Overburden	Y
6703848	566424	4814763	328.71	323.71	329.01	329.839	n/a	n/a	Overburden	Y
6704043	569894	4813453	316.43	311.43	329.14	317.063	n/a	n/a	Overburden	Y
6704767	570492	4815885	317.86	312.86	329.32	326.771	n/a	n/a	Overburden	Y
6703150	566514	4814783	327.58	322.58	330.06	329.896	n/a	n/a	Overburden	Y
6705005	566708	4814830	326.97	321.97	330.37	330.19	n/a	n/a	Overburden	Y
6707984	567254	4815183	329.4	324.4	330.44	330.483	n/a	n/a	Overburden	Y
6702505	567352	4814883	323.68	318.68	331.61	329.317	n/a	n/a	Overburden	Y
6709138	568199	4815620	323.22	318.22	334.06	330.867	n/a	n/a	Overburden	Y
6702544	570559	4809818	294.56	289.56	300.06	313.293	n/a	n/a	Bedrock	Y
6711317	568454	4809354	297.09	292.09	302.15	310.739	n/a	n/a	Bedrock	Y
6702510	567261	4812616	296.88	291.88	304.04	311.768	n/a	n/a	Bedrock	Y
6702543	571138	4810754	293.71	288.71	304.4	315.877	n/a	n/a	Bedrock	Y
6705330	568095	4809837	288.6	283.6	304.98	310.19	n/a	n/a	Bedrock	Y
6703855	570534	4809973	292.06	287.06	305.18	313.857	n/a	n/a	Bedrock	Y
6704041	567724	4811683	294.98	289.98	305.22	308.557	n/a	n/a	Bedrock	Y
6708317	568700	4813342	301.83	296.83	306.51	311.769	n/a	n/a	Bedrock	Y
n/a	567098	4810050	295.26	290.26	307.21	306.549	n/a	n/a	Bedrock	Y
6703151	569034	4813523	300.95	295.95	307.32	312.937	n/a	n/a	Bedrock	Y
6702512	568527	4813668	303.39	298.39	307.8	312.521	n/a	n/a	Bedrock	Y
6705008	567593	4812085	294.47	289.47	307.86	309.488	n/a	n/a	Bedrock	Y
6708493	568928	4813684	303.8	298.8	308.45	313.048	n/a	n/a	Bedrock	Y
6709413	570395	4813932	292.33	287.33	308.49	321.219	n/a	n/a	Bedrock	Y
6702662	571493	4811063	298.35	293.35	308.59	316.108	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6702354	567032	4812124	300.83	295.83	308.88	309.693	n/a	n/a	Bedrock	Y
6707579	568834	4813483	303.61	298.61	308.93	311.592	n/a	n/a	Bedrock	Y
6705773	569305	4811654	300.86	295.86	309.17	313.219	n/a	n/a	Bedrock	Y
6702521	568986	4813391	300.31	295.31	310.07	310.725	n/a	n/a	Bedrock	Y
6703496	569944	4812433	304.5	299.5	310.07	317.793	n/a	n/a	Bedrock	Y
6711545	570823	4810768	299.78	294.78	310.3	316.309	n/a	n/a	Bedrock	Y
6707386	571314	4811043	292.6	287.6	310.31	316.421	n/a	n/a	Bedrock	Y
6702523	569267	4813098	304.69	299.69	310.51	313.418	n/a	n/a	Bedrock	Y
6711281	568817	4812602	301.35	296.35	310.57	311.821	n/a	n/a	Bedrock	Y
6711762	568867	4812703	301.82	296.82	310.73	311.584	n/a	n/a	Bedrock	Y
6707381	568934	4813483	301.94	296.94	310.82	311.378	n/a	n/a	Bedrock	Y
6711879	571584	4811029	296.12	291.12	310.83	315.73	n/a	n/a	Bedrock	Y
6711101	571372	4811391	300.14	295.14	310.85	317.308	n/a	n/a	Bedrock	Y
6703314	566754	4812643	310.73	305.73	310.87	311.432	n/a	n/a	Bedrock	Y
6702522	568903	4813438	302.59	297.59	310.97	310.98	n/a	n/a	Bedrock	Y
6706916	568814	4810343	292.7	287.7	311.05	311.964	n/a	n/a	Bedrock	Y
6702508	567189	4812498	303.56	298.56	311.23	311.229	n/a	n/a	Bedrock	Y
6712002	570371	4812065	304.7	299.7	311.25	318.649	n/a	n/a	Bedrock	Y
6702658	570439	4811943	301.21	296.21	311.6	318.565	n/a	n/a	Bedrock	Y
6707587	569474	4812983	304.83	299.83	311.68	315.024	n/a	n/a	Bedrock	Y
6712021	571020	4810584	299.44	294.44	311.77	315.537	n/a	n/a	Bedrock	Y
6712203	571008	4810662	293.08	288.08	311.81	315.815	n/a	n/a	Bedrock	Y
6708922	571571	4811075	296.96	291.96	311.88	315.944	n/a	n/a	Bedrock	Y
6702509	568391	4813760	304.27	299.27	311.92	314.226	n/a	n/a	Bedrock	Y
6702647	568915	4813584	304.01	299.01	312.13	311.982	n/a	n/a	Bedrock	Y
6708590	569104	4813309	300.78	295.78	312.25	311.892	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6707590	568914	4813503	301.77	296.77	312.34	311.464	n/a	n/a	Bedrock	Y
6706258	568794	4813503	302.26	297.26	312.37	311.961	n/a	n/a	Bedrock	Y
6712204	571027	4810632	294.79	289.79	312.51	315.685	n/a	n/a	Bedrock	Y
6702665	571498	4811003	294.93	289.93	312.72	315.882	n/a	n/a	Bedrock	Y
6711006	571509	4811487	299.36	294.36	313.47	317.4	n/a	n/a	Bedrock	Y
6702529	569838	4812082	305.32	300.32	313.76	316.997	n/a	n/a	Bedrock	Y
6707591	568854	4813543	302.67	297.67	313.95	311.759	n/a	n/a	Bedrock	Y
6703313	571494	4810923	292.31	287.31	314.03	315.598	n/a	n/a	Bedrock	Y
6704790	569069	4813439	300.12	295.12	314.31	312.506	n/a	n/a	Bedrock	Y
6706778	571494	4810983	294.56	289.56	315.3	315.818	n/a	n/a	Bedrock	Y
6707593	568349	4813759	303.88	298.88	315.37	314.625	n/a	n/a	Bedrock	Y
6712276	567448	4814044	300.66	295.66	315.68	323.005	n/a	n/a	Bedrock	Y
6704519	569344	4813343	304.41	299.41	316.06	315.021	n/a	n/a	Bedrock	Y
6711416	567367	4813986	303.92	298.92	316.08	322.948	n/a	n/a	Bedrock	Y
6709634	568293	4814156	305.63	300.63	316.84	318.687	n/a	n/a	Bedrock	Y
6709001	568279	4814202	306.39	301.39	317.12	319.327	n/a	n/a	Bedrock	Y
6710981	567314	4813921	305.26	300.26	318.71	322.663	n/a	n/a	Bedrock	Y
6710777	567237	4813973	310.1	305.1	318.76	323.442	n/a	n/a	Bedrock	Y
6707678	571014	4812283	304.34	299.34	318.78	319.174	n/a	n/a	Bedrock	Y
6704032	569764	4813408	310.79	305.79	318.86	316.841	n/a	n/a	Bedrock	Y
6704534	570134	4813733	302.63	297.63	318.97	319.071	n/a	n/a	Bedrock	Y
6710919	567405	4814099	303.08	298.08	319.19	323.621	n/a	n/a	Bedrock	Y
6710737	567243	4813972	310.22	305.22	319.27	323.408	n/a	n/a	Bedrock	Y
6707517	571494	4813643	304.53	299.53	319.68	321.544	n/a	n/a	Bedrock	Y
6709238	571285	4814060	301.92	296.92	319.86	322.964	n/a	n/a	Bedrock	Y
6710282	571966	4811761	301.74	296.74	320.58	317.476	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6710281	571947	4811801	302.07	297.07	320.84	317.64	n/a	n/a	Bedrock	Y
6704691	569747	4813387	310.26	305.26	321.06	316.813	n/a	n/a	Bedrock	Y
6710353	571902	4811493	294.65	289.65	322.95	316.689	n/a	n/a	Bedrock	Y
6711129	571567	4811505	300.69	295.69	324.75	317.38	n/a	n/a	Bedrock	Y
6702753	569954	4815470	310.18	305.18	324.89	325.606	n/a	n/a	Bedrock	Y
6709879	569832	4815502	309.17	304.17	324.89	325.118	n/a	n/a	Bedrock	Y
6703163	569674	4815763	311.3	306.3	325.15	325.207	n/a	n/a	Bedrock	Y
6703250	570354	4815843	313.58	308.58	328.31	326.471	n/a	n/a	Bedrock	Y
6705404	566840	4814992	308.18	303.18	329.91	330.589	n/a	n/a	Bedrock	Y
6702504	567204	4815026	310.52	305.52	329.93	330.209	n/a	n/a	Bedrock	Y
6702755	571022	4814599	317.36	312.36	330.81	325.663	n/a	n/a	Bedrock	Y
6711016	566645	4815009	307.7	302.7	335.04	330.682	n/a	n/a	Bedrock	Y
6707457	567794	4809923	283.48	278.48	304.11	309.588	n/a	n/a	Bedrock	Y
6702325	567471	4810184	291.26	286.26	304.67	308.296	n/a	n/a	Bedrock	Y
6711087	571421	4811476	297.33	292.33	305.63	317.449	n/a	n/a	Bedrock	Y
6702287	567141	4809885	292.88	287.88	306.55	307.578	n/a	n/a	Bedrock	Y
6703552	567794	4811613	292.76	287.76	306.65	308.956	n/a	n/a	Bedrock	Y
6707762	568554	4810923	291.7	286.7	306.83	310.623	n/a	n/a	Bedrock	Y
6708266	568878	4813528	299.88	294.88	307.58	311.52	n/a	n/a	Bedrock	Y
6710473	571674	4811271	295.59	290.59	308.72	316.374	n/a	n/a	Bedrock	Y
6711745	566845	4811436	295.44	290.44	308.75	307.726	n/a	n/a	Bedrock	Y
6711288	569424	4811792	298.7	293.7	308.99	313.669	n/a	n/a	Bedrock	Y
6705091	565540	4811635	293.07	288.07	309.19	316.522	n/a	n/a	Bedrock	Y
6708578	568587	4813470	301.04	296.04	309.19	311.976	n/a	n/a	Bedrock	Y
6710441	572024	4811656	296.94	291.94	309.59	316.975	n/a	n/a	Bedrock	Y
6702516	568291	4813582	301.32	296.32	310.18	313.969	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6711378	569488	4811604	301.87	296.87	310.73	314.419	n/a	n/a	Bedrock	Y
6711936	568461	4812560	299.03	294.03	310.82	310.453	n/a	n/a	Bedrock	Y
6706256	571574	4811093	295.54	290.54	311.57	315.985	n/a	n/a	Bedrock	Y
6707592	568894	4813443	300.57	295.57	311.9	310.966	n/a	n/a	Bedrock	Y
6705876	565508	4812167	295.59	290.59	312.08	319.658	n/a	n/a	Bedrock	Y
6702528	569943	4812220	299.51	294.51	312.23	317.65	n/a	n/a	Bedrock	Y
6707589	568174	4813523	300.57	295.57	312.68	314.517	n/a	n/a	Bedrock	Y
6710048	570834	4812414	306.26	301.26	313.08	319.491	n/a	n/a	Bedrock	Y
6702671	571516	4811026	293.54	288.54	313.99	315.893	n/a	n/a	Bedrock	Y
6703544	571684	4811203	292.19	287.19	314.11	316.086	n/a	n/a	Bedrock	Y
6711543	567193	4813996	303.22	298.22	316.3	323.751	n/a	n/a	Bedrock	Y
6712390	567251	4813926	308.17	303.17	317.61	322.948	n/a	n/a	Bedrock	Y
6702530	570404	4811875	298.5	293.5	317.88	318.408	n/a	n/a	Bedrock	Y
6707241	569494	4812183	301.87	296.87	318.48	314.565	n/a	n/a	Bedrock	Y
6711000	567250	4813891	306.11	301.11	319.1	322.674	n/a	n/a	Bedrock	Y
6711206	567274	4813957	306.89	301.89	319.26	323.094	n/a	n/a	Bedrock	Y
6704637	572281	4813000	302.27	297.27	320.23	320.236	n/a	n/a	Bedrock	Y
6710452	567234	4814135	300.89	295.89	321.14	324.548	n/a	n/a	Bedrock	Y
6707585	569874	4812423	301.6	296.6	321.73	317.455	n/a	n/a	Bedrock	Y
6710453	567223	4814193	298.63	293.63	321.78	324.959	n/a	n/a	Bedrock	Y
6703384	566564	4814803	307.27	302.27	323.99	329.95	n/a	n/a	Bedrock	Y
6702502	567236	4815011	303.1	298.1	324.05	330.101	n/a	n/a	Bedrock	Y
6712462	569753	4813403	302.96	297.96	324.13	316.807	n/a	n/a	Bedrock	Y
6702500	567136	4814963	304.24	299.24	324.15	330.056	n/a	n/a	Bedrock	Y
n/a	570861	4815146	320.99	315.99	325.11	327.427	n/a	n/a	Bedrock	Y
6703809	567204	4814973	301.14	296.14	325.77	330.031	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6710998	567210	4814155	304.81	299.81	325.94	324.771	n/a	n/a	Bedrock	Y
6702651	570745	4814449	305.97	300.97	326.01	324.552	n/a	n/a	Bedrock	Y
6710122	567268	4814965	303.1	298.1	326.28	329.942	n/a	n/a	Bedrock	Y
6704690	570503	4814793	307.74	302.74	326.57	325.636	n/a	n/a	Bedrock	Y
6702501	566936	4815030	303.33	298.33	328.02	330.542	n/a	n/a	Bedrock	Y
6710455	566870	4814987	306.19	301.19	330.26	330.514	n/a	n/a	Bedrock	Y
6707910	567314	4815423	306.38	301.38	332.38	331.041	n/a	n/a	Bedrock	Y
n/a	569002	4812639	294.91	289.91	303.35	310.506	n/a	n/a	Bedrock	Y
6706771	567214	4812523	293.97	288.97	303.88	311.438	n/a	n/a	Bedrock	Y
6711570	570942	4810908	292.49	287.49	304.95	316.392	n/a	n/a	Bedrock	Y
6711125	570908	4810689	291.97	286.97	307.83	315.569	n/a	n/a	Bedrock	Y
6707223	569454	4811823	297.45	292.45	308.49	313.842	n/a	n/a	Bedrock	Y
6707637	568114	4814103	298.31	293.31	308.74	319.608	n/a	n/a	Bedrock	Y
6711821	570314	4812071	298.68	293.68	308.74	318.381	n/a	n/a	Bedrock	Y
6709781	570746	4810738	294.91	289.91	308.98	315.852	n/a	n/a	Bedrock	Y
6711417	570888	4810595	293.36	288.36	309.52	315.166	n/a	n/a	Bedrock	Y
6704402	571294	4810923	290.25	285.25	309.61	316.057	n/a	n/a	Bedrock	Y
6710853	567288	4814280	293.07	288.07	309.76	325.111	n/a	n/a	Bedrock	Y
6707271	569314	4811663	295.75	290.75	309.97	313.21	n/a	n/a	Bedrock	Y
6702531	570429	4811843	294.55	289.55	310.81	318.133	n/a	n/a	Bedrock	Y
6712401	571536	4811528	295.22	290.22	310.81	317.146	n/a	n/a	Bedrock	Y
6707339	569354	4813163	297.62	292.62	311.41	314.295	n/a	n/a	Bedrock	Y
6712063	570925	4810655	292.55	287.55	311.82	315.384	n/a	n/a	Bedrock	Y
6705880	568383	4813747	296.55	291.55	312.7	314.255	n/a	n/a	Bedrock	Y
6708205	567931	4813572	294.81	289.81	312.86	316.391	n/a	n/a	Bedrock	Y
6710084	571422	4811357	291.48	286.48	313	316.847	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6709102	570456	4811904	296.4	291.4	313.05	318.241	n/a	n/a	Bedrock	Y
6712259	571724	4811484	295.27	290.27	313.19	316.643	n/a	n/a	Bedrock	Y
6708700	570797	4812633	297.24	292.24	314.06	319.498	n/a	n/a	Bedrock	Y
6708415	571811	4811592	295.5	290.5	314.36	316.852	n/a	n/a	Bedrock	Y
6710918	567033	4813999	298.64	293.64	315.59	324.092	n/a	n/a	Bedrock	Y
6706624	570174	4815083	301.67	296.67	316.72	325.531	n/a	n/a	Bedrock	Y
6709101	570866	4812341	299.41	294.41	317.48	319.029	n/a	n/a	Bedrock	Y
6704850	571665	4813240	300.41	295.41	319.09	321.107	n/a	n/a	Bedrock	Y
6711802	567180	4814103	294.29	289.29	319.19	324.263	n/a	n/a	Bedrock	Y
6706667	571914	4812923	298.44	293.44	319.51	320.527	n/a	n/a	Bedrock	Y
6710454	567406	4814209	293.28	288.28	320.64	324.244	n/a	n/a	Bedrock	Y
6711298	567211	4814129	294.26	289.26	322.07	324.335	n/a	n/a	Bedrock	Y
6704962	571036	4814394	304.84	299.84	323.69	324.408	n/a	n/a	Bedrock	Y
6711077	570035	4815041	301.69	296.69	324.31	324.911	n/a	n/a	Bedrock	Y
6704018	570244	4815753	304.13	299.13	325.19	326.129	n/a	n/a	Bedrock	Y
6705873	570262	4815039	302.31	297.31	325.6	325.617	n/a	n/a	Bedrock	Y
6703154	570724	4814433	300.43	295.43	326.81	324.339	n/a	n/a	Bedrock	Y
6703431	568974	4816163	300.68	295.68	331.44	330.584	n/a	n/a	Bedrock	Y
6711488	568133	4815081	303.61	298.61	331.52	327.381	n/a	n/a	Bedrock	Y
6704794	567419	4810108	284.8	279.8	308.88	308.345	n/a	n/a	Bedrock	Y
6707389	568954	4813463	295.41	290.41	310.96	310.05	n/a	n/a	Bedrock	Y
6708407	568633	4813324	293.64	288.64	311.42	312.043	n/a	n/a	Bedrock	Y
6711675	570661	4814445	298.47	293.47	312.43	323.769	n/a	n/a	Bedrock	Y
6710485	571694	4811530	290.17	285.17	313.64	315.172	n/a	n/a	Bedrock	Y
6702517	568366	4813668	293.74	288.74	314.06	314.232	n/a	n/a	Bedrock	Y
6708577	568759	4813444	295.09	290.09	314.64	311.824	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6706980	569494	4814523	296.84	291.84	321.24	318.654	n/a	n/a	Bedrock	Y
6706156	565814	4813543	290.58	285.58	324.8	322.928	n/a	n/a	Bedrock	Y
6712077	568457	4815067	293.44	288.44	325.87	325.653	n/a	n/a	Bedrock	Y
6702650	569098	4813614	292.92	287.92	305.16	314.246	n/a	n/a	Bedrock	Y
6711394	567617	4812179	289.89	284.89	307.55	311.428	n/a	n/a	Bedrock	Y
6707577	569554	4811603	289.24	284.24	307.76	314.047	n/a	n/a	Bedrock	Y
6702327	567655	4811176	286.85	281.85	309.05	310.206	n/a	n/a	Bedrock	Y
6710177	571453	4811389	290.6	285.6	310.38	313.475	n/a	n/a	Bedrock	Y
6712209	570062	4812193	292.66	287.66	311.42	317.176	n/a	n/a	Bedrock	Y
6709785	571760	4811588	291.46	286.46	311.52	313.562	n/a	n/a	Bedrock	Y
6707584	571034	4812283	290.83	285.83	313.37	317.142	n/a	n/a	Bedrock	Y
6702515	568765	4813521	292.32	287.32	315.09	311.821	n/a	n/a	Bedrock	Y
6709499	571027	4812595	292.97	287.97	319.09	317.732	n/a	n/a	Bedrock	Y
6707298	570714	4812063	291.05	286.05	319.63	316.544	n/a	n/a	Bedrock	Y
6702660	571915	4813224	295.22	290.22	320.8	318.574	n/a	n/a	Bedrock	Y
6711280	570156	4815082	297.06	292.06	326.26	324.89	n/a	n/a	Bedrock	Y
6710562	568664	4809522	277.32	272.32	293.66	307.788	n/a	n/a	Bedrock	Y
6706619	567434	4811683	283.01	278.01	305.73	311.808	n/a	n/a	Bedrock	Y
6708234	568219	4813623	291.32	286.32	305.89	315.584	n/a	n/a	Bedrock	Y
6703309	568134	4809933	280.73	275.73	306.18	308.972	n/a	n/a	Bedrock	Y
6703158	567214	4810823	279.3	274.3	306.92	310.434	n/a	n/a	Bedrock	Y
6704719	568191	4809783	280.4	275.4	307.29	308.768	n/a	n/a	Bedrock	Y
6708472	568760	4813465	291.23	286.23	308.83	312.101	n/a	n/a	Bedrock	Y
6711486	571727	4811433	287.39	282.39	309.01	311.3	n/a	n/a	Bedrock	Y
6711282	568661	4812623	285.74	280.74	309.22	311.38	n/a	n/a	Bedrock	Y
6710111	571674	4811436	287.01	282.01	309.4	311.453	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6705029	567317	4812307	283.28	278.28	310.11	313.371	n/a	n/a	Bedrock	Y
6708075	569214	4813223	290.29	285.29	310.12	310.757	n/a	n/a	Bedrock	Y
6712352	567484	4814090	289.79	284.79	313.07	320.797	n/a	n/a	Bedrock	Y
6712370	571787	4811620	292.86	287.86	313.9	311.942	n/a	n/a	Bedrock	Y
6705438	569171	4814467	292.27	287.27	314.15	320.335	n/a	n/a	Bedrock	Y
6710409	567084	4813795	287.24	282.24	314.25	319.408	n/a	n/a	Bedrock	Y
6710484	567278	4814252	287.96	282.96	314.48	321.132	n/a	n/a	Bedrock	Y
6711969	567145	4814090	286.67	281.67	316.09	320.487	n/a	n/a	Bedrock	Y
6711289	568085	4815040	292.19	287.19	320.67	324.026	n/a	n/a	Bedrock	Y
6712112	567399	4814151	287.23	282.23	321.74	320.922	n/a	n/a	Bedrock	Y
6703965	569414	4815543	293.13	288.13	323.65	325.396	n/a	n/a	Bedrock	Y
6711574	568308	4815049	287.6	282.6	325.97	324.256	n/a	n/a	Bedrock	Y
6711126	568443	4815015	287.68	282.68	328	324.331	n/a	n/a	Bedrock	Y
6711204	568392	4815115	287.4	282.4	328.25	324.428	n/a	n/a	Bedrock	Y
6711472	568504	4815648	290.7	285.7	329.01	325.277	n/a	n/a	Bedrock	Y
6711284	568429	4815087	287.49	282.49	329.91	324.418	n/a	n/a	Bedrock	Y
6703535	567884	4810143	266.42	261.42	300.02	309.094	n/a	n/a	Bedrock	Y
6705488	567634	4811560	280.22	275.22	300.46	311.515	n/a	n/a	Bedrock	Y
6711299	567755	4814391	276.5	271.5	300.91	322.136	n/a	n/a	Bedrock	Y
6705566	570354	4812050	289.48	284.48	303.53	315.065	n/a	n/a	Bedrock	Y
6707935	568334	4812943	282.24	277.24	304.85	312.831	n/a	n/a	Bedrock	Y
6708076	568354	4812983	280.72	275.72	305.08	312.885	n/a	n/a	Bedrock	Y
6711724	569957	4811308	278.16	273.16	305.13	311.239	n/a	n/a	Bedrock	Y
6709481	567941	4814561	279.05	274.05	305.5	322.9	n/a	n/a	Bedrock	Y
6708740	569075	4813762	281.21	276.21	306.76	315.415	n/a	n/a	Bedrock	Y
6706620	566474	4812183	274.74	269.74	306.98	313.765	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6709480	568005	4814603	283.21	278.21	307.32	323.101	n/a	n/a	Bedrock	Y
6707797	568974	4812563	278.56	273.56	307.74	311.377	n/a	n/a	Bedrock	Y
6711455	569561	4811898	280.09	275.09	307.86	312.901	n/a	n/a	Bedrock	Y
6703640	568574	4811553	277.35	272.35	308.03	310.696	n/a	n/a	Bedrock	Y
6711801	569167	4812847	277.23	272.23	308.21	308.1	n/a	n/a	Bedrock	Y
6712247	569167	4812847	277.23	272.23	308.21	308.1	n/a	n/a	Bedrock	Y
6704699	569078	4813573	285.18	280.18	308.89	313.758	n/a	n/a	Bedrock	Y
6709784	570964	4810635	281.46	276.46	309.13	309.211	n/a	n/a	Bedrock	Y
6710008	569484	4811644	276.74	271.74	309.17	311.996	n/a	n/a	Bedrock	Y
6703703	571414	4810853	279.93	274.93	309.75	309.378	n/a	n/a	Bedrock	Y
6711723	569656	4811874	281.91	276.91	311.16	313.168	n/a	n/a	Bedrock	Y
6707290	569194	4812803	277.63	272.63	311.24	309.959	n/a	n/a	Bedrock	Y
6707742	568714	4813583	283.63	278.63	311.31	313.547	n/a	n/a	Bedrock	Y
n/a	568860	4812797	274.7	269.7	311.64	310.814	n/a	n/a	Bedrock	Y
6712145	568212	4813479	277.32	272.32	311.92	315.478	n/a	n/a	Bedrock	Y
6703870	568464	4811503	267.19	262.19	312.37	310.593	n/a	n/a	Bedrock	Y
6707384	568734	4813623	286.25	281.25	312.4	313.062	n/a	n/a	Bedrock	Y
6707581	568374	4813103	280.63	275.63	313.71	313.191	n/a	n/a	Bedrock	Y
6711926	567211	4813858	273.63	268.63	313.85	319.68	n/a	n/a	Bedrock	Y
6706705	568074	4813403	278.29	273.29	314.19	315.667	n/a	n/a	Bedrock	Y
6710007	569955	4813426	279.19	274.19	314.25	317.23	n/a	n/a	Bedrock	Y
6707383	568394	4813663	285.73	280.73	314.25	315.676	n/a	n/a	Bedrock	Y
6702655	570187	4813889	281.61	276.61	314.66	320.276	n/a	n/a	Bedrock	Y
6710680	570907	4812719	288.97	283.97	314.83	317.072	n/a	n/a	Bedrock	Y
6709382	571007	4812571	282.84	277.84	315.1	316.667	n/a	n/a	Bedrock	Y
6709384	570809	4812624	288.25	283.25	315.22	316.899	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6706000	568749	4814191	282.8	277.8	315.33	318.886	n/a	n/a	Bedrock	Y
n/a	569037	4812797	277.58	272.58	315.59	301.493	n/a	n/a	Bedrock	Y
6711669	567430	4814174	280.08	275.08	316.56	320.985	n/a	n/a	Bedrock	Y
6711923	567346	4814287	280.55	275.55	316.71	321.258	n/a	n/a	Bedrock	Y
6711270	567649	4814311	276.5	271.5	316.97	321.715	n/a	n/a	Bedrock	Y
6704352	569574	4812903	281.38	276.38	317.52	314.083	n/a	n/a	Bedrock	Y
6709478	570658	4812485	282.39	277.39	317.7	316.571	n/a	n/a	Bedrock	Y
6711473	567264	4814276	275.72	270.72	317.75	321.134	n/a	n/a	Bedrock	Y
6711544	568053	4815021	285.53	280.53	318.68	323.922	n/a	n/a	Bedrock	Y
6712192	567520	4814191	278.54	273.54	318.82	321.142	n/a	n/a	Bedrock	Y
6710341	570868	4812349	281.96	276.96	318.95	316.323	n/a	n/a	Bedrock	Y
6710997	567596	4814247	277.86	272.86	320.24	321.437	n/a	n/a	Bedrock	Y
6702657	570310	4814090	283.09	278.09	320.39	321.644	n/a	n/a	Bedrock	Y
6711713	570175	4812374	280.68	275.68	320.65	316.022	n/a	n/a	Bedrock	Y
6707693	569094	4814363	285.26	280.26	320.68	320.582	n/a	n/a	Bedrock	Y
6712399	568572	4814981	279.26	274.26	320.95	324.38	n/a	n/a	Bedrock	Y
6711439	568593	4814887	285.55	280.55	321.75	324.288	n/a	n/a	Bedrock	Y
6712473	568504	4815044	279.93	274.93	322.37	324.4	n/a	n/a	Bedrock	Y
6703907	570554	4814473	291.13	286.13	325.01	322.891	n/a	n/a	Bedrock	Y
6710952	570141	4815237	277.23	272.23	325.41	324.88	n/a	n/a	Bedrock	Y
6710387	571037	4812996	276.8	271.8	289.66	317.664	n/a	n/a	Bedrock	Y
6709669	569318	4812734	269.33	264.33	295.39	312.193	n/a	n/a	Bedrock	Y
6704969	567832	4813260	271.62	266.62	297.44	316.049	n/a	n/a	Bedrock	Y
6710603	568383	4814775	272.01	267.01	300.63	323.931	n/a	n/a	Bedrock	Y
6710009	569682	4811635	272.96	267.96	304.3	311.735	n/a	n/a	Bedrock	Y
6711474	568333	4813676	269.91	264.91	304.73	316.344	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6708923	570552	4812191	273.69	268.69	306.28	315.527	n/a	n/a	Bedrock	Y
6707273	568954	4812523	266.56	261.56	309.47	311.537	n/a	n/a	Bedrock	Y
6707289	568874	4812723	274.83	269.83	310.42	311.205	n/a	n/a	Bedrock	Y
6706694	570514	4812023	271	266	312	314.908	n/a	n/a	Bedrock	Y
6711997	569519	4813144	269.93	264.93	312.04	313.381	n/a	n/a	Bedrock	Y
6711715	570553	4812185	271.6	266.6	312.37	315.51	n/a	n/a	Bedrock	Y
6712159	569604	4813231	274.12	269.12	312.55	314.346	n/a	n/a	Bedrock	Y
6712321	569694	4811655	272.88	267.88	312.66	311.847	n/a	n/a	Bedrock	Y
n/a	568870	4812485	266.96	261.96	312.85	311.596	n/a	n/a	Bedrock	Y
6709385	568151	4814028	268.73	263.73	315.19	319.384	n/a	n/a	Bedrock	Y
6711113	567229	4814364	274.68	269.68	316.06	321.31	n/a	n/a	Bedrock	Y
6710888	567417	4814097	273.45	268.45	319.81	320.68	n/a	n/a	Bedrock	Y
6710835	570259	4814207	280.02	275.02	320.01	322.183	n/a	n/a	Bedrock	Y
6709498	570997	4812491	276.77	271.77	320.37	316.452	n/a	n/a	Bedrock	Y
6710407	568248	4814779	269.79	264.79	321.03	323.761	n/a	n/a	Bedrock	Y
6712327	568166	4814755	270.14	265.14	321.22	323.609	n/a	n/a	Bedrock	Y
6712119	568471	4814862	277.07	272.07	321.24	324.137	n/a	n/a	Bedrock	Y
6707042	569414	4814423	275.79	270.79	321.81	321.783	n/a	n/a	Bedrock	Y
6708373	570422	4814251	276.25	271.25	321.82	322.348	n/a	n/a	Bedrock	Y
6710654	568635	4814877	269.52	264.52	328.13	324.322	n/a	n/a	Bedrock	Y
6711845	571043	4810933	246.6	241.6	303.69	310.223	n/a	n/a	Bedrock	Y
6708456	568504	4813622	257.84	252.84	303.83	315.281	n/a	n/a	Bedrock	Y
6708457	568528	4813674	258.67	253.67	304.36	315.471	n/a	n/a	Bedrock	Y
6711872	570240	4812553	254.95	249.95	309.59	316.061	n/a	n/a	Bedrock	Y
6712296	569007	4812634	258.98	253.98	310.9	311.195	n/a	n/a	Bedrock	Y
6712227	570996	4812571	253.51	248.51	314.11	316.613	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen /Open Interval Top (masl)	Screen /Open Interval Bottom (masl)	Observed Average Water Level (2009 to 2013 and 2015) (masl) ¹	Simulated Average Water Level (masl)	Observed Drawdown (0 to 3,600 m ³ /day) (m)	Simulated Drawdown (0 to 3,600 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6711021	568494	4814422	262.68	257.68	318.46	321.682	n/a	n/a	Bedrock	Y
6708652	570683	4812236	238.12	233.12	314.39	315.805	n/a	n/a	Bedrock	Y
6711771	568413	4814821	248.63	243.63	319.52	324.015	n/a	n/a	Bedrock	Y
6712093	568506	4814893	251.34	246.34	321.15	324.203	n/a	n/a	Bedrock	Y

n/a information not available

WWIS – Water Well Information System

Masl – meters above sea level

¹ Observed water levels for WWIS wells represent values collected over different time periods and potentially under different regional pumping conditions

TABLE A2 Calibration Dataset and Results - Erin

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
TW1-88	568376	4847829	410.80	393.60	423.1	425.85	6.40	7.49	Bedrock	N
MW05A-05	568339	4847771	410.56	404.47	423.78	425.63	4.08	4.02	Bedrock	N
MW06A-05	568741	4847572	411.72	408.67	422.18	420.75	0.68	0.94	Bedrock	N
MW11A-08	568784	4848063	411.80	407.23	426.9	426.09	n/a	n/a	Bedrock	N
MW12A-08	569279	4847593	407.90	404.86	424.85	416.94	n/a	n/a	Bedrock	N
D3	568160	4847870	418.72	410.80	425	428.78	1.67	1.96	Bedrock	N
D8	568759	4848313	412.32	390.07	427.3	428.69	0.44	0.85	Bedrock	N
D15	569038	4848475	408.35	406.83	427.38	428.59	n/a	n/a	Bedrock	N
D24A	567878	4847889	409.61	400.16	425.82	429.45	1.82	1.59	Bedrock	N
D24B	567891	4847804	410.93	399.04	425.2	429.13	1.72	1.61	Bedrock	N
D26A	568405	4847251	n/a	n/a	420.22	419.57	1.45	0.96	Bedrock	N
D26B	568348	4847311	398.50	396.06	420.22	420.55	n/a	n/a	Bedrock	N
D32	569198	4847127	404.50	390.18	413.45	412.51	0.10	0.15	Bedrock	N
D36B	569195	4847350	399.28	384.48	424.08	414.21	0.32	0.21	Bedrock	N
MW02-00	568432	4847705	428.07	426.66	428.29	429.56	0.00	0.06	Overburden	N
MW03A-00	568370	4847686	426.88	426.63	428.42	428.52	0.00	0.00	Overburden	N
MW03B-00	568370	4847686	428.13	427.94	428.31	428.52	0.00	0.00	Overburden	N
MW05B-05	568350	4847778	420.68	418.85	428.58	430.50	0.00	0.06	Overburden	N
MW06B-05	568741	4847574	426.63	425.10	428.33	429.38	0.00	0.11	Overburden	N
MW11B-08	568784	4848062	423.38	420.33	428.62	432.22	n/a	n/a	Overburden	N
MW12B-08	569281	4847591	434.26	431.22	431.7	431.37	n/a	n/a	Overburden	N
TW1-99	568515	4847847	422.48	420.04	428.53	431.55	0.00	0.10	Overburden	N
D7B	568370	4848313	n/a	n/a	435.5	435.90	0.00	0.01	Overburden	N
D26C	568329	4847305	n/a	n/a	434.72	425.03	n/a	n/a	Overburden	N

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
D36A	569178	4847335	n/a	n/a	435.06	426.30	0.00	-0.17	Overburden	N
6706674	571064	4846323	390.4	385.4	400.64	403.25	n/a	n/a	Bedrock	Y
6708665	568535	4846462	362.7	357.7	405.58	414.58	n/a	n/a	Bedrock	Y
6706591	569414	4847123	368.3	363.3	405.81	412.47	n/a	n/a	Bedrock	Y
6700710	569479	4846990	395.4	390.4	406.27	410.79	n/a	n/a	Bedrock	Y
6707233	569614	4846473	354.6	349.6	406.85	409.18	n/a	n/a	Bedrock	Y
6704921	569432	4847165	376.4	371.4	408.06	412.75	n/a	n/a	Bedrock	Y
6707351	570014	4848173	401.9	396.9	408.42	419.77	n/a	n/a	Bedrock	Y
6703622	570164	4845973	369.1	364.1	408.57	406.37	n/a	n/a	Bedrock	Y
6703617	568634	4846553	368.7	363.7	409.34	414.27	n/a	n/a	Bedrock	Y
6709574	569889	4845983	366.2	361.2	409.49	407.54	n/a	n/a	Bedrock	Y
6710155	567703	4845330	378.4	373.4	409.56	411.08	n/a	n/a	Bedrock	Y
6703960	568374	4847373	400.2	395.2	409.84	421.09	n/a	n/a	Bedrock	Y
6704991	569250	4847091	394.9	389.9	410.15	412.07	n/a	n/a	Bedrock	Y
6703808	569314	4846833	381.3	376.3	410.16	411.16	n/a	n/a	Bedrock	Y
6706588	569714	4846323	365.9	360.9	410.45	408.46	n/a	n/a	Bedrock	Y
6708632	569510	4847139	373.0	368.0	410.51	412.39	n/a	n/a	Bedrock	Y
6708725	570195	4845854	366.6	361.6	410.52	406.32	n/a	n/a	Bedrock	Y
6705561	568973	4846730	382.6	377.6	410.79	412.72	n/a	n/a	Bedrock	Y
6703704	569414	4847043	381.4	376.4	411.02	411.88	n/a	n/a	Bedrock	Y
6700677	567765	4846419	402.1	397.1	411.94	418.99	n/a	n/a	Bedrock	Y
6700676	568648	4847067	409.2	404.2	412.14	415.51	n/a	n/a	Bedrock	Y
6711066	570000	4846184	371.4	366.4	412.16	407.02	n/a	n/a	Bedrock	Y
6710535	570297	4845535	378.5	373.5	412.6	405.98	n/a	n/a	Bedrock	Y
6706403	569464	4846623	386.9	381.9	412.67	409.76	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6700711	569451	4847061	381.8	376.8	412.85	411.91	n/a	n/a	Bedrock	Y
6708631	569481	4847149	372.7	367.7	413.01	412.52	n/a	n/a	Bedrock	Y
6703621	569284	4847193	375.2	370.2	413.2	413.35	n/a	n/a	Bedrock	Y
6700708	570707	4845652	381.0	376.0	413.24	404.32	n/a	n/a	Bedrock	Y
6712435	571353	4846608	384.4	379.4	413.38	403.99	n/a	n/a	Bedrock	Y
6707864	569414	4847273	372.8	367.8	413.49	413.69	n/a	n/a	Bedrock	Y
6703647	570014	4846093	371.3	366.3	413.81	406.96	n/a	n/a	Bedrock	Y
6710528	567720	4846248	392.2	387.2	413.81	417.63	n/a	n/a	Bedrock	Y
6712437	569781	4846039	361.2	356.2	413.91	408.04	n/a	n/a	Bedrock	Y
6703623	569324	4847243	373.7	368.7	414.21	413.64	n/a	n/a	Bedrock	Y
6710144	570236	4845456	370.5	365.5	414.22	406.14	n/a	n/a	Bedrock	Y
6703186	571114	4846523	409.3	404.3	414.33	404.40	n/a	n/a	Overburden	Y
6700679	568013	4847639	411.4	406.4	414.36	426.81	n/a	n/a	Bedrock	Y
6704458	566589	4845848	404.4	399.4	414.36	419.96	n/a	n/a	Bedrock	Y
6710566	566595	4845926	393.6	388.6	414.47	421.09	n/a	n/a	Bedrock	Y
6705648	570168	4847799	398.1	393.1	414.72	416.38	n/a	n/a	Bedrock	Y
6710547	570538	4845437	392.9	387.9	415.14	405.21	n/a	n/a	Bedrock	Y
6709043	570486	4845481	392.7	387.7	415.31	405.47	n/a	n/a	Bedrock	Y
6700655	568538	4844747	376.7	371.7	415.6	407.89	n/a	n/a	Bedrock	Y
6705975	569454	4847483	370.6	365.6	415.61	415.55	n/a	n/a	Bedrock	Y
6707356	569214	4845823	387.4	382.4	415.63	410.46	n/a	n/a	Bedrock	Y
6707429	569214	4846473	372.4	367.4	415.96	411.08	n/a	n/a	Bedrock	Y
6710800	569858	4846123	369.4	364.4	415.97	407.69	n/a	n/a	Bedrock	Y
6709713	567678	4846188	394.5	389.5	416.1	417.22	n/a	n/a	Bedrock	Y
6705147	569413	4844769	393.8	388.8	416.14	406.92	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6711236	570697	4847263	392.6	387.6	416.17	410.96	n/a	n/a	Bedrock	Y
6706342	569414	4847323	374.8	369.8	416.18	414.13	n/a	n/a	Bedrock	Y
6700657	567894	4845359	382.4	377.4	416.54	411.57	n/a	n/a	Bedrock	Y
6707555	567714	4845423	412.0	407.0	416.96	411.86	n/a	n/a	Bedrock	Y
6708433	567375	4846783	404.9	399.9	417	424.53	n/a	n/a	Bedrock	Y
6707831	567814	4845023	372.2	367.2	417.03	409.34	n/a	n/a	Bedrock	Y
6710326	566893	4846209	370.1	365.1	417.03	422.00	n/a	n/a	Bedrock	Y
6708353	571002	4848734	391.0	386.0	417.12	418.08	n/a	n/a	Bedrock	Y
6707564	571314	4848423	401.9	396.9	417.18	415.87	n/a	n/a	Bedrock	Y
6704164	568984	4845323	397.0	392.0	417.46	410.30	n/a	n/a	Bedrock	Y
6700656	568126	4844868	391.3	386.3	417.55	408.61	n/a	n/a	Bedrock	Y
6700658	567559	4846306	383.0	378.0	417.58	419.05	n/a	n/a	Bedrock	Y
6705643	567414	4846123	390.2	385.2	417.72	417.73	n/a	n/a	Bedrock	Y
6711073	569502	4846342	395.0	390.0	417.99	409.48	n/a	n/a	Bedrock	Y
6709053	567547	4846423	397.9	392.9	418.1	420.52	n/a	n/a	Bedrock	Y
6705908	566934	4846163	390.4	385.4	418.28	420.88	n/a	n/a	Bedrock	Y
6705623	567464	4846463	400.5	395.5	418.33	421.20	n/a	n/a	Bedrock	Y
6710544	571205	4848518	395.2	390.2	418.36	416.62	n/a	n/a	Bedrock	Y
6704175	569614	4848173	387.8	382.8	418.43	422.21	n/a	n/a	Bedrock	Y
6705150	568086	4846287	388.7	383.7	418.49	416.01	n/a	n/a	Bedrock	Y
6700675	570019	4845838	386.0	381.0	418.54	407.07	n/a	n/a	Bedrock	Y
6707836	566864	4847223	406.0	401.0	418.68	431.28	n/a	n/a	Bedrock	Y
6707559	569914	4848073	382.1	377.1	418.79	419.50	n/a	n/a	Bedrock	Y
6708163	567412	4846538	402.1	397.1	418.8	422.13	n/a	n/a	Bedrock	Y
6709026	567531	4846382	398.5	393.5	418.96	420.15	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6709566	569134	4844963	395.4	390.4	419.03	408.65	n/a	n/a	Bedrock	Y
6708168	567387	4846730	403.2	398.2	419.09	424.02	n/a	n/a	Bedrock	Y
6704176	569589	4848198	388.3	383.3	419.11	422.66	n/a	n/a	Bedrock	Y
6706651	567314	4846773	404.2	399.2	419.18	424.80	n/a	n/a	Bedrock	Y
6704455	567454	4847003	405.6	400.6	419.67	425.28	n/a	n/a	Bedrock	Y
6700709	570961	4846631	387.7	382.7	419.67	405.69	n/a	n/a	Bedrock	Y
6705479	567314	4846703	403.0	398.0	419.7	424.31	n/a	n/a	Bedrock	Y
6704704	571576	4848191	394.7	389.7	419.9	413.78	n/a	n/a	Bedrock	Y
6700660	566787	4846065	397.7	392.7	420.04	421.30	n/a	n/a	Bedrock	Y
6711773	567421	4846972	401.3	396.3	420.18	425.33	n/a	n/a	Bedrock	Y
6708432	567594	4846933	405.8	400.8	420.21	423.14	n/a	n/a	Bedrock	Y
6708719	567424	4846743	404.3	399.3	420.26	423.91	n/a	n/a	Bedrock	Y
6704432	566714	4845848	410.3	405.3	420.34	419.15	n/a	n/a	Bedrock	Y
6710223	567335	4846650	403.9	398.9	420.46	423.75	n/a	n/a	Bedrock	Y
6711808	569345	4846461	377.9	372.9	420.51	410.41	n/a	n/a	Bedrock	Y
6704447	567064	4845848	398.0	393.0	420.58	417.00	n/a	n/a	Bedrock	Y
6707572	567864	4845673	393.4	388.4	420.62	413.77	n/a	n/a	Bedrock	Y
6712044	569347	4844923	394.7	389.7	420.63	407.76	n/a	n/a	Bedrock	Y
6706395	567364	4846573	404.9	399.9	420.68	422.87	n/a	n/a	Bedrock	Y
6704910	570868	4846925	383.9	378.9	420.73	407.96	n/a	n/a	Bedrock	Y
6709530	569027	4848418	405.9	400.9	420.75	428.09	n/a	n/a	Bedrock	Y
6704182	569054	4845123	388.9	383.9	420.9	409.70	n/a	n/a	Bedrock	Y
6704988	567377	4846689	404.9	399.9	420.92	423.88	n/a	n/a	Bedrock	Y
6710218	567214	4846583	404.6	399.6	421	423.80	n/a	n/a	Bedrock	Y
6708722	567235	4846710	405.3	400.3	421.07	424.81	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6709533	569032	4848393	414.8	409.8	421.19	427.87	n/a	n/a	Bedrock	Y
6705146	569719	4848033	403.4	398.4	421.24	420.30	n/a	n/a	Bedrock	Y
6709532	569027	4848442	411.9	406.9	421.25	428.36	n/a	n/a	Bedrock	Y
6706583	569214	4848473	413.9	408.9	421.28	427.56	n/a	n/a	Bedrock	Y
6707852	567164	4846823	407.6	402.6	421.35	426.11	n/a	n/a	Bedrock	Y
6710548	569791	4848098	403.4	398.4	421.75	420.50	n/a	n/a	Bedrock	Y
6707143	569764	4848123	405.1	400.1	421.79	420.95	n/a	n/a	Bedrock	Y
6709595	569834	4847973	405.4	400.4	421.84	418.89	n/a	n/a	Bedrock	Y
6704171	569634	4848173	404.7	399.7	421.85	422.21	n/a	n/a	Bedrock	Y
6710567	567154	4846831	409.3	404.3	421.99	426.24	n/a	n/a	Bedrock	Y
6710551	569634	4847672	406.3	401.3	422.01	417.28	n/a	n/a	Bedrock	Y
6707151	568414	4845723	393.7	388.7	422.19	413.10	n/a	n/a	Bedrock	Y
6709602	569745	4848059	405.3	400.3	422.31	420.42	n/a	n/a	Bedrock	Y
6706590	568614	4845323	395.2	390.2	422.92	411.39	n/a	n/a	Bedrock	Y
6708080	569664	4848123	398.5	393.5	423.2	421.53	n/a	n/a	Bedrock	Y
6706286	569574	4848223	399.5	394.5	423.36	423.03	n/a	n/a	Bedrock	Y
6707144	569664	4848273	407.3	402.3	423.63	422.99	n/a	n/a	Bedrock	Y
6710154	567876	4847308	401.4	396.4	423.65	424.37	n/a	n/a	Bedrock	Y
6710572	567085	4846863	406.5	401.5	423.68	426.95	n/a	n/a	Bedrock	Y
6710530	566954	4846933	408.5	403.5	423.85	428.34	n/a	n/a	Bedrock	Y
6709709	566879	4846853	411.0	406.0	424.18	428.20	n/a	n/a	Bedrock	Y
6704115	568764	4847223	411.1	406.1	424.49	415.23	n/a	n/a	Bedrock	Y
6709886	569405	4848417	412.5	407.5	424.59	425.92	n/a	n/a	Bedrock	Y
6700712	569004	4848354	399.3	394.3	424.68	427.61	n/a	n/a	Bedrock	Y
6703357	570184	4848273	401.0	396.0	424.99	419.49	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6705148	569795	4848098	411.4	406.4	425.1	420.50	n/a	n/a	Bedrock	Y
6709212	570116	4848219	396.4	391.4	425.15	419.44	n/a	n/a	Bedrock	Y
6708146	567881	4847890	405.2	400.2	425.37	429.44	n/a	n/a	Bedrock	Y
6711507	570228	4849191	382.5	377.5	425.39	428.30	n/a	n/a	Bedrock	Y
6706041	569314	4848473	418.8	413.8	425.42	426.99	n/a	n/a	Bedrock	Y
6705612	568840	4848356	395.6	390.6	425.47	428.59	n/a	n/a	Bedrock	Y
6709065	570567	4848720	403.2	398.2	425.63	420.90	n/a	n/a	Bedrock	Y
6704542	569434	4848483	413.8	408.8	426.07	426.37	n/a	n/a	Bedrock	Y
6707156	569814	4848273	405.2	400.2	426.12	422.06	n/a	n/a	Bedrock	Y
6710148	569082	4848616	377.3	372.3	426.22	429.55	n/a	n/a	Bedrock	Y
6703520	566584	4847283	401.5	396.5	426.32	434.04	n/a	n/a	Bedrock	Y
6703518	569004	4848873	381.5	376.5	426.66	432.37	n/a	n/a	Bedrock	Y
6709578	568859	4848859	389.2	384.2	426.83	433.08	n/a	n/a	Bedrock	Y
6705647	570514	4848673	407.2	402.2	426.89	420.79	n/a	n/a	Bedrock	Y
6706911	569064	4848723	418.4	413.4	427.63	430.68	n/a	n/a	Bedrock	Y
6710156	570480	4848893	415.9	410.9	427.78	423.48	n/a	n/a	Bedrock	Y
6700771	570664	4849203	416.1	411.1	427.79	425.77	n/a	n/a	Bedrock	Y
6700739	570583	4848804	415.2	410.2	428.07	421.65	n/a	n/a	Bedrock	Y
6700746	569464	4848468	408.0	403.0	428.15	426.01	n/a	n/a	Bedrock	Y
6708720	568791	4848303	395.1	390.1	428.19	428.38	n/a	n/a	Bedrock	Y
6700713	569185	4848623	415.5	410.5	428.22	429.11	n/a	n/a	Bedrock	Y
6703528	568634	4848703	384.7	379.7	428.4	433.10	n/a	n/a	Bedrock	Y
6706594	570714	4848973	412.7	407.7	428.49	422.67	n/a	n/a	Bedrock	Y
6710228	568207	4847890	414.7	409.7	429.31	427.31	n/a	n/a	Bedrock	Y
6711625	571312	4849051	406.2	401.2	429.57	419.55	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6712043	566646	4847156	404.9	399.9	429.7	432.28	n/a	n/a	Bedrock	Y
6710162	567449	4848214	410.7	405.7	429.79	437.17	n/a	n/a	Bedrock	Y
6704913	568918	4849017	364.8	359.8	430.24	434.23	n/a	n/a	Bedrock	Y
6708616	568719	4849027	415.1	410.1	430.36	435.31	n/a	n/a	Bedrock	Y
6707054	570814	4849023	411.7	406.7	430.75	422.41	n/a	n/a	Bedrock	Y
6703149	569034	4849223	403.3	398.3	430.8	435.23	n/a	n/a	Bedrock	Y
6711075	568765	4848930	384.1	379.1	430.94	434.40	n/a	n/a	Bedrock	Y
6710235	568896	4848874	406.2	401.2	431.28	432.96	n/a	n/a	Bedrock	Y
6708365	568793	4848858	405.3	400.3	431.34	433.40	n/a	n/a	Bedrock	Y
6709042	568731	4849270	401.1	396.1	431.46	437.95	n/a	n/a	Bedrock	Y
6707358	568714	4848823	408.5	403.5	431.46	433.54	n/a	n/a	Bedrock	Y
6709050	568646	4848767	385.8	380.8	431.56	433.63	n/a	n/a	Bedrock	Y
6700740	568722	4849233	406.5	401.5	431.68	437.67	n/a	n/a	Bedrock	Y
6707821	568814	4849473	429.3	424.3	432.07	443.42	n/a	n/a	Overburden	Y
6703077	569084	4848213	412.8	407.8	432.12	425.80	n/a	n/a	Bedrock	Y
6708174	568803	4848861	416.5	411.5	432.19	433.31	n/a	n/a	Bedrock	Y
6709537	567566	4848063	410.5	405.5	432.3	434.45	n/a	n/a	Bedrock	Y
6704915	568749	4849470	404.1	399.1	432.39	439.80	n/a	n/a	Bedrock	Y
6710806	568559	4848525	415.6	410.6	432.41	431.90	n/a	n/a	Bedrock	Y
6706282	568764	4849423	422.7	417.7	432.43	439.23	n/a	n/a	Bedrock	Y
6700742	568801	4849079	413.5	408.5	432.49	435.20	n/a	n/a	Bedrock	Y
6704716	568914	4849033	394.1	389.1	432.49	434.29	n/a	n/a	Bedrock	Y
6709156	568808	4849283	394.8	389.8	432.51	437.44	n/a	n/a	Bedrock	Y
6709207	567608	4848229	392.8	387.8	432.55	435.89	n/a	n/a	Bedrock	Y
6709548	567785	4848113	410.7	405.7	432.63	432.60	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6707813	568814	4849473	417.8	412.8	432.68	439.41	n/a	n/a	Bedrock	Y
6708153	569289	4847274	378.8	373.8	432.81	413.98	n/a	n/a	Bedrock	Y
6708360	568714	4849447	419.6	414.6	432.87	439.92	n/a	n/a	Bedrock	Y
6709702	567034	4847593	425.1	420.1	432.87	434.28	n/a	n/a	Bedrock	Y
6708388	568233	4848077	405.6	400.6	432.88	429.42	n/a	n/a	Bedrock	Y
6708347	568847	4849569	416.2	411.2	433.19	440.15	n/a	n/a	Bedrock	Y
6708346	568642	4848787	407.9	402.9	433.31	433.65	n/a	n/a	Bedrock	Y
6700738	568722	4849243	403.6	398.6	433.64	437.77	n/a	n/a	Bedrock	Y
6707860	568914	4849723	415.9	410.9	433.68	441.16	n/a	n/a	Bedrock	Y
6709157	568786	4849305	417.5	412.5	433.86	437.83	n/a	n/a	Bedrock	Y
6708154	568752	4849492	432.5	427.5	434.32	444.86	n/a	n/a	Overburden	Y
6708625	568732	4849358	427.0	422.0	434.33	443.02	n/a	n/a	Overburden	Y
6708413	568828	4849519	416.3	411.3	434.65	439.81	n/a	n/a	Bedrock	Y
6709888	568876	4849608	419.1	414.1	434.87	440.33	n/a	n/a	Bedrock	Y
6704918	568725	4849314	422.5	417.5	435.02	438.53	n/a	n/a	Bedrock	Y
6711499	570182	4849736	410.2	405.2	435.72	434.39	n/a	n/a	Bedrock	Y
6705153	569302	4847515	394.2	389.2	435.72	415.21	n/a	n/a	Bedrock	Y
6703896	568514	4848713	400.2	395.2	435.78	433.87	n/a	n/a	Bedrock	Y
6712436	568623	4849076	415.0	410.0	436.1	436.80	n/a	n/a	Bedrock	Y
6704469	568174	4849553	390.6	385.6	436.36	444.28	n/a	n/a	Bedrock	Y
6707731	566614	4848423	396.3	391.3	436.59	445.32	n/a	n/a	Bedrock	Y
6700741	568764	4849146	420.3	415.3	436.75	436.38	n/a	n/a	Bedrock	Y
6707861	568664	4848923	409.6	404.6	436.82	434.84	n/a	n/a	Bedrock	Y
6706900	568564	4848773	389.7	384.7	437.27	434.15	n/a	n/a	Bedrock	Y
6707558	568814	4849723	408.1	403.1	438.42	441.80	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6708148	569542	4850082	411.8	406.8	439.05	440.72	n/a	n/a	Bedrock	Y
6710805	570293.3	4849525	406.3	401.3	439.84	431.53	n/a	n/a	Bedrock	Y
6707164	568564.3	4848823	422.8	417.8	440.63	434.39	n/a	n/a	Bedrock	Y
6706584	568814.3	4849373	394.6	389.6	441.5	438.28	n/a	n/a	Bedrock	Y
6708389	567929.3	4848635	412.8	407.8	441.99	437.64	n/a	n/a	Bedrock	Y
6709580	566837.3	4848885	424.7	419.7	442.5	447.87	n/a	n/a	Bedrock	Y
6707858	568614.3	4849323	422.0	417.0	443.05	439.51	n/a	n/a	Bedrock	Y
6710531	566141.3	4848004	418.4	413.4	443.2	443.66	n/a	n/a	Bedrock	Y
6708826	568676.3	4849428	440.4	435.4	443.75	445.20	n/a	n/a	Overburden	Y
6704718	567064.3	4849503	385.7	380.7	444.03	451.00	n/a	n/a	Bedrock	Y
6703364	568294.3	4849423	406.7	401.7	444.77	442.39	n/a	n/a	Bedrock	Y
6708396	570346.3	4848685	404.4	399.4	444.91	422.35	n/a	n/a	Bedrock	Y
6709726	566740.3	4848952	420.4	415.4	445.69	448.98	n/a	n/a	Bedrock	Y
6703961	567144.3	4849103	425.5	420.5	447.09	447.62	n/a	n/a	Bedrock	Y
6705915	567864.3	4849643	418.3	413.3	448.1	447.42	n/a	n/a	Bedrock	Y
6709502	568399.3	4849055	452.6	447.6	448.48	444.56	n/a	n/a	Overburden	Y
6705909	568614.3	4849343	412.2	407.2	450.12	439.69	n/a	n/a	Bedrock	Y
6703169	567474.3	4850243	426.3	421.3	450.97	454.46	n/a	n/a	Bedrock	Y
6705933	568514.3	4849213	429.4	424.4	453.39	444.89	n/a	n/a	Overburden	Y
6708663	566580.3	4849279	-112.6	-117.6	454.56	449.94	n/a	n/a	Bedrock	Y
6705633	567564.3	4850323	427.6	422.6	456	454.57	n/a	n/a	Bedrock	Y
1700164	565046.3	4851813	412.1	407.1	459.38	468.64	n/a	n/a	Bedrock	Y
1700172	565445.3	4852268	405.0	400.0	461.84	469.78	n/a	n/a	Bedrock	Y
6700640	565813.3	4846073	404.6	399.6	426.14	426.67	n/a	n/a	Bedrock	Y
6700641	564344.3	4847545	404.0	399.0	443.3	443.36	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6700642	563881.3	4847890	414.9	409.9	444.62	449.33	n/a	n/a	Overburden	Y
6700659	566250.3	4845950	390.0	385.0	418.27	423.45	n/a	n/a	Bedrock	Y
6700680	565311.3	4848647	419.0	414.0	454.22	452.09	n/a	n/a	Bedrock	Y
6700681	565157.3	4850516	408.2	403.2	460.24	463.26	n/a	n/a	Bedrock	Y
6700715	565859.3	4850112	409.4	404.4	463.28	459.92	n/a	n/a	Bedrock	Y
6700716	566175.3	4849703	429.4	424.4	458.96	456.76	n/a	n/a	Bedrock	Y
6700743	567632.3	4851670	434.3	429.3	454.95	461.66	n/a	n/a	Bedrock	Y
6700744	567203.3	4850833	429.5	424.5	455.47	459.32	n/a	n/a	Bedrock	Y
6700745	566981.3	4852503	421.0	416.0	460	467.34	n/a	n/a	Bedrock	Y
6700747	565321.3	4851775	403.6	398.6	464.22	468.17	n/a	n/a	Bedrock	Y
6700773	567955.3	4851858	421.8	416.8	454.26	460.91	n/a	n/a	Bedrock	Y
6703203	567564.3	4851973	404.5	399.5	459.04	463.10	n/a	n/a	Bedrock	Y
6704116	566354.3	4845803	390.3	385.3	424.23	421.02	n/a	n/a	Bedrock	Y
6704424	566064.3	4845973	404.9	399.9	428.94	424.71	n/a	n/a	Bedrock	Y
6704723	566314.3	4851523	390.2	385.2	466.02	465.26	n/a	n/a	Bedrock	Y
6704905	566645.3	4845263	388.3	383.3	420.29	415.69	n/a	n/a	Bedrock	Y
6705292	569160.3	4851037	421.1	416.1	441.9	449.56	n/a	n/a	Bedrock	Y
6705636	564751.3	4851073	404.9	399.9	474.87	465.93	n/a	n/a	Bedrock	Y
6705651	569064.3	4851203	418.8	413.8	444.56	451.24	n/a	n/a	Bedrock	Y
6705992	565614.3	4852373	419.2	414.2	464.12	470.02	n/a	n/a	Bedrock	Y
6706037	564994.3	4849543	419.7	414.7	463.65	458.75	n/a	n/a	Bedrock	Y
6706280	568514.3	4851073	419.7	414.7	450.93	453.83	n/a	n/a	Bedrock	Y
6706917	566364.3	4845623	394.2	389.2	416.7	418.70	n/a	n/a	Bedrock	Y
6707158	565714.3	4847773	380.6	375.6	442.29	443.10	n/a	n/a	Bedrock	Y
6707159	566164.3	4849373	393.8	388.8	459.55	454.63	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6707352	566614.3	4850023	424.7	419.7	457.27	456.91	n/a	n/a	Bedrock	Y
6707355	565564.3	4846473	405.4	400.4	431.85	431.37	n/a	n/a	Bedrock	Y
6707430	565614.3	4847523	410.1	405.1	448.34	441.47	n/a	n/a	Bedrock	Y
6707560	566014.3	4845923	395.8	390.8	422.57	424.53	n/a	n/a	Bedrock	Y
6707561	568064.3	4851723	438.9	433.9	458.37	474.28	n/a	n/a	Overburden	Y
6707773	565314.3	4847173	389.5	384.5	444.23	438.99	n/a	n/a	Bedrock	Y
6707819	567014.3	4845023	400.6	395.6	408.64	411.86	n/a	n/a	Bedrock	Y
6707822	564364.3	4847173	386.7	381.7	441.02	440.18	n/a	n/a	Bedrock	Y
6708157	567474.3	4844928	391.5	386.5	404.05	407.90	n/a	n/a	Bedrock	Y
6708352	565637.3	4848328	414.3	409.3	449.23	448.52	n/a	n/a	Bedrock	Y
6708361	567663.3	4852044	408.4	403.4	455.75	462.96	n/a	n/a	Bedrock	Y
6708485	564282.3	4849595	393.9	388.9	451.82	458.60	n/a	n/a	Bedrock	Y
6708605	566441.3	4845353	398.2	393.2	416.62	417.22	n/a	n/a	Bedrock	Y
6708810	568727.3	4851931	431.3	426.3	449.54	456.94	n/a	n/a	Bedrock	Y
6708813	566764.3	4850893	406.8	401.8	466.37	461.14	n/a	n/a	Bedrock	Y
6709022	565901.3	4851735	428.9	423.9	466.4	466.07	n/a	n/a	Bedrock	Y
6709034	565457.3	4847352	385.8	380.8	441.3	440.27	n/a	n/a	Bedrock	Y
6709048	565230.3	4847040	369.2	364.2	423.13	437.65	n/a	n/a	Bedrock	Y
6709218	564239.3	4850302	422.4	417.4	465.09	475.73	n/a	n/a	Overburden	Y
6709339	565376.3	4849091	431.7	426.7	469.27	456.42	n/a	n/a	Bedrock	Y
6709340	564272.3	4847648	410.1	405.1	445.79	444.25	n/a	n/a	Bedrock	Y
6709534	566308.3	4851112	401.7	396.7	459.4	463.56	n/a	n/a	Bedrock	Y
6709547	567166.3	4850473	429.4	424.4	458.27	457.40	n/a	n/a	Bedrock	Y
6709550	567300.3	4850524	430.7	425.7	455.73	457.15	n/a	n/a	Bedrock	Y
6709710	565525.3	4846488	407.9	402.9	432.88	431.77	n/a	n/a	Bedrock	Y

Well Name	Easting	Northing	Screen/ Open Interval Top (masl)	Screen/ Open Interval Bottom (masl)	Estimated Observed Water Level (0 m ³ /day) (masl) ¹	Simulated Average Water Level (0 m ³ /day) (masl)	Estimated Observed Drawdown (0 to 890 m ³ /day) (m)	Simulated Drawdown (0 to 890 m ³ /day) (m)	Interpreted Aquifer System	WWIS Target from Tier Three Assessment (Y/N)
6709893	565049.3	4847570	412.1	407.1	449.39	443.19	n/a	n/a	Bedrock	Y
6709978	564506.3	4847273	393.4	388.4	441.98	441.01	n/a	n/a	Bedrock	Y
6710065	564146.3	4850498	427.5	422.5	469.29	476.52	n/a	n/a	Overburden	Y
6710067	565468.3	4848429	416.5	411.5	458	449.81	n/a	n/a	Bedrock	Y
6710546	564434.3	4850584	423.7	418.7	466	464.08	n/a	n/a	Bedrock	Y
6710799	568444.3	4851098	432.9	427.9	451.16	454.48	n/a	n/a	Bedrock	Y
6711062	566306.3	4845341	400.5	395.5	420.22	417.98	n/a	n/a	Bedrock	Y
6711071	565510.3	4847164	396.0	391.0	436.92	438.27	n/a	n/a	Bedrock	Y
6711385	566022.3	4846371	385.8	380.8	429.01	428.27	n/a	n/a	Bedrock	Y
6711710	565084.3	4848643	416.0	411.0	450.78	452.29	n/a	n/a	Bedrock	Y
6711782	569686.3	4850657	402.2	397.2	447.44	444.42	n/a	n/a	Bedrock	Y
6712042	566148.3	4845576	404.0	399.0	419.21	420.52	n/a	n/a	Bedrock	Y
6712152	567648.3	4851940	405.2	400.2	461.75	462.60	n/a	n/a	Bedrock	Y
6712423	566797.3	4845155	403.2	398.2	412.25	414.15	n/a	n/a	Bedrock	Y
6712438	567279.3	4844805	391.2	386.2	406.22	407.99	n/a	n/a	Bedrock	Y


n/a information not available

WWIS – Water Well Information System

Masl – meters above sea level

¹ Observed water levels for WWIS wells represent values collected over different time periods and potentially under different regional pumping conditions

APPENDIX B
Hydraulic Conductivity Updates



- Nestlé Waters Canada Property Boundary
 - Community
 - Water Body
 - Watercourse
 - Highway
 - Road
 - Production Well
- Conductivity Zone Update**
- Kx = 1×10^{-1} m/s
 - Ky = 1×10^{-1} m/s

Reference: Contains information licensed under the Open Government Licence - Ontario and information made available under the copyright of Grand River Conservation Authority Open Data Licence v3.0. Service Layer Credits.

1:27,500

 290 0 290 580 metres
 NAD 1983 UTM Zone 17N




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take
 Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities
**Aberfoyle - Hydraulic Conductivity Updates
 Coarser Grained Overburden Deposits
 (Layer 1 and 2)**

Date: September 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\FiguresandTables\CH02\B1\Report\Appendix B\Figures\B1\Aberfoyle_Hydraulic_Conductivity_Updates_Coarser_Grained_Overburden_Deposits_Layer_1_and_2.mxd - Tabbed_L_07Sep18_04:27PM - c:\user - TID005



- Nestlé Waters Canada Property Boundary
 - Community
 - Water Body
 - Watercourse
 - Highway
 - Road
 - + Production Well
- Conductivity Zone Update**
- $K_x = 2 \times 10^{-7} \text{ m/s}$
 - $K_y = 1 \times 10^{-7} \text{ m/s}$

Reference: Contains information licensed under the Open Government Licence - Ontario and information made available under the copyright © of Grand River Conservation Authority Open Data Licence v3.0. Service Layer Credits.

1:27,500 metres
 290 0 290 580
 NAD 1983 UTM Zone 17N




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take
 Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities
**Aberfoyle - Hydraulic Conductivity Updates
 Finer-Grained Overburden Deposits
 (Layer 3)**

Date: September 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\FiguresandTables\CH03\B2\Report\Appendix B\Figure B2\Aberfoyle_Hydraulic_Conductivity_Updates_Finer_Grained_Overburden_Deposits_Layer_3.mxd - Tabbed_L_107.Sep.18, 04:28 PM - curry, TID005



- Nestlé Waters Canada Property Boundary
- Community
- Water Body
- Watercourse
- Highway
- Road
- + Production Well
- Conductivity Zone Update**
- $K_y = 3 \times 10^{-7} \text{ m/s}$

Reference: Contains information licensed under the Open Government Licence – Ontario and information made available under the copyright © of Grand River Conservation Authority Open Data Licence v3.0. Service Layer Credits.

1:27,500 metres
 290 0 290 580
 NAD 1983 UTM Zone 17N




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take
 Water for the Nestle Waters Canada Aberfoyle and Erin Facilities
**Aberfoyle - Hydraulic Conductivity Updates
 Guelph Fm and Reformatory Quarry Mbr. of
 Eramosa Fm. (Layer 5 and 6)**

Date: September 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\Figures\Tables\CHG\2018\Report\Appendix B\Figure B3\Aberfoyle_Hydraulic_Conductivity_Updates_Guelph_Fm_and_Reformatory_Quarry_Mbr_of_Eramosa_Formation_Layer_5_and_6.mxd - Tabloid_L - 13-Sep-18, 02:37 PM - csury - TD006



- Nestlé Waters Canada Property Boundary
 - Community
 - Water Body
 - Watercourse
 - Highway
 - Road
 - Production Well
- Conductivity Zone Update**
- $K_x = 3 \times 10^{-6}$ m/s
 - $K_y = 3 \times 10^{-7}$ m/s

Reference: Contains information licensed under the Open Government Licence – Ontario and information made available under the copyright © of Grand River Conservation Authority Open Data Licence v3.0. Service Layer Credits.

1:27,500

 NAD 1983 UTM Zone 17N




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take
 Water for the Nestle Waters Canada Aberfoyle and Erin Facilities
Aberfoyle - Hydraulic Conductivity Updates
Vinemount Mbr. of Eramosa Fm.
(Layers 7 to 9)

Date: September 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\CityOfGuelph\26435\FiguresandTables\CHG\2018\Report\Appendix B\Figure-B4-Aberfoyle-Hydraulic-Conductivity-Updates-Vinemount-Mbr-of-Eramosa-Fm-Layer_7-to_9.mxd - Tabbed_L_13-Sep-18 02:37 PM - canny - TD005



- Nestlé Waters Canada Property Boundary
- Community
- Water Body
- Watercourse
- Highway
- Road
- Production Well

Conductivity Zone Update

- Zone 1**
- $K_x = 8 \times 10^{-8}$ m/s
 - $K_y = 1.3 \times 10^{-9}$ m/s
- Zone 2**
- $K_x = 1 \times 10^{-3}$ m/s
 - $K_y = 1 \times 10^{-4}$ m/s

Reference: Contains information licensed under the Open Government Licence - Ontario and information made available under the copyright © of Grand River Conservation Authority Open Data Licence v3.0. Service Layer Credits.

1:27,500 metres
 290 0 290 580
 NAD 1983 UTM Zone 17N




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities
Aberfoyle - Hydraulic Conductivity Updates
Goat Island Fm.
(Layers 10)

Date: September 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\FiguresandTables\CH02\B5\Report\Appendix B\Figure-B5-Aberfoyle_Hydraulic_Conductivity_Updates_Goat_Island_Fm.mxd - county - TD006



- Nestlé Waters Canada Property Boundary
 - Community
 - Water Body
 - Watercourse
 - Highway
 - Road
 - Production Well
- Conductivity Zone Update**
- $K_x = 1 \times 10^{-7}$ m/s
 - $K_y = 1 \times 10^{-8}$ m/s

Reference: Contains information licensed under the Open Government Licence – Ontario and information made available under the copyright © of Grand River Conservation Authority Open Data Licence v3.0. Service Layer Credits.

1:27,500
 290 0 290 580 metres
 NAD 1983 UTM Zone 17N




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take
 Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities
**Aberfoyle - Hydraulic Conductivity Updates
 Upper and Lower Gasport Fm.
 (Layers 11 and 13)**

Date: September 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\Figures and Tables\CH02\B6\Report\Appendix B\Figure B6\Aberfoyle_Hydraulic_Conductivity_Updates_Upper_and_Lower_Gasport_Fm_Layer_11_and_13.mxd - Tabloid_L_13_Sep-18_02:38 PM - csmj - TID005



- Nestlé Waters Canada Property Boundary
 - Community
 - Water Body
 - Watercourse
 - Highway
 - Road
 - Production Well
- Conductivity Zone Update**
- $K_x = 1 \times 10^{-7}$ m/s
 - $K_y = 1 \times 10^{-8}$ m/s

Reference: Contains information licensed under the Open Government Licence – Ontario and information made available under the copyright © of Grand River Conservation Authority Open Data Licence v3.0. Service Layer Credits.

1:27,500

 290 0 290 580
 metres
 NAD 1983 UTM Zone 17N




City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take
 Water for the Nestle Waters Canada Aberfoyle and Erin Facilities
Aberfoyle - Hydraulic Conductivity Updates
Middle Gasport Fm.
(Layers 12)

Date: September 2018 | Project: 26435 | Submitter: J. Melchin | Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\Figures\Tables\CHG\2018\Report\Appendix B\Figure B7\Aberfoyle_Hydraulic_Conductivity_Updates_Middle_Gasport_Fm_Layer_12.mxd - Tabloid_L - 13-Sep-18 02:38 PM - c:\user - 710008



- Nestlé Waters Canada Property Boundary
 - Tier Three Model Boundary
 - Water Body
 - Watercourse
 - Highway
 - Road
 - Industry Road
 - Railway
 - Production Well
- Conductivity Zone Update**
- Zone 1**
- $K_x = 6 \times 10^{-8}$ m/s
 - $K_y = 6 \times 10^{-9}$ m/s
- Zone 2**
- $K_x = 5 \times 10^{-6}$ m/s
 - $K_y = 5 \times 10^{-7}$ m/s
- Zone 3**
- $K_x = 1 \times 10^{-5}$ m/s
 - $K_y = 5 \times 10^{-6}$ m/s

Reference: Contains information licensed under the Open Government Licence - Ontario. Data obtained from Grand River Conservation Authority used under license.
Service Layer Credits:

1:87,500 metres
900 0 900 1,800
NAD 1983 UTM Zone 17N




City of Guelph
Groundwater Modelling Report for Renewal of the Permit to Take Water for the Nestlé Waters Canada Aberfoyle and Erin Facilities

**Erin Hydraulic Conductivity Updates
Finer-Grained Overburden Deposits
(Layer 3)**

Date: September 2018 Project: 26435 Submitter: J. Melchin Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\FiguresandTables\GHG\2018\Report\Appendix B\Figures\Erin_Hydraulic_Conductivity_Updates_Finer_Grained_Overburden_Deposits_Layer_3.mxd - Tab01_L_13-Sep-18_08:19:AM - canny - ITD005



- Nestlé Waters Canada Property Boundary
 - Tier Three Model Boundary
 - Water Body
 - Watercourse
 - Highway
 - Road
 - Industry Road
 - Railway
 - Production Well
- Conductivity Zone Update**
- Zone 1**
- $K_x = 6 \times 10^{-6}$ m/s
 - $K_y = 6 \times 10^{-7}$ m/s
- Zone 2**
- $K_x = 3 \times 10^{-5}$ m/s
 - $K_y = 3 \times 10^{-6}$ m/s
- Zone 3**
- $K_x = 1 \times 10^{-4}$ m/s
 - $K_y = 1 \times 10^{-5}$ m/s
- Zone 4**
- $K_x = 8 \times 10^{-5}$ to 8×10^{-4} m/s
 - $K_y = 8 \times 10^{-6}$ to 8×10^{-5} m/s

Reference: Contains information licensed under the Open Government Licence - Ontario. Data obtained from Grand River Conservation Authority used under license.
 Service Layer Credits: 1:87,500 metres
 NAD 1983 UTM Zone 17N



City of Guelph
 Groundwater Modelling Report for Renewal of the Permit to Take
 Water for the Nestle Waters Canada Aberfoyle and Erin Facilities

**Erin Hydraulic Conductivity Updates
 Guelph Fm.
 (Layer 5 through 10)**

Date: September 2018 Project: 26435 Submitter: J. Melchin Reviewer: D. Van Vliet

Disclaimer: The information contained herein may be compiled from numerous third party materials that are subject to periodic change without prior notification. While every effort has been made by Matrix Solutions Inc. to ensure the accuracy of the information presented at the time of publication, Matrix Solutions Inc. assumes no liability for any errors, omissions, or inaccuracies in the third party material.

I:\Client\Guelph\26435\Figures and Tables\GHG\2018\Report\Appendix B\Figure B11- Erin_Hydraulic_Conductivity_Updates_Guelph_Fm_Layer_5_through_10.mxd - Table B11 - 13-Sep-18, 02:37 PM - csmr - TD005

APPENDIX L

Well Interference Protocol

TOWN OF ERIN

5684 Wellington Rd. 24, R.R #2
Hillsburgh, Ontario N0B 1Z0



Office of the Town Manager

Telephone: (519) 855-4407 ext. 223

Fax: (519) 855-4821

E-mail: lisa.hass@town.erin.on.ca

June 19, 2009

John B. Challinor II
Director of Corporate Affairs
Nestle Waters Canada
101 Brock Road South
Guelph, ON N1H 6H9

Dear John:

Re: Well Protection Agreement

Please find enclosed two (2) copies of the Well Protection Agreement between Nestle Waters and the Town of Erin.

Please sign and return one (1) copy to this office.

It has been a pleasure working with you on this matter.

Yours truly,

A handwritten signature in cursive script, appearing to read "Lisa Hass".

Lisa Hass
Town Manager

WELL PROTECTION AGREEMENT

THIS AGREEMENT is made as of JUNE 16, 2009 between The Corporation of the Town of Erin (the "Town") and Nestlé Waters Canada, a division of Nestlé Canada Inc. ("NWC").

RECITAL:

The parties wish to set out in this Agreement the procedure and terms on which complaints, if any, that may be raised by the Well Owners about their wells being affected by NWC Operations may be received, investigated and, if found to be caused by NWC Operations, remedied by NWC.

FOR GOOD AND VALUABLE CONSIDERATION the receipt and sufficiency of which is acknowledged, the parties agree as follows:

1. Definitions

In this Agreement, unless the context otherwise requires:

"**Agreement**" means this agreement as it may be amended from time to time.

"**Applicant**" has the meaning given to it in Section 3(3).

"**Assessed Owners**" has the meaning given to it in Section 4(1).

"**Business Day**" means any day except Saturday, Sunday or a statutory holiday in the Province of Ontario.

"**Committee**" has the meaning given to it in Section 2.

"**Cone of Depression**" means such area of influence as may be agreed to between the Town and NWC relating to NWC Operations within the Town.

"**Contractor**" has the meaning given to it in Section 5(1).

"**GRCA**" means the Grand River Conservation Authority.

"**including**" means to include without limitation.

"**NWC Operations**" means the present and future operations by NWC of NWC's production water wells in the Town of Erin, County of Wellington, Ontario.

"**Well Owner**" means such owners from time to time who have a water supply well within the Cone of Depression.

2. Well Protection Committee

- (1) The parties shall establish a committee called the “Well Protection Committee” (the “Committee”) comprising of five (5) members, being: (a) two (2) members appointed by NWC (each, a “NWC Member”); (b) two (2) members appointed by the Town (each, a “Town Member”); and (c) one (1) member appointed by the GRCA who is a member of GRCA’s board of directors or professional staff (the “GRCA Member”) (each such person referred to in subsections (a) to (c) above may be referred to as a “Member” and, collectively, as the “Members”). The Members should, to the extent reasonably possible, have a strong technical understanding of hydrogeology. The Members shall be appointed for a term up to four (4) years and may be re-appointed.
- (2) The Committee shall meet monthly unless otherwise determined by it. A quorum for a meeting shall be constituted by the attendance of at least: (a) one (1) NWC Member; (b) one (1) Town Member; and (c) the GRCA Member. Members may participate by telephone or by web-based or video conference call or other electronic means (and as a result be deemed to be in attendance) at a meeting of the Committee.
- (3) Decisions of the Committee shall require the approval of a majority of those in attendance at a meeting at which a quorum is constituted.
- (4) At meetings of the Committee, the Committee shall review any water use or private water well issues relating to NWC Operations. A long-term meeting schedule shall be decided on by the Committee.
- (5) The Committee shall keep an active log of all correspondence and arrange for minutes to be prepared of each meeting.
- (6) Any Member may call a meeting of the Committee on ten (10) days’ prior written notice to the other Members. Such notice shall set out the reason for the meeting and include any relevant documents or information.

3. Well Owners

- (1) NWC shall prepare and deliver to the Committee a list of the addresses of all current Well Owners. NWC will update such list from time to time as it learns of changes relating to the Well Owners.
- (2) NWC shall send a package, approved by the Committee, to each Well Owner consisting of: (a) a letter to the Well Owner describing this Agreement; (b) a copy of this Agreement; (c) a laminated card outlining the process to follow in case of a claim or problem; (d) contact information; and (e) such other information as may be approved by the Committee.
- (3) If an owner of a water well located in the Town but outside of the Cone of Depression (the “Applicant”) wishes to be treated as a Well Owner, such Well Owner may request

this in writing to the Committee. The Committee will review the request. If the Committee, based on scientific evidence, believes that the Applicant may be affected by NWC Operations, the Committee may, in its absolute discretion, decide to deem the Applicant to be a Well Owner despite being outside of the Cone of Depression. In any event, the Committee will inform the Applicant of the Committee's decision. The Committee's decision shall be final.

4. **Well Assessment**

- (1) NWC will at its expense arrange for a residential, agricultural or commercial well assessment to be conducted with respect to each Well Owner's well and for owners of properties in the Town immediately adjacent to the Cone of Depression (collectively, the "Assessed Owners"). The assessment will include: well location, type of casing and other well construction details, well depth, water level, depth of pump intake, condition of well and pump, history of water quantity and quality issues, source aquifer and municipal address. In conducting the assessment, account will be taken of public information, information from the Assessed Owners and, where appropriate, from actual testing of the well in question.
- (2) NWC shall seek permission to access the well, but no formal written site access agreement will be required by NWC, and NWC shall not be required to pay for access rights. If access to the well is limited or denied by the Assessed Owners, then the assessment will still be conducted to the extent possible, but the parties acknowledge that the assessment may be incomplete.

5. **Well Contractors**

- (1) NWC shall enter into a contractual arrangement with up to two (2) professional licensed well contractors (a "Contractor") to provide the services contemplated of Contractors under this Agreement on a seven (7)-day-a-week basis.
- (2) NWC shall deliver to each Contractor a list of the addresses of the Well Owners and a description of the Cone of Depression and provide updates of such list to each Contractor as necessary from time to time.

6. **Well Owner Complaints**

- (1) If a Well Owner in good faith believes that the quantity or quality of the water from its well located within the Cone of Depression is being adversely affected by NWC Operations (the "Problem"), then the following procedure shall be followed:
 - (a) the Well Owner shall contact, as soon as possible, one of the Contractors;
 - (b) such Contractor, at NWC's cost, will respond to all calls within 24 hours; and

- (c) the Contractor will deliver five (5) cases of bottled water (consisting of at least 60 litres in total) to the Well Owner at NWC's cost within 24 hours after the Well Owner's call.
- (2) NWC will instruct the Contractor to investigate the cause of the Problem as soon as reasonably possible. NWC will continue to provide a suitable alternate water supply to the Well Owner while the Contractor investigates.
 - (3) If the Contractor determines that the cause of the Problem is a mechanical issue or otherwise unrelated to NWC Operations (a "**Non-NWC Failure**"), then the Contractor will issue a written report to that effect and deliver it to the Well Owner with a copy to the Committee and NWC. There will be no further action by NWC.
 - (4) If, however, the Contractor does not determine that the Problem is a Non-NWC Failure, then, NWC, at NWC's cost, and to the extent reasonably possible, within 24 hours after receiving the Contractor's report shall: (a) inform the Committee; (b) take all reasonable steps to arrange for an alternative water supply; and (c) arrange for a qualified independent consultant to undertake a scientific study of the Problem.
 - (5) The scientific study shall be documented in a written report (the "**Report**"), prepared in a timely manner, which summarizes all relevant information regarding the Problem, its cause, and recommendations regarding possible mitigation. The Report must be signed and stamped by a Professional Geoscientist (P.Geo.) or Professional Engineer (P.Eng.) licensed in the Province of Ontario.
 - (6) NWC shall promptly deliver a copy of the Report to the Committee and the Well Owner.
 - (7) If the Report concludes that the Problem was materially caused by NWC Operations, then NWC shall so inform the Committee and the Well Owner and NWC shall also promptly provide a copy of the Report to the appropriate Director of the Ontario Ministry of the Environment ("**MOE**"). Subject to subsection 6(8) below, NWC shall promptly take all reasonable steps to remedy the Problem and shall promptly report the details and results of such remedial action to the Committee, the Well Owner and the Director of the MOE.
 - (8) If the Report concludes that the Problem was materially caused by NWC Operations, NWC shall be entitled to advise the Committee, the Well Owner and the Director of the MOE, at the time that NWC delivers the first Report, that it intends to arrange for a second scientific study and Report in order to obtain a second opinion. NWC will continue to provide the Well Owner with a suitable alternative water supply while the second opinion is being obtained. If the second Report concludes that the Problem was not materially caused by NWC Operations, then NWC shall promptly inform the Committee, the Well Owner and the Director of the MOE of that conclusion in writing and, unless the Well Owner promptly notifies the Committee that the Well Owner disputes the conclusion of the Report, no further action will be required of NWC.

- (9) If, however, the Report concludes that the Problem was not materially caused by NWC Operations, then NWC shall promptly inform the Committee and the Well Owner of that conclusion in writing and, unless the Well Owner promptly notifies the Committee that the Well Owner disputes the conclusion of the Report, no further action will be required of NWC.
- (10) If the Well Owner disputes the conclusion of the Report or of a second Report if obtained by NWC, then the Well Owner shall promptly notify in writing the Committee of its dispute. Within five (5) Business Days after receiving such notice and after giving each of the Contractor, NWC and the Well Owner similar opportunities to present their position (or within such longer period as the Committee may require), the Committee shall determine whether NWC materially caused the Problem. The Committee may in its discretion also request the Director of the MOE to provide its opinion to the Committee prior to making any such determination. The Committee shall provide its determination in writing to NWC, the Well Owner and the Director of the MOE and the Committee's decision is final, unless the Director of the MOE notifies the Committee in writing that the Director has made a different determination, in which case the Director's determination shall govern.
- (11) If the Committee finds that the Problem was materially caused by NWC Operations, then NWC at its cost shall promptly remedy the Problem, including paying the cost of providing the Well Owner with an alternate water supply during the dispute process and paying the Well Owner's direct costs incurred in relation to the dispute, as determined by the Committee.
- (12) If the Committee finds that the Problem was caused by a Non-NWC Failure, the Committee will send a copy of its decision to the Well Owner and no further action will be required of NWC in relation to that matter.
- (13) If the Well Owner limits or denies access to the Contractor or to the consultant engaged to do the scientific study contemplated above, then NWC shall not be responsible for remedying the Problem raised by the Well Owner. Such access includes, as necessary or appropriate, such tests as may be required or appropriate to assist in determining the cause of the Problem (such as collecting water samples or conducting pumping tests).

7. Term

This Agreement shall remain in full force until NWC is no longer carrying on NWC Operations or the Town and NWC agree in writing to terminate this Agreement (whichever occurs earlier).

8. Notices

- (1) Any notice required or permitted to be given by either party under this Agreement to the other shall be in writing and shall be delivered or sent by registered mail (except during a postal disruption or threatened postal disruption) or fax or email to the applicable address set out below:

- (a) in the case of the Town, to:

The Corporation of the Town of Erin
5684 Trafalgar Rd. (WCR #24), R. R. # 2
Hillsburgh, ON N0B 1Z0

Attention: Ms. Lisa Hass, Town Manager
Telephone: (519) 855-4407
Facsimile: (519) 855-4821
E-mail: lisa.hass@erin.ca

- (b) in the case of NWC, to:

Mr. Dennis German, Natural Resources Manager
Nestlé Waters Canada
101 Brock Road South
Guelph, Ontario N1H 6H9
Telephone: (888) 565-1445, Ext. 6376
Facsimile: (519) 763-5046
E-mail: dennis.german@waters.nestle.com

- (2) The contact information for the Director of the MOE is:

Director, Permits to Take Water
Ontario Ministry of the Environment, Guelph District Office
1 Stone Road W.
Guelph ON N1G 4Y2
Toll free: (800) 265-8658
Tel: (519) 826-4255
Facsimile: (519) 826-4286

- (3) Any notice delivered shall be deemed to have been validly and effectively given on the day of such delivery. Any notice sent by registered mail shall be deemed to have been validly and effectively given on the third (3rd) Business Day following the date of mailing. Any notice sent by fax or email shall be deemed to have been validly and effectively given on the day the fax or email is sent if sent before 4:00 p.m. but if after 4:00 p.m., then on the next Business Day after it was sent.
- (4) Either party may from time to time by notice to the other change its address for service under this Agreement.

9. General

- (1) The parties agree to cooperate in the implementation of this Agreement with the intent that good faith complaints from Well Owners should be addressed promptly, fairly and reasonably on their merits. Each party shall do such further things and execute such

further documents as may be reasonably required by the other party to more fully implement the intent of this Agreement.

- (2) This Agreement shall enure to the benefit of, and bind, the parties to it and their respective successors and permitted assigns provided that the Town shall not assign this Agreement (other than to a successor municipality) without the prior written consent of NWC, which consent shall not be unreasonably withheld.
- (3) A waiver of any default, breach or non-compliance under this Agreement is not effective unless in writing and signed by the party to be bound by the waiver. No waiver will be inferred from or implied by any failure to act or delay in acting by a party in respect of any default, breach or non-observance or by anything done or omitted to be done by the other party. The waiver by a party of any default, breach or non-compliance under this Agreement will not operate as a waiver of that party's rights under this Agreement in respect of any continuing or subsequent default, breach or non-observance (whether of the same or any other nature).
- (4) No amendment of this Agreement will be effective unless made in writing and signed by the parties.
- (5) This Agreement is in addition to, and does not replace, or supersede, any rights a Well Owner may have at law or in equity, including under municipal, provincial or federal statutes or regulations.
- (6) Despite anything else in this Agreement, this Agreement shall be solely for the benefit of the Town and NWC and no Well Owner is a party to this Agreement and no Well Owner shall have any rights under this Agreement including as a third party beneficiary.


10. **Interpretation**

- (1) This Agreement constitutes the entire agreement between the parties with respect to the subject matter of it and cancels and supersedes any prior agreements, undertakings, declarations or representations, written or verbal in respect of it.
- (2) Any provision of this Agreement that is prohibited or unenforceable in any jurisdiction will, as to that jurisdiction, be ineffective to the extent of such prohibition or unenforceability and will be severed from the balance of this Agreement, all without affecting the remaining provisions of this Agreement or affecting the validity or enforceability of such provision in any other jurisdiction.
- (3) The division of this Agreement into Sections, the insertion of headings, and the provision of any table of contents, are for convenience of reference only and will not affect the construction or interpretation of this Agreement.
- (4) Unless the context requires otherwise, words importing the singular include the plural and *vice versa* and words importing gender include all genders.

- (5) This Agreement will be governed by and construed in accordance with the laws of the Province of Ontario and the laws of Canada applicable in that Province.
- (6) This Agreement may be executed by fax or in counterpart, or both.

The parties have executed and deliver this Agreement as of the date first written above.


THE CORPORATION OF THE TOWN OF ERIN

By: 
Name: Rob F. Lunn
Title: Mayor

By: 
Name: Lisa Hass
Title: Town Manager

I/We have authority to bind the Corporation.

NESTLÉ WATERS CANADA, a division of NESTLÉ CANADA INC.

By: 
Name: Rob Lunn
Title: CEO

By: 
Name: Chris McNeil
Title: CEO

I/We have authority to bind the Corporation

PRIVATE WELL INTERFERENCE COMPLAINTS RESOLUTION AGREEMENT

THIS AGREEMENT is made as of _____, 20__ (the “**Effective Date**”) between the Corporation of the Town of Erin (the “**Town**”) and Nestlé Waters Canada, a division of Nestlé Canada Inc. (“**NWC**”).

RECITAL:

The parties wish to set out in this Agreement the procedure and terms on which complaints, if any, that may be raised by the Well Owners about their wells being affected by NWC Operations may be received, investigated and, if found to be caused by NWC Operations, remedied by NWC.

FOR GOOD AND VALUABLE CONSIDERATION the receipt and sufficiency of which is acknowledged, the parties agree as follows:

1. Key Definitions

In this Agreement, unless the context otherwise requires:

- (1) "**Agreement**" means this Private Well Interference Complaints Resolution Agreement as it may be amended from time to time.
- (2) "**Business Day**" means any day except Saturday, Sunday or a statutory holiday in the Province of Ontario.
- (3) "**Committee**" has the meaning given to it in Section 2(1).
- (4) "**Contractor**" has the meaning given to it in Section 5(1).
- (5) "**GRCA**" means the Grand River Conservation Authority.
- (6) “**including**” means to include without limitation.
- (7) "**NWC Operations**" means the present and future operations by NWC of NWC's production water wells in the Town of Erin, County of Wellington, Ontario.
- (8) “**PTTW**” means a Permit to Take Water under the *Ontario Water Resources Act* and any applicable regulations, which is applicable to at least part of the Potential Well Interference Area.
- (9) "**Well Owner**" means such owners from time to time who have a water supply well within the Potential Well Interference Area.
- (10) "**Potential Well Interference Area**" means the area defined in the attached **Schedule A**.

2. Well Protection Committee

- (1) The parties shall establish a committee called the "Well Protection Committee" (the "**Committee**") comprised of five members (the "**Members**") being: (a) two members appointed by NWC (each, a "**NWC Member**"); (b) one member appointed by the Town (each, a "**Town Member**"); (c) one member appointed by the GRCA who is a member of GRCA's board of directors or professional staff (the "**GRCA Member**") and one member appointed by the Ministry of Environment, Conservation, and Parks (the "**MECP**"). The Members should, to the extent reasonably possible, have a strong technical understanding of hydrogeology.
- (2) The Committee shall meet quarterly unless otherwise determined by the Committee that an additional meeting is required. A quorum for a meeting shall be constituted by the attendance of at least: (a) one NWC Member; and (b) one Town Member. Members may participate by telephone or by web-based or video conference call or other electronic means (and as a result be deemed to be in attendance) at a meeting of the Committee.
- (3) Decisions of the Committee shall require the approval of a majority of those in attendance at a meeting at which a quorum is constituted, subject to the jurisdiction of the MECP, where applicable.
- (4) At meetings of the Committee, the Committee may review and discuss any outstanding Complaints (defined in Section 6 below) related to NWC Operations.
- (5) The Committee may, if it determines it relevant and beneficial to do so, keep an active log of all correspondence and arrange for minutes to be prepared of each meeting.
- (6) Any Member may call a meeting of the Committee on ten days' prior written notice to the other Members. Such notice shall set out the reason for the meeting and include any relevant documents or information.

3. Well Owners

- (1) At the Committee's reasonable request, NWC shall prepare and deliver to the Committee a list of the addresses of all current Well Owners. At the Committee's reasonable request, NWC, with the assistance of the Town, will update such list from time to time to reflect changes relating to the Well Owners.
- (2) NWC shall make commercially reasonable efforts to, within sixty (60) days of receiving a new PTTW or a renewal of an existing PTTW, send a package to each then-current Well Owner consisting of: (a) a letter to the Well Owner describing this Agreement; (b) a copy of this Agreement; (c) a laminated card outlining the process to follow in case of a claim or problem; (d) contact information; and (e) such other information as may be approved by the Committee,

4. Private Well Survey

- (1) As part of its periodic applications for and renewals of its relevant PTTWs, where required by the permitting process, NWC will, at its expense, arrange for a well survey to be

conducted with respect to each Well Owner's well. The assessment may include: well location, type of casing and other well construction details, well depth, water level, depth of pump intake, condition of well and pump, history of water quantity and quality issues, source aquifer and municipal address. In conducting the assessment, account will be taken of public information, information from the Well Owners and, where appropriate, from actual testing of the well in question.

- (2) NWC shall seek permission to access the well, but no formal written site access agreement will be required by NWC, and NWC shall not be required to pay for access rights. If access to the well is limited or denied by the Well Owners, then the assessment will still be conducted to the extent possible, but the parties acknowledge that the assessment may be incomplete.

5. Use of Independent Well Contractors

- (1) NWC shall enter into a contractual arrangement with up to two professional licensed well contractors (a "**Contractor**") to provide, if necessary, the services contemplated of Contractors under this Agreement on a seven day-a-week basis.
- (2) NWC shall deliver to each Contractor a list of the addresses of the Well Owners and a description, including a map, of the Potential Well Interference Area and provide updates of such list to each Contractor as necessary from time to time.
- (3) NWC shall also deliver to each Well Owner the contact information for one or more Contractors.

6. Well Owner Complaints

- (1) If a Well Owner in good faith believes that the quantity or quality of the water from its well located within the Potential Well Interference Area is being adversely affected by NWC Operations (a "**Complaint**"), then the following procedure shall be followed:
 - (a) the Well Owner shall contact, as soon as possible, one of the Contractors, who will subsequently notify NWC, to ensure NWC is immediately aware of the issue;
 - (b) such Contractor, at NWC's cost, will respond to all calls within 24 hours; and
 - (c) the Contractor will deliver five (5) cases of bottled water (consisting of at least 60 litres in total) to the Well Owner at NWC's cost within 24 hours after the Well Owner's call.
- (2) NWC will instruct the Contractor to investigate the cause of the Complaint as soon as reasonably possible. NWC will continue to provide a suitable alternate water supply to the Well Owner while the Contractor investigates.
- (3) If the Contractor determines that the cause of the Complaint is a mechanical issue or otherwise unrelated to NWC Operations (a "**Non-NWC Failure**"), then the Contractor will issue a written report to that effect and deliver it to the Well Owner with a copy to the Committee, the Town and NWC. There will be no further action by NWC.

- (4) If, however, the Contractor does determine that the water from the well has been adversely affected, and does not determine that the Complaint is a Non-NWC Failure, then, NWC, at NWC's cost, shall: (a) take all reasonable steps to arrange for an alternative water supply; and (b) arrange for a qualified independent consultant (which may in appropriate circumstances be the Contractor) to undertake a scientific study of the Complaint. To the extent reasonably possible, NWC shall take the foregoing steps within twenty-four (24) hours after receiving the Contractor's report.
- (5) The scientific study shall be documented in a written report (the "**Report**"), prepared in a timely manner and shall summarize all relevant information regarding the Complaint, its cause, and recommendations regarding possible mitigation. The Report must be signed and stamped by a Professional Geoscientist (P.Geo.) or Professional Engineer (P.Eng.) licensed in the Province of Ontario.
- (6) NWC shall promptly deliver a copy of the Report to the Well Owner.
- (7) If the Report concludes that the Complaint was caused by NWC Operations, then NWC shall so inform the Committee and the Well Owner and NWC shall also promptly provide a copy of the Report to the appropriate Manager of the MECP. Subject to Section 6(8) below, NWC shall promptly take all reasonable steps to remedy the Complaint and shall promptly report the details and results of such remedial action to the Committee, the Well Owner and the Manager of the MECP.
- (8) If the Report concludes that the Complaint was not caused by NWC Operations, then NWC shall promptly inform the Committee and the Well Owner of that conclusion in writing and no further action will be required of NWC.
- (9) Any complaints, whether caused by NWC or not, shall be logged by NWC and form part of its annual reporting requirements.
- (10) If the Well Owner limits or denies access to the Contractor or to the consultant engaged to do the scientific study contemplated above, then NWC shall not be responsible for remedying the Complaint raised by the Well Owner. Such access includes, as necessary or appropriate, such tests as may be required or appropriate to assist in determining the cause of the Complaint. The MECP shall be so notified.
- (11) In managing any Complaints, NWC shall comply with the terms of its applicable PTTWs.

7. Term

This Agreement shall commence on the Effective Date and, unless terminated earlier pursuant to the terms of this Agreement, shall remain in effect until NWC ceases to have any valid PTTWs applicable to the Potential Well Interference Area, at which point this Agreement shall immediately expire automatically. Notwithstanding the foregoing, either party may terminate this Agreement at any time, without cause or penalty, upon not less than six (6) months' prior written notice to the other party.

8. Notices

(1) Any notice required or permitted to be given by either party under this Agreement to the other shall be in writing and shall be delivered or sent by registered mail (except during a postal disruption or threatened postal disruption) or fax or email to the applicable address set out below:

(a) in the case of the Town, to:

The Corporation of the Town of Erin
5684 Trafalgar Rd. (WCR #24), R.R.#2
Hillsburgh, ON
N0B 1Z0
Attention: Nathan Hyde
Tel: (519) 855-4407 ext. 222
Fax: (519) 855-4821
E-mail: Nathan.Hyde@erin.ca

(b) in the case of NWC, to:

Natural Resource Manager, Nestlé Waters Canada
Nestlé Waters Canada, a division of Nestlé Canada Inc.
101 Brock Road,
Puslinch, ON
N0B 2J0
No: 519-767-6422

And

General Counsel
Nestlé Canada Inc.
25 Sheppard Avenue West,
North York, ON
M2N 6S8
No: 1-416-218-2816

(2) The contact information for the Manager of the MECP is:

Dan Dobrin, Manager
Ontario Ministry of the Environment, Conservation, and Parks, Section 34.1
Ontario Water Resources Act, R.S.O. 1990
12th Floor
119 King St W
Hamilton ON L8P 4Y7
Fax: (905) 521-7820

- (3) Any notice delivered shall be deemed to have been validly and effectively given on the day of such delivery. Any notice sent by registered mail shall be deemed to have been validly and effectively given on the third Business Day following the date of mailing. Any notice sent by fax or email shall be deemed to have been validly and effectively given on the day the fax or email is sent if sent before 4:00 p.m. but if after 4:00 p.m., then on the next Business Day after it was sent.
- (4) Either party may from time to time by notice to the other change its address for service under this Agreement.

9. General

- (1) The parties agree to cooperate in the implementation of this Agreement with the intent that good faith complaints from Well Owners should be addressed promptly, fairly and reasonably on their merits. Each party shall do such further things and execute such further documents as may be reasonably required by the other party to more fully implement the intent of this Agreement.
- (2) This Agreement shall enure to the benefit of, and bind, the parties to it and their respective successors and permitted assigns provided that the Town shall not assign this Agreement (other than to a successor municipality) without the prior consent of NWC, which consent shall not be unreasonably withheld.
- (3) A waiver of any default, breach or non-compliance under this Agreement is not effective unless in writing and signed by the party to be bound by the waiver. No waiver will be inferred from or implied by any failure to act or delay in acting by a party in respect of any default, breach or non-observance or by anything done or omitted to be done by the other party. The waiver by a party of any default, breach or non-compliance under this Agreement will not operate as a waiver of that party's rights under this Agreement in respect of any continuing or subsequent default, breach or non-observance (whether of the same or any other nature).
- (4) No amendment of this Agreement will be effective unless made in writing and signed by the parties.
- (5) This Agreement is in addition to, and does not replace, or supersede, any rights a Well Owner may have at law or in equity, including under municipal, provincial or federal statutes regulations.
- (6) Despite anything else in this Agreement, this Agreement shall be solely for the benefit of the Town and NWC and no Well Owner is a party to this Agreement and no Well Owner shall have any rights under this Agreement including as a third party beneficiary.

10. Interpretation

- (1) This Agreement constitutes the entire agreement between the parties with respect to the subject matter of it and cancels and supersedes any prior agreements, undertakings, declarations or representations, written or verbal in respect of it.

- (2) Any provision of this Agreement that is prohibited or unenforceable in any jurisdiction will, as to that jurisdiction, be ineffective to the extent of such prohibition or unenforceability and will be severed from the balance of this Agreement, all without affecting the remaining provisions of this Agreement or affecting the validity or enforceability of such provision in any other jurisdiction.
- (3) The division of this Agreement into Sections, the insertion of headings, and the provision of any table of contents, are for convenience of reference only and will not affect the construction or interpretation of this Agreement.
- (4) Unless the context requires otherwise, words importing the singular include the plural and vice versa and words importing gender include all genders.
- (5) This Agreement will be governed by and construed in accordance with the laws of the Province of Ontario and the laws of Canada applicable in that Province.
- (6) This Agreement may be executed by fax or in counterpart, or both.


The parties have executed and deliver this Agreement as of the date first written above.

**THE CORPORATION OF THE TOWN OF NESTLÉ WATERS CANADA,
ERIN** **A DIVISION OF NESTLÉ CANADA INC.**

By: _____	By: _____
Name:	Name:
Title:	Title:
Date:	Date:
I have the authority to bind the corporation.	I have the authority to bind the corporation.

Schedule A

Potential Well Interference Area





golder.com